



STATE OF FLORIDA
DEPARTMENT OF HEALTH
ON-SITE SEWAGE TREATMENT AND DISPOSAL
SYSTEM

FILED
NES
PERMIT #: 12-SC-3186339
APPLICATION #: AP2246562
DATE PAID: _____
FEE PAID: _____
RECEIPT #: _____
DOCUMENT #: PR2321232

CONSTRUCTION PERMIT FOR: OSTDS New
APPLICANT: ALEXANDER**25-0691 REVILLE
PROPERTY ADDRESS: 987 SW MONTEGO AVE. Lake City, FL 32024
LOT: _____ BLOCK: _____ SUBDIVISION: _____
PROPERTY ID #: 00464007 [SECTION, TOWNSHIP, RANGE, PARCEL NUMBER]
[OR TAX ID NUMBER]

SYSTEM MUST BE CONSTRUCTED IN ACCORDANCE WITH SPECIFICATIONS AND STANDARDS OF SECTION 381.0065, F.S., AND CHAPTER 64E-6, F.A.C. DEPARTMENT APPROVAL OF SYSTEM DOES NOT GUARANTEE SATISFACTORY PERFORMANCE FOR ANY SPECIFIC PERIOD OF TIME. ANY CHANGE IN MATERIAL FACTS, WHICH SERVED AS A BASIS FOR ISSUANCE OF THIS PERMIT, REQUIRE THE APPLICANT TO MODIFY THE PERMIT APPLICATION. SUCH MODIFICATIONS MAY RESULT IN THIS PERMIT BEING MADE NULL AND VOID. ISSUANCE OF THIS PERMIT DOES NOT EXEMPT THE APPLICANT FROM COMPLIANCE WITH OTHER FEDERAL, STATE, OR LOCAL PERMITTING REQUIRED FOR DEVELOPMENT OF THIS PROPERTY.

SYSTEM DESIGN AND SPECIFICATIONS

T [1,050] GALLONS / GPD _____ CAPACITY
A [] GALLONS / GPD N/A CAPACITY
N [] GALLONS GREASE INTERCEPTOR CAPACITY [MAXIMUM CAPACITY SINGLE TANK:1250 GALLONS]
K [] GALLONS DOSING TANK CAPACITY [] GALLONS @ [] DOSES PER 24 HRS #Pumps []

D [616] SQUARE FEET _____ SYSTEM
R [] SQUARE FEET N/A SYSTEM
A TYPE SYSTEM: [] STANDARD [] FILLED [x] MOUND []
I CONFIGURATION: [x] TRENCH [] BED []

F LOCATION OF BENCHMARK: Power pole north of site

I ELEVATION OF PROPOSED SYSTEM SITE [36.00] [INCHES / FT] [ABOVE / BELOW] BENCHMARK/REFERENCE POINT
E BOTTOM OF DRAINFIELD TO BE [36.00] [INCHES / FT] [ABOVE / BELOW] BENCHMARK/REFERENCE POINT

D FILL REQUIRED: [18.00] INCHES EXCAVATION REQUIRED: [] INCHES

O
T
H
E
R
The system is sized for 4 bedrooms with a maximum occupancy of 8 persons (2 per bedroom), for a total estimated flow of 400 gpd.

SPECIFICATIONS BY: Robert Ford TITLE: Master Contractor

APPROVED BY: Kyle E Roberts TITLE: Environmental Manager Columbia CHD

DATE ISSUED: 09/08/2025 EXPIRATION DATE: 03/08/2027

DEP 4015, 06-21-2022 (Obsoletes previous editions which may not be used)
Incorporated 62-6.004, FAC



STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
ONSITE SEWAGE TREATMENT AND DISPOSAL
SYSTEM (OSTDS)

PERMIT NO. 25-0691
DATE PAID: 9.2.25
FEE PAID: \$210.00
RECEIPT #: 2246562

APPLICATION FOR CONSTRUCTION PERMIT

APPLICATION FOR:

New System Existing System Holding Tank Innovative
 Repair Abandonment Temporary

APPLICANT: Alexander Reville EMAIL: NFLSEPTICTANK@COMCAST.NET

AGENT: ROBERT FORD III-NORTH FLORIDA SEPTIC TANK INC TELEPHONE: 386-755-6372

MAILING ADDRESS: 741 SE STATE ROAD 100, LAKE CITY FL 32025

TO BE COMPLETED BY APPLICANT OR APPLICANT'S AUTHORIZED AGENT. SYSTEMS MUST BE CONSTRUCTED BY A PERSON LICENSED PURSUANT TO 489.105(3)(m) OR 489.552, FLORIDA STATUTES. IT IS THE APPLICANT'S RESPONSIBILITY TO PROVIDE DOCUMENTATION OF THE DATE THE LOT WAS CREATED OR PLATTED (MM/DD/YY) IF REQUESTING CONSIDERATION OF STATUTORY GRANDFATHER PROVISIONS.

OSTDS REMEDIATION PLAN? [Y / N]

PROPERTY INFORMATION

LOT: BLOCK: SUBDIVISION: PLATTED:

PROPERTY ID #: 2355-15-00A104-007 ZONING: I/M OR EQUIVALENT: [Y / N]

PROPERTY SIZE: A ACRES WATER SUPPLY: PRIVATE PUBLIC [] <=2000GPD [] >2000GPD

IS SEWER AVAILABLE AS PER 381.0065, FS? [Y / N] DISTANCE TO SEWER: FT

PROPERTY ADDRESS: 987 SW Montego Ave, Lake City

DIRECTIONS TO PROPERTY: US Hwy 247 South turn left on to Montego Ave
Cross Carpenter Rd Driveway on left.

BUILDING INFORMATION

RESIDENTIAL COMMERCIAL

Unit No.	Type of Establishment	No. of Bedrooms	Building Area Sqft	Commercial/Institutional System Design Table I, Chapter 62-6, FAC
1	MH	4	1600	
2				
3				
4				

Floor/Equipment Drains Other (specify)

SIGNATURE: Robert Ford 999 DATE: 9-2-2025

STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
APPLICATION FOR CONSTRUCTION PERMIT

1"-50'

Permit Application Number

25-0691

-----PART II - SITEPLAN-----

Reville

See Att -

Notes: _____

Site Plan submitted by: Robert Fred 9/9/9 9-2-2025

Plan Approved

Not Approved

Date 9/8/25

By [Signature]

Columbica

County Health Department

ALL CHANGES MUST BE APPROVED BY THE COUNTY HEALTH DEPARTMENT

DEP 4015, 06-21-2022 (Obsoletes previous editions which may not be used)


Incorporated: 62-6.004, F.A.C.

"=50'
2-2025
GWS/Indee

Keville Job.

SW Carpenter Rd.

25-0691



SW MONTGO AVE

500.80

500.80

347.92

347.92

100'

85'

40'

30'

80'

Slopes

Slopes

Slopes

North

Exwell 160'
from split.
W/line 138'
from split.

26.8 x 6.0
4.88

BM

Ditch