

# Inspection Checklist for Permit #000055539

Notes:

| <b>Order</b> | <b>Category</b> | <b>Inspection</b>  | <b>Requirements</b> |
|--------------|-----------------|--|---------------------|
| 1            | Building        | <b>Monolithic Slab</b><br><i>Inspects reinforcement, vapor barrier, termite treatment, and plumbing prior to pour. Ref: FBC 110.3(1)</i>   |                     |
| 2            | Electrical      | <b>Footer Steel &amp; Grounding</b><br><i>Confirms bonding and grounding electrode conductor in foundation steel. Ref: NEC Art. 250.52</i> |                     |
| 3            | Engineering     | <b>Setbacks</b><br><i>Confirms buildings, structures, and improvements are within required property setbacks. Columbia County LDR 4.1</i>  |                     |
| 4            | Building        | <b>Framing</b><br><i>Reviews structural framing, load paths, fire blocking, and MEP rough-ins prior to insulation. Ref: FBC 110.3(3)</i>   |                     |
| 5            | Electrical      | <b>Permanent Power</b><br><i>Releases power once service equipment is complete and safe. Ref: NEC Art. 230</i>                             |                     |