

# Inspection Checklist for Permit #000055721

Notes:

Order	Category	Inspection	Requirements
1	Building	<b>Footer</b> <i>Inspects footing size, depth, and reinforcing steel before concrete placement. Ref: FBC 110.3(1)</i>	
2	Engineering	<b>Setbacks</b> <i>Confirms buildings, structures, and improvements are within required property setbacks. Columbia County LDR 4.1</i>	
3	Building	<b>Roof Decking</b> <i>Checks roof sheathing attachment and fastener pattern per FBC wind zones. Ref: FBC 110.3(3)</i>	Requires Document Surveyor Letter Confirming Finished Floor Elevation., Requires Document Grading and Fill Report (volume, compaction, etc.), Requires Document Engineer Letter providing Minimum Floor Elevation Requirements.
4	Building	<b>Wall Sheathing</b> <i>Confirms nail/screw spacing and panel installation per plans. Ref: FBC 110.3(3)</i>	Requires Document Surveyor Letter Confirming Finished Floor Elevation., Requires Document Grading and Fill Report (volume, compaction, etc.), Requires Document Engineer Letter providing Minimum Floor Elevation Requirements.
5	Building	<b>Framing</b> <i>Reviews structural framing, load paths, fire blocking, and MEP rough-ins prior to insulation. Ref: FBC 110.3(3)</i>	Requires Document Surveyor Letter Confirming Finished Floor Elevation., Requires Document Grading and Fill Report (volume, compaction, etc.), Requires Document Engineer Letter providing Minimum Floor Elevation Requirements.
6	Electrical	<b>2nd Rough-In</b> <i>Checks wiring, panel placement, and boxes before cover-up. Ref: NEC Art. 110.3</i>	Requires Document Surveyor Letter Confirming Finished Floor Elevation., Requires Document Grading and Fill Report (volume, compaction, etc.), Requires Document Engineer Letter providing Minimum Floor Elevation Requirements.
7	Mechanical	<b>Rough In</b> <i>Checks ductwork, equipment location, and condensate before covering. Ref: FBC-M 603</i>	Requires Document Surveyor Letter Confirming Finished Floor Elevation., Requires Document Grading and Fill Report (volume, compaction, etc.), Requires Document Engineer Letter providing Minimum Floor Elevation Requirements.
8	Building	<b>Insulation</b> <i>Verifies insulation type, R-value, and installation before drywall. Ref: FBC Energy C101.5</i>	Requires Document Surveyor Letter Confirming Finished Floor Elevation., Requires Document Grading and Fill Report (volume, compaction, etc.), Requires Document Engineer Letter providing Minimum Floor Elevation Requirements.
9	Building	<b>Final</b> <i>Ensures structure is complete, safe, and code-compliant before Certificate of Occupancy. Ref: FBC 110.5</i>	Requires Document As-Built Survey.