

Jeff Johnson, P.E.

6374 E CR240

Lake Butler, FL 32054

(386) 719-0584

jpjlulu@hotmail.com

February 17, 2025

Natalie Lamneck

Permit Application # 69241

Ref: ELEVATION LETTER – 929 SW Old Lake City Ter, High Springs, FL 32643

As requested, I inspected the building site for the proposed construction at the above referenced site.

Per the flood report by SRWMD, there are no wetlands on the property and only one floodplain that is close to the property, which is located to the northeast. The home will be built in zone X, per the Effective Flood Information Report (see attached sheet).

From the topography, it can be determined that the site drains off in every direction from the foundation. The finished floor elevation of the home shall be approximately 4 feet above the adjacent dirt road "Old Lake City Terrace".

I certify that the minimum finished floor elevation listed above will protect the structure against water damage from a base flood event, as defined in Article 8 of the Land Development Regulations. Should you have any questions, please don't hesitate to contact me.

Respectfully

Jeff Johnson, P.E.

