



City of Lake City Accessibility Letter Required before Building Permit Issuance



Service Representatives :

Growth Management: growthmanagement@lcfla.com,

Utilities: PelhamS@lcfla.com, MedearisK@lcfla.com, McGhinB@lcfla.com

Date: 8/10/2026

County Application # 78458

Applicant Name: ARTHUR FRANCIS

Phone: (407) 378-6682

Email: WAYNEFRANCISTHD@EXPEDITEPERMIT.COM

Site Address: 888 SE RACETRACK LN LAKE CITY, FL 32025

Parcel: 21-4S-17-08632-001

Acres: 9.79

Project Description: Remodel

Existing Structures on Property:

Any tree removal:

Number of trees removed:

Trees remaining:

Utilities:

Utility Accessibility: Water: Available Sewer: Unavailable Gas: Available City Letter of Accessibility Required: No

Utility Active: Water: Inactive Sewer: Inactive Gas: Inactive Has Impact Fee: Impact Fees paid:

Customer service official's name: **Amy Fernandez**

Reviewed: 8/11/2026

Requires Tap Inspection: No

Customer service official's notes: The City of Lake City does not provide utilities to this location.

Zoning:

Minimum Setback Requirements: Font: Side: Rear:

Landscape Requirements:

Flood Zone: B.F.E.: Finished Floor Elevation Requirement:

Site Approval Plan:

Special Exception: Variance:

Documents Required:

Needed Before Power: No

Needed Before CO: No

Zoning official clearance

Date Reviewed:

Access:

Permit Issued: Needed Before CO:

Access official clearance

Date Reviewed:

Code Enforcement:

Code Enforcement Cases: None Case Notes:

Code Enforcement clearance

Date Reviewed:

Special Notes to be noted on permit