

Project Information

For: King Residence
Columbia County, FL



Review for Code Compliance
Universal Engineering Science

Lawrence Parnell
Examiner-License No.

PX2707 07/15/2024

Design Information

	Htg	Clg	Method	Infiltration	Simplified Average
Outside db (°F)	33	92			
Inside db (°F)	68	75	Construction quality		
Design TD (°F)	35	17	Fireplaces		0
Daily range	-	M			
Inside humidity (%)	50	50			
Moisture difference (gr/lb)	29	43			

HEATING EQUIPMENT

Make	Trane
Trade	TRANE
Model	4TWR5036H1
AHRI ref	211215791
Efficiency	7.8 HSPF2
Heating input	
Heating output	32800 Btuh @ 47°F
Temperature rise	0 °F
Actual air flow	0 cfm
Air flow factor	0 cfm/Btuh
Static pressure	0.50 in H2O
Space thermostat	
Capacity balance point = 29 °F	

COOLING EQUIPMENT

Make	Trane
Trade	TRANE
Cond	4TWR5036H1
Coil	TEM4B0C37M31++TDR
AHRI ref	211215791
Efficiency	12.0 EER2, 14.3 SEER2
Sensible cooling	24080 Btuh
Latent cooling	10320 Btuh
Total cooling	34400 Btuh
Actual air flow	1147 cfm
Air flow factor	0.053 cfm/Btuh
Static pressure	0.50 in H2O
Load sensible heat ratio	0.77

ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
bd1	166	3057	1791	0	95
hall	35	0	0	0	0
bath	59	726	578	0	31
bd2	163	3066	1995	0	106
common area	674	8685	10221	0	541
pwdr	38	869	567	0	30
m bd	187	2041	2770	0	147
m bath	126	2491	1557	0	82
wc	23	458	452	0	24
wic	88	936	330	0	17
laundry	96	2196	1225	0	65
pantry	34	252	165	0	9
ent	102	0	0	0	0

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

Entire House	1792	24776	21650	0	1147
Other equip loads		2765	1386		
Equip. @ 0.97 RSM			22437		
Latent cooling			7022		
TOTALS	1792	27541	29459	0	1147



**Review for Code Compliance
Universal Engineering Science**


Laurence Powell
Examiner-License No.

PX2707

07/15/2024

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.





11'-0"



Review for Code Compliance
 Universal Engineering Science

Lawrence Parnell

PX2707

07/15/2024

Examiner-License No.

Project Information

For: King Residence
Columbia County, FL

Cooling Equipment

Design Conditions

Outdoor design DB:	92.4°F	Sensible gain:	23036 Btuh	Entering coil DB:	76.3°F
Outdoor design WB:	75.8°F	Latent gain:	7022 Btuh	Entering coil WB:	63.8°F
Indoor design DB:	75.0°F	Total gain:	30058 Btuh		
Indoor RH:	50%	Estimated airflow:	1147 cfm		

Manufacturer's Performance Data at Actual Design Conditions

Equipment type: Split ASHP
Manufacturer: Trane Model: 4TWR5036H1+TEM4B0C37M31++TDR
Actual airflow: 1147 cfm
Sensible capacity: 24080 Btuh 105% of load
Latent capacity: 10320 Btuh 147% of load
Total capacity: 34400 Btuh 114% of load SHR: 70%

Heating Equipment

Design Conditions

Outdoor design DB:	33.3°F	Heat loss:	27541 Btuh	Entering coil DB:	68.0°F
Indoor design DB:	68.0°F				

Manufacturer's Performance Data at Actual Design Conditions

Equipment type: Split ASHP
Manufacturer: Trane Model: 4TWR5036H1+TEM4B0C37M31++TDR
Actual airflow: 0 cfm
Output capacity: 32800 Btuh 119% of load Capacity balance: 29 °F
Supplemental heat required: 0 Btuh Economic balance: -99 °F



Review for Code Compliance
Universal Engineering Science

Laundon Powell
Examiner-License No.

PX2707

07/15/2024

Meets all requirements of ACCA Manual S.

Project Information

For: King Residence
Columbia County, FL

	Heating	Cooling
External static pressure	0.50 in H2O	0.50 in H2O
Pressure losses	0.18 in H2O	0.18 in H2O
Available static pressure	0.32 in H2O	0.32 in H2O
Supply / return available pressure	0.211 / 0.109 in H2O	0.211 / 0.109 in H2O
Lowest friction rate	0.088 in/100ft	0.088 in/100ft
Actual air flow	0 cfm	1147 cfm
Total effective length (TEL)	364 ft	

Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
bath	c 578	0	31	0.088	4.0	0x0	VIFx	69.5	170.0	st6
bd1	c 1791	0	95	0.129	6.0	0x0	VIFx	47.9	115.0	st3
bd2	c 1995	0	106	0.089	6.0	0x0	VIFx	67.2	170.0	st6
common area	c 2555	0	135	0.106	7.0	0x0	VIFx	52.9	145.0	st5
common area-A	c 2555	0	135	0.137	7.0	0x0	VIFx	39.0	115.0	st3
common area-B	c 2555	0	135	0.139	7.0	0x0	VIFx	36.5	115.0	st3
common area-C	c 2555	0	135	0.107	7.0	0x0	VIFx	52.3	145.0	st5
laundry	c 1225	0	65	0.178	5.0	0x0	VIFx	18.4	100.0	st1
m bath	c 1557	0	82	0.138	5.0	0x0	VIFx	27.5	125.0	st4
m bd	c 2770	0	147	0.133	7.0	0x0	VIFx	33.2	125.0	st4
pantry	c 165	0	9	0.181	4.0	0x0	VIFx	16.4	100.0	st2
pwdr	c 567	0	30	0.179	4.0	0x0	VIFx	17.9	100.0	st1
wc	c 452	0	24	0.179	4.0	0x0	VIFx	17.5	100.0	st2
wic	c 330	0	17	0.180	4.0	0x0	VIFx	16.9	100.0	st2

Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st6	Peak AVF	0	136	0.088	390	8.0	0 x 0	VinIFlx	st5
st5	Peak AVF	0	407	0.088	518	12.0	0 x 0	VinIFlx	st4
st4	Peak AVF	0	636	0.088	595	14.0	0 x 0	VinIFlx	st2
st2	Peak AVF	0	686	0.088	492	16.0	0 x 0	VinIFlx	
st3	Peak AVF	0	366	0.129	466	12.0	0 x 0	VinIFlx	st1
st1	Peak AVF	0	461	0.129	586	12.0	0 x 0	VinIFlx	



Review for Code Compliance
Universal Engineering Science

Return Branch Detail Table

Name	Grille Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb2	0x0	0	95	124.3	0.088	483	6.0	0x 0		VIFx	rt3
rb3	0x0	0	106	120.2	0.091	538	6.0	0x 0		VIFx	rt3
rb1	0x0	0	676	48.3	0.227	484	16.0	0x 0		VIFx	rt1
rb4	0x0	0	271	69.3	0.158	613	9.0	0x 0		VIFx	rt2

Return Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
rt3	Peak AVF	0	201	0.088	454	9.0	0 x 0	VinIFlx	rt2
rt2	Peak AVF	0	471	0.088	600	12.0	0 x 0	VinIFlx	rt1
rt1	Peak AVF	0	1147	0.088	526	20.0	0 x 0	VinIFlx	



Review for Code Compliance
Universal Engineering Science

Lawrence Parnell
Examiner-License No.

PX2707

07/15/2024

