

October 2, 2019

Ron Armstrong
SW Baron Glen
Fort White, FL 32038

Subject: Permit # 38384 - Lot 14, Southern Meadows, Ph 2 - Elevation Letter

Dear Mr. Armstrong:

Daniel & Gore, LLC has performed a vertical survey on Lot 14, Southern Meadows, Phase 2, Columbia County, Florida from a benchmark being a FDOT concrete monument (2902007 BM 8) on the West right of way of State Road No. 47 (elevation – 76.27', NGVD 1929) and have determined the following:

- The Subdivision plat requires the minimum finish floor elevation to be 89.5'.
- A benchmark has been set on Lot 14 in a 15" pine tree, near the proposed home site. Said benchmark being a 60d nail with an elevation of 91.82', being 2.32' above the required minimum finish floor elevation of 89.5'.
- The finished floor elevation of the residence is 92.68', being 3.18' above the required minimum finish floor elevation of 89.5'.

If you have any questions, please call me.

Sincerely,



Scott Daniel, PSM

