



Load Short Form
Entire House
Bounds Heating and Air

Job:
 Date: Jan 29, 2026
 By:

Email: jlegler@boundshvac.com

Project Information

For: Lot 97 Emerald Cove, DWC Contracting

Design Information

	Htg	Clg	Infiltration	Simplified Average
Outside db (°F)	33	92	Method	0
Inside db (°F)	70	75	Construction quality	
Design TD (°F)	37	17	Fireplaces	
Daily range	-	M		
Inside humidity (%)	30	50		
Moisture difference (gr/lb)	10	44		

HEATING EQUIPMENT

Make	Carrier
Trade	15 SEER2 HP
Model	GH5SAN53000AA0
AHRI ref	214101792
Efficiency	7.5 HSPF2
Heating input	
Heating output	28600 Btuh @ 47°F
Temperature rise	28 °F
Actual air flow	947 cfm
Air flow factor	0.044 cfm/Btuh
Static pressure	0.50 in H2O
Space thermostat	
Capacity balance point = 27 °F	

COOLING EQUIPMENT

Make	Carrier
Trade	15 SEER2 HP
Cond	GH5SAN53000AA0
Coil	FJ5ANXB30L00
AHRI ref	214101792
Efficiency	12.0 EER2, 14.5 SEER2
Sensible cooling	19880 Btuh
Latent cooling	8520 Btuh
Total cooling	28400 Btuh
Actual air flow	947 cfm
Air flow factor	0.042 cfm/Btuh
Static pressure	0.50 in H2O
Load sensible heat ratio	0.87

Backup:
 Input = 5 kW, Output = 15906 Btuh, 100 AFUE

ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
master bedroom	230	4075	3824	180	160
kitchen/living	536	8565	10202	379	428
master bath	87	1473	1750	65	73
wic	58	366	319	16	13
laundry	65	786	1246	35	52
bedroom 3	177	2960	2534	131	106
bath	55	498	396	22	17
bedroom 2	147	2688	2310	119	97
hall	36	0	0	0	0

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Entire House	1391	21411	22582	947	947
Other equip loads		0	0		
Equip. @ 0.97 RSM			21950		
Latent cooling			3279		
TOTALS	1391	21411	25229	947	947

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.





Project Summary

Entire House

Bounds Heating and Air

Job:
Date: Jan 29, 2026
By:

Email: jlegler@boundshvac.com

Project Information

For: Lot 97 Emerald Cove, DWC Contracting

Notes:

Design Information

Weather: Gainesville Regional, FL, US

Winter Design Conditions

Outside db 33 °F
Inside db 70 °F
Design TD 37 °F

Ventilation Method MJ8

Heating Summary

Structure 17187 Btuh
Ducts (R-6.0) 4224 Btuh
Central vent (0 cfm) 0 Btuh

Humidification 0 Btuh
Piping 0 Btuh
Equipment load 21411 Btuh

Infiltration

Method Simplified
Construction quality Average
Fireplaces 0

	Heating	Cooling
Area (ft ²)	1384	1384
Volume (ft ³)	12519	12519
Air changes/hour	0.45	0.23
Equiv. AVF (cfm)	94	48

Heating Equipment Summary

Make Carrier
Trade 15 SEER2 HP
Model GH5SAN53000AA0
AHRI ref 214101792

Efficiency 7.5 HSPF2
Heating input
Heating output 28600 Btuh @ 47°F
Temperature rise 28 °F
Actual air flow 947 cfm
Air flow factor 0.044 cfm/Btuh
Static pressure 0.50 in H2O
Space thermostat
Capacity balance point = 27 °F

Backup:
Input = 5 kW, Output = 15906 Btuh, 100 AFUE

Bold/italic values have been manually overridden

Summer Design Conditions

Outside db 92 °F
Inside db 75 °F
Design TD 17 °F
Daily range M
Relative humidity 50 %
Moisture difference 44 gr/lb

Sensible Cooling Equipment Load Sizing

Structure 16318 Btuh
Ducts (R-6.0) 6264 Btuh
Central vent (0 cfm) 0 Btuh

Blower 0 Btuh

Use manufacturer's data n
Rate/swing multiplier 0.97
Equipment sensible load 21950 Btuh

Latent Cooling Equipment Load Sizing

Structure 2223 Btuh
Ducts 1056 Btuh
Central vent (0 cfm) 0 Btuh

Equipment latent load 3279 Btuh

Equipment Total Load (Sen+Lat) 25229 Btuh
Req. total capacity at 0.70 SHR 2.6 ton

Cooling Equipment Summary


Make Carrier
Trade 15 SEER2 HP
Cond GH5SAN53000AA0
Coil FJ5ANXB30L00
AHRI ref 214101792
Efficiency 12.0 EER2, 14.5 SEER2
Sensible cooling 19880 Btuh
Latent cooling 8520 Btuh
Total cooling 28400 Btuh
Actual air flow 947 cfm
Air flow factor 0.042 cfm/Btuh
Static pressure 0.50 in H2O
Load sensible heat ratio 0.87

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.





Sheet 1



Job #:
Performed for:
Lot 97 Emerald Cove

Bounds Heating and Air

jlegler@boundshvac.com

Scale: 1 : 84

Page 1
Right-Suite@Universal 2025
25.0.04 RSU57217
2026-Jan-30 09:09:49
...ald Cove\Emerald Cove lot 97.rup



Manual S Compliance Report
Entire House
Bounds Heating and Air

Job:
 Date: Jan 29, 2026
 By:

Email: jlegler@boundshvac.com

Project Information

For: Lot 97 Emerald Cove, DWC Contracting

Cooling Equipment

Design Conditions

Outdoor design DB:	92.2°F	Sensible gain:	22582 Btuh	Entering coil DB:	76.8°F
Outdoor design WB:	75.8°F	Latent gain:	3279 Btuh	Entering coil WB:	63.4°F
Indoor design DB:	75.0°F	Total gain:	25861 Btuh		
Indoor RH:	50%	Estimated airflow:	947 cfm		

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP			
Manufacturer:	Carrier	Model:	GH5SAN53000AA0+FJ5ANXB30L00	
Actual airflow:	947 cfm			
Sensible capacity:	19880 Btuh		88% of load	
Latent capacity:	8520 Btuh		260% of load	
Total capacity:	28400 Btuh		110% of load	SHR: 70%

Heating Equipment

Design Conditions

Outdoor design DB:	33.2°F	Heat loss:	21411 Btuh	Entering coil DB:	69.1°F
Indoor design DB:	70.0°F				

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP			
Manufacturer:	Carrier	Model:	GH5SAN53000AA0+FJ5ANXB30L00	
Actual airflow:	947 cfm			
Output capacity:	28600 Btuh		134% of load	Capacity balance: 27 °F
Supplemental heat required:	0 Btuh			Economic balance: -99 °F

Backup equipment type:	Elec strip			
Manufacturer:		Model:		
Actual airflow:	947 cfm			
Output capacity:	4.7 kW	74% of load	Temp. rise:	50 °F

Meets all requirements of ACCA Manual S.





Duct System Summary

Entire House
Bounds Heating and Air

Job:
Date: Jan 29, 2026
By:

Email: jlegler@boundshvac.com

Project Information

For: Lot 97 Emerald Cove, DWC Contracting

	Heating	Cooling
External static pressure	0.50 in H2O	0.50 in H2O
Pressure losses	0 in H2O	0 in H2O
Available static pressure	0.50 in H2O	0.50 in H2O
Supply / return available pressure	0.355 / 0.145 in H2O	0.355 / 0.145 in H2O
Lowest friction rate	0.204 in/100ft	0.204 in/100ft
Actual air flow	947 cfm	947 cfm
Total effective length (TEL)		245 ft

Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
bath	h 498	22	17	0.208	4.0	0x0	VIFx	35.6	135.0	st2
bedroom 2	h 2688	119	97	0.206	6.0	0x0	VIFx	37.0	135.0	st2
bedroom 3	h 2960	131	106	0.204	6.0	0x0	VIFx	38.8	135.0	st2
kitchen/living	c 3402	126	143	0.250	7.0	0x0	VIFx	16.9	125.0	st1
kitchen/living-A	c 3401	126	143	0.218	7.0	0x0	VIFx	28.1	135.0	st2
kitchen/living-B	c 3401	126	143	0.219	7.0	0x0	VIFx	27.1	135.0	st2
laundry	c 1246	35	52	0.284	5.0	0x0	VIFx	10.0	115.0	st1
master bath	c 1750	65	73	0.270	5.0	0x0	VIFx	16.3	115.0	st1
master bedroom	h 4075	180	160	0.261	7.0	0x0	VIFx	15.9	120.0	st1
wic	h 366	16	13	0.286	4.0	0x0	VIFx	8.9	115.0	st1

Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st2	Peak AVF	524	505	0.204	668	12.0	0 x 0	VinIFlx	st1
st1	Peak AVF	947	947	0.204	678	16.0	0 x 0	VinIFlx	

Bold/italic values have been manually overridden



Return Branch Detail Table

Name	Grille Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb1	0x0	947	947	71.1	0.204	678	16.0	0x 0		VIFx	rst3

Return Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
rst3	Peak AVF	947	947	0.204	678	16.0	0 x 0	VinIFlx	

Bold/italic values have been manually overridden

