



Name of person this mobile home home is for? James Everett

Resident's Phone #

Are you applying for a 5 year temporary permit? No

Special temporary use permit number:

Septic # 26-0323

Setback Info

Site Plan Setbacks Front 260

Site Plan Setbacks Side 1 234

Site Plan Setbacks Side 2 95

Site Plan Setbacks Rear 385

Optional Job Notes

**Review Notes: NEEDED**

\* (SITE PLAN APPEARS TO PLACE HOME PARTIALLY IN FLOODZONE)

\* THERE IS A SIGNIFICANT DIFFERENCE IN THE ELEVATION OF THE ROAD AND THE ELEVATION AT THE PROPOSED DEVELOPMENT. AN ENGINEER LETTER WILL BE REQUIRED TO ASSURE THAT THE MINIMUM FLOOR ELEVATION WILL BE SUFFICIENT TO AVOID POSSIBLE RISING WATERS OF THE AREA (RECEIVED ZONING TO REVIEW)