



CAL-TECH TESTING, INC.

ENGINEERING & TESTING LABORATORY

P.O. Box 1625, Lake City, FL 32056-1625
7540 103rd St. Suite 215 • Jacksonville, FL 32210

Lake City • (386) 755-3633
Fax • (386) 752-5456

Jacksonville • (904) 381-8901
Fax • (904) 381-8902

JOB NO.: 22-527
DATE TESTED: 11-22-22

REPORT OF IN-PLACE DENSITY TEST

ASTM METHOD: (D-2922) Nuclear (D-2937) Drive Cylinder Other

PROJECT: 264 SW Foreman Glen

CLIENT: Hennies Foreman

GENERAL CONTRACTOR: SAC **EARTHWORK CONTRACTOR:** SAC

SOIL USE (SEE NOTE): 1 **SPECIFICATION REQUIREMENTS:** 95%

TECHNICIAN: C. Jay

MODIFIED (ASTM D-1557): **STANDARD (ASTM D-698):**

TEST NO.	TEST LOCATION	TEST:	PROCTOR NO.	WET DENS. LBS./CU.FT.	DRY DENS. LBS./CU.FT.	MOIST PERCENT	% MAX. DENS.
		DEPTH ELEV. LIFT					
1	NE Corner of pad 18ft 5 x 10ft w	12"	1	117.9	110.0	7.2	104
2	SE Corner of pad 15ft 10 x 12ft w	12"	1	107.9	100.5	7.4	96
3	SW Corner of pad 10ft 8 x 10ft w	12"	1	109.1	102.5	6.4	97

REMARKS: _____

PROCTOR NO.	SOIL DESCRIPTION	PROCTOR VALUE	OPT. MOIST.
1	Graham 49 Pit	105.2	

NOTE: 1. Building Fill 2. Trench Backfill 3. Base Course 4. Subbase/Stabilized Subgrade 5. Embankment 6. Subgrade/Natural Soil 7. Other
The test results presented in this report are specific only to the samples tested at the time of testing. The tests were performed in accordance with generally accepted methods and standards. Since material conditions can vary between test location and change with time, sound judgement should be exercised with regard to the use and interpretation of the data.