

**ADDENDUM #20
BID NO. 2009-T**

Issue Date: September 4, 2009

Project: South Columbia County Regional Wastewater Treatment Plant

Notice to all bidders is hereby given that the following modification is made to the Request for Bids referenced above:

Project Clarifications

The following modifications have been made to the project.

Administration Building

The contractor shall carry in his bid, the price to furnish and install a 3 ton heat pump with an adequate attic air handler and 60 feet of spiral duct work that meets all applicable local, state, and federal codes.

A full length ridge vent shall be included along with vented soffit..

Costs for these items shall be included in Section 4.I. of the Bid Form.

Ground Storage Tank

The inside diameter of the Ground Storage Tank is 66 feet. The inside wall height is 22’.

Each bid submitted in response to this Request for Bids shall include an acknowledgement of this addendum.