

**ADDENDUM #22  
BID NO. 2009-T**

**Issue Date: September 9, 2009**

**Project: South Columbia County Regional Wastewater Treatment Plant**

Notice to all bidders is hereby given that the following modification is made to the Request for Bids referenced above:

**Response to Request for Additional Information #4**

Attached are Responses to a Request for Additional Information. Each bidder shall familiarize themselves with the information provided herein to the submission of their bid.

**Each bid submitted in response to this Request for Bids shall include an acknowledgement of this addendum.**

EUTAW UTILITIES, INC.  
Project Development...Concept to Completion



**Date: September 9, 2009**

**To: All Bidders**

**From: Eutaw Utilities**

**RE: South Columbia County Regional Wastewater Treatment Plant  
Request for Additional Information #4**

The following questions were submitted in respect to the above referenced project.

1. On sheet S-16, please clarify conflict regarding ID size, 22' or 45'.

**The Digester ID is 22'.**

2. Sheet S-16 shows a 6" air line DIP pipe and S-17 calls for an 8" air line pipe.

**The air line is 6". The air header goes across the floor and distributes in 6 location branches (3 each side of header).**

3. On sheet S-18, there is a conflict on the Water Storage Tank ID.

**The Ground Storage ID is 66 ft.**

4. Sheet S-18 shows twelve (12) #200 precast overflows. Please confirm.

**This tank requires four (4) #200 precast overflows.**

5. Sheet S-18 shows a parapet wall. Please provide height of wall.

**Parapet wall height is 12".**

6. Sheet S-19 shows an interior FG ladder with safety cage. Please confirm.

**The interior cage is deleted and replaced with stainless steel safety rail.  
Regarding the exterior ladder –the safety rail is not required with cage for tanks 22' tall.**

7. With regard to the Digester Tank and the Water Storage Tank, the specifications call for painting. Please provide specifications for painting.

**The exterior of both tanks are to be Tnemec Series 156 Envirocrete, no substitutes allowed prior to bidding. Note there are no equivalent products to series 156 by other manufacturers at this time as this is an engineered coating system for prestressed concrete tanks.**