

**ADDENDUM #5
BID NO. 2009-T**

Issue Date: August 26, 2009

Project: South Columbia County Regional Wastewater Treatment Plant

Notice to all bidders is hereby given that the following modification is made to the Request for Bids referenced above:

Response to Request for Additional Information #1

Attached are Responses to a Request for Additional Information. Each bidder shall familiarize themselves with the information provided herein to the submission of their bid.

Each bid submitted in response to this Request for Bids shall include an acknowledgement of this addendum.

EUTAW UTILITIES, INC.
Project Development...Concept to Completion



Date: August 26, 2009

To: All Bidders

From: Eutaw Utilities

**RE: South Columbia County Regional Wastewater Treatment Plant
Request for Additional Information #1**

The following questions were submitted in respect to the above referenced project.

1. Can more descriptive detail be provided as to the locations of the existing plant to be removed and future lift stations? I could not find these areas based on the drawings.

Please see the Attached Map.

2. As noted in the pre-bid meeting, no water is currently available at the site. However, a well field is located nearby where water may be obtained. However, the nearby wells do not have a continuous power source. There is no timeline for when power may be available. Please advise if we will need to bring water from an off-site source, and if so, what is the closest available source and would the water be metered? The tank contractor will need a continuous water source to complete their work.

Columbia County will make one of the wells operational to supply water. The pumps will be operated by Columbia County Staff and coordination will be required by the contractor to arrange for water with the designated staff operator.

3. Considering that the adjacent area is primarily residential, has the owner and/or engineer made provisions with Clay Electric to provide 3-phase power?

Clay Electric is under contract with Columbia County to provide 3-Phase power to the site, but has not provided their estimated completion date.

4. As noted in the pre-bid meeting, material may potentially be buried onsite. Is this the case, or may burning be allowed if an air-curtain is used?

Burning shall not be allowed. Chipped or other processed debris may be disposed of on site.

5. Please confirm how the project will be awarded: Base Bid only or Base Bid plus Alternates.

Base bid PLUS Alternates.

6. Can the bid date be postponed by one or two days, as the bid date is currently set to be the day after Labor Day?


Bid Opening has been moved to September 9th, 2009.

GRAPHIC SCALE

0 70 140 280



(IN FEET)



I-75

EXISTING PACKAGE PLANT

PROPOSED LIFT STATION

U.S. 441

CLIENT	COLUMBIA COUNTY
PROJECT NAME	SOUTH REGIONAL WWTP
SHEET TITLE	ABANDONED PACKAGE PLANT LOCATION MAP

EUTAW UTILITIES, INC.
Project Development... Concept to Completion



415 St. Francis Street
Unit 114
TALLAHASSEE, FLORIDA 32301

OFFICE PHONE: (850) 383-0400
OFFICE FAX: (888) 878-2939
Cert. of Authorization 9961

DATE DRAWN	8/26/09	PRINT DATE	26 Aug 2009
DESIGN ENGINEER			
SIGNATURE			
P.E. NUMBER			
DRAWN BY			
CHECKED BY			
SCALE	AS SHOWN		

Owner: Aug 26, 2009 - 10:14am S:\arcadis\columbia_county\Columbia_Co_LDD_Projects\CHP_TENPL\locat\locat.dwg