

**ADDENDUM #12  
BID NO. 2009-T**

**Issue Date: August 28, 2009**

**Project: South Columbia County Regional Wastewater Treatment Plant**

Notice to all bidders is hereby given that the following modification is made to the Request for Bids referenced above:

**Drawing Clarifications**

The following clarifications to the construction documents are provided:

**Drawing M-24**

Wet well dimensions are 10' diameter by 10' tall with a nominal 3' diameter access opening. The transitional piece between the manhole cover and the box is 3' diameter by 4' diameter. Elevations are:

Box bottom finished floor: 66.8 feet

Top: 79.47 feet

Ground Elevation: 77.5 feet.

The guide rail system shown is optional. A cable and winch system (not shown) can be provided in lieu of the rail system

**Drawing M-2**

The contractor for this package shall be responsible for constructing 80 feet of 6" potable water pipe beyond the fence line and install a blind for future connection by others.

**Each bid submitted in response to this Request for Bids shall include an acknowledgement of this addendum.**