

**ADDENDUM #4
BID NO. 2009-V**

Issue Date: September 1, 2009

Project: Ellisville Water System Improvement – Expansion to US 441

This ADDENDUM is issued to institute the included changes, additions and/or deletions to the Plans and Specifications for the construction of the **ELLISVILLE WATER SYSTEM IMPROVEMENTS – EXPANSION TO HWY 441** for **COLUMBIA COUNTY** and hereby becomes a part of said Plans and Specifications. Where an item on the original Plans and Specifications is amended, voided, or superseded by a modification contained in the ADDENDUM, the provisions of such item not specifically amended, voided, or superseded shall remain in effect.

PLANS CLARIFICATION

The Fire Hydrant Assembly Detail has been revised as noted below:

Notes 6, 8 and 9 – Remove reference to “Tallahassee” threads. Hydrants shall have two (2) – 2 ½” hose nozzles and one (1) – 4 ½ “ steamer nozzles with National Standard Threads (NST).

Each bid submitted in response to this Request for Bids shall include an acknowledgement of this addendum.