

**ADDENDUM #1  
BID NO. 2009-W**

**Issue Date: September 1, 2009**

**Project: Ellisville Water System Improvement – Expansion to I-75 North**

This ADDENDUM is issued to institute the included changes, additions and/or deletions to the Plans and Specifications for the construction of the **ELLISVILLE WATER SYSTEM IMPROVEMENTS – EXPANSION TO I-75 NORTH** and hereby becomes a part of said Plans and Specifications. Where an item on the original Plans and Specifications is amended, voided, or superseded by a modification contained in the ADDENDUM, the provisions of such item not specifically amended, voided, or superseded shall remain in effect.

**PLANS CLARIFICATION**

Sheet 15 of the plans is revised as noted below:

Notes 6, 8 and 9 – Remove reference to “Tallahassee” threads. Hydrants shall have two (2) – 2 ½” hose nozzles and one (1) – 4 ½ “ steamer nozzles with National Standard Threads (NST).

**Each bid submitted in response to this Request for Bids shall include an acknowledgement of this addendum.**