

April 13, 2010

To: **ALL PLAN HOLDERS VIA EMAIL**

Total No. of Pages: **_1_**

Re: **ADDENDUM No. 5**

NEW FT. WHITE BRANCH LIBRARY

1. Please note the clarification to the electrical floor plans E1.1

LB -8, LB-10, LB-15, LB-17, LB-16, LB -18 shall be combination flush floor mounted outlet box with double duplex receptacle and telecomm outlet, cast iron two gang with brushed aluminum flange and cover plate with 1" EMT to above finished ceiling with insulating bushing.