

ADDENDA # 1

DEEP CREEK COMMUNITY CENTER

COLUMBIA COUNTY BOARD OF COMMISSIONERS (CCBC)

November 12, 2014

This will become a part of the construction documents and requirements

- **Acoustical Ceiling**
 - Use only factory attachments when joining new with old ceiling grid.
- **Plumbing**
 - Do not provide hose bibb to North end of proposed addition.
- **Electrical**
 - Provide and install Lighting Troffers 2x4 (4 lamp) lay in troffer with T8-741 Lamps matching the existing light fixtures
 - Provide and install Emergency Lights – ELM2 Lithonia Two head emergency lights
 - Provide and install Paddle Fans to match existing
 - Provide and install receptacles – CR 20I P&S 20 amp duplex receptacle construction grade 2095I P&S 20 amp GFI receptacle.
 - Provide and install switches with the following specifications –
 - CSB20AC1I P&S Single pole construction grade 20 amp switch
 - CSB20AC3I P&S Three way construction grade 20 amp switch
 - CSB20AC4I P&S Four way construction grade 20 amp switch
 - Do not use less than 12 AWG THHN electrical wire
- **Exterior Trim Carpentry**
 - Soffit to match existing (Aluminum)
- **Drywall**
 - (Correction to Typical Wall Section) Interior drywall has been determined to be ½". Match with new construction.
- **Framing**
 - Correct irregular roof plane on North end of existing building to provide for smooth and level transition for proposed addition.

• End of Addenda 1