

ADDENDUM 1 QUESTIONS AND ANSWERS
BID NO. 2015-7

Will the materials need to be USA only or will Imported material be allowed?

imports allowed

BI# 1 : What DR rating do you want for the PVC Pipe? **DR18?**

BI# 21 : Can you give me a list of the additional material you need for the HydroGuard Unit? **100' of 2" sch. 40 pipe, 8 – 2" 90deg elbows, 6 – 2" male adapters**

BI#14: What bury depth do you want your hydrants? **7'**

BI#8: Valve boxes Medium Height? do you want a 24"-36" valve box ? **yes, yes**

BI# 24: Metallic Locating tape is sold in 1000' reels and they are sold as a "EA" qty , **therefore we need 8 rolls**

BI# 3 & 19: Do the Megalugs need to be all for PVC pipe? **yes**

BI# 30: Please specify what meter box you want? **No specific type, but traffic bearing and sized as follows: 19" long, 13.5" wide, 12" high**

Bid Bond required if your bid is over \$150,000.