

**ADDENDUM 2
COLUMBIA COUNTY BOCC
LED SIGN 2015-I**

Questions/Requests below...

1. Request for permitting requirements from City and County. Permitting will be thru the Columbia County Building & Zoning Department. Contact Randy Jones.
2. Request for most recent stamped engineering drawings for the entire structure and sign. The attached drawings are all that we have.
3. Who is responsible for new engineering drawings? Vendor. If the most recent stamped engineering drawings are not available can the vendor add a line that the engineering and permit cost will be a "pass through" cost to Columbia County? No
4. Power Amps - What is the current Amp load for the structure (feeds LED sign, tri-vision sign and lights)
600 amp main
2- 200 amp (42 Space Panels)
1 – with 11 circuit 20 amp
1 – With 14 circuit 20 amp
5. Performance Bond - Can the performance bond be broken up? (i.e. The bond for product comes from the sign manufacturer and the bond for labor comes from the dealer) No, our contract is with the contractor not with the sign company.

Columbia County Building Permit Application

For Office Use Only Application # 0911-04 Date Received 11-2-09 By LH Permit # 28184
 Zoning Official N/A ^{existing sign} Date 11/2/09 Flood Zone _____ Land Use _____ Zoning _____
 FEMA Map # _____ Elevation _____ MFE _____ River _____ Plans Examiner MA Date 11/2/09
 Comments No charge for permit - Columbia County - No NOC Required
 NOC EH Deed or PA Site Plan State Road Info Parent Parcel # _____
 Dev Permit # _____ In Floodway Letter of Auth. from Contractor F W Comp. letter
 IMPACT FEES: EMS _____ Fire _____ Corr _____ Road/Code _____
 School _____ = TOTAL 0

Septic Permit No. X09-347 Fax _____

Name Authorized Person Signing Permit Ken Bringle Phone 904-425-3363

Address 263 S. Edgewood Ave, Jacksonville, FL 32254

Owners Name Columbia County Phone 758-2028

911 Address 435 NW Hall of Fame Dr. Lake City FL 32055

Contractors Name Kenneth Bringle (CNS Signs, Inc.) Phone 904-425-3363

Address 263 S. Edgewood Ave, Jacksonville, FL 32254

Fee Simple Owner Name & Address N/A

Bonding Co. Name & Address Western Surety Co. 101 S. Phillips Ave, Sioux Falls, SD 57117

Architect/Engineer Name & Address ^{FL# 15113} Charles R. Adams, P.E. 820 E. 10th Ave, New Smyrna Beach, FL 32169

Mortgage Lenders Name & Address N/A

Circle the correct power company - FL Power & Light - Clay Elec. - Suwannee Valley Elec. - Progress Energy

Property ID Number 35-35-16-02526-001 Estimated Cost of Construction 4001.00 ^{Installation Only}

Subdivision Name N/A Lot _____ Block _____ Unit _____ Phase _____

Driving Directions 90 West, (R) NW Hall of Fame Dr., (R) At the Sports Hall of Fame Building, follow parking lot to rear on the (R) side of building - see dirt path around trees then it turns (L) by Interstate fence to the sign. Number of Existing Dwellings on Property 0

Construction of Replacing Sign Section on Existing Sign Total Acreage 1.55 Lot Size 1.55

Do you need a - Culvert Permit or Culvert Waiver or Have an Existing Drive Total Building Height _____

Actual Distance of Structure from Property Lines - Front Existing Side Side _____ Rear _____

Number of Stories _____ Heated Floor Area _____ Total Floor Area _____ Roof Pitch _____

Application is hereby made to obtain a permit to do work and installations as indicated. I certify that no work or installation has commenced prior to the issuance of a permit and that all work be performed to meet the standards of all laws regulating construction in this jurisdiction.

[Signature] (Don't forget to Address)

Columbia County Building Permit Application

TIME LIMITATIONS OF APPLICATION : An application for a permit for any proposed work shall be deemed to have been abandoned 180 days after the date of filing, unless such application has been pursued in good faith or a permit has been issued; except that the building official is authorized to grant one or more extensions of time for additional periods not exceeding 90 days each. The extension shall be requested in writing and justifiable cause demonstrated.

TIME LIMITATIONS OF PERMITS: Every permit issued shall become invalid unless the work authorized by such permit is commenced within 180 days after its issuance, or if the work authorized by such permit is suspended or abandoned for a period of 180 days after the time work is commenced. A valid permit receives an approved inspection every 180 days. Work shall be considered not suspended, abandoned or invalid when the permit has received an approved inspection within 180 days of the previous approved inspection.

FLORIDA'S CONSTRUCTION LIEN LAW: Protect Yourself and Your Investment: According to Florida Law, those who work on your property or provide materials, and are not paid-in-full, have a right to enforce their claim for payment against your property. This claim is known as a construction lien. If your contractor fails to pay subcontractors or material suppliers or neglects to make other legally required payments, the people who are owed money may look to your property for payment, even if you have paid your contractor in full. This means if a lien is filed against your property, it could be sold against your will to pay for labor, materials or other services which your contractor may have failed to pay.

NOTICE OF RESPONSIBILITY TO BUILDING PERMITEE: **YOU ARE HEREBY NOTIFIED** as the recipient of a building permit from Columbia County, Florida, you will be held responsible to the County for any damage to sidewalks and/or road curbs and gutters, concrete features and structures, together with damage to drainage facilities, removal of sod, major changes to lot grades that result in ponding of water, or other damage to roadway and other public infrastructure facilities caused by you or your contractor, subcontractors, agents or representatives in the construction and/or improvement of the building and lot for which this permit is issued. No certificate of occupancy will be issued until all corrective work to these public infrastructures and facilities has been corrected.

WARNING TO OWNER: YOUR FAILURE TO RECORD A NOTICE OF COMMENCEMENT MAY RESULT IN YOU PAYING TWICE FOR IMPROVEMENTS TO YOUR PROPERTY. A NOTICE OF COMMENCEMENT MUST BE RECORDED AND POSTED ON THE JOB SITE BEFORE THE FIRST INSPECTION. IF YOU INTEND TO OBTAIN FINANCING, CONSULT WITH YOUR LENDER OR ATTORNEY BEFORE RECORDING YOUR NOTICE OF COMMENCEMENT.

OWNERS CERTIFICATION: I CERTIFY THAT ALL THE FOREGOING INFORMATION IS ACCURATE AND THAT ALL WORK WILL BE DONE IN COMPLIANCE WITH ALL APPLICABLE LAWS REGULATING CONSTRUCTION AND ZONING.

NOTICE TO OWNER: There are some properties that may have deed restrictions recorded upon them. These restrictions may limit or prohibit the work applied for in your building permit. It may be to your advantage to check and see if your property is encumbered by any restrictions.

(Owners Must Sign All Applications Before Permit Issuance.)

Pen Scott

Owners Signature

****OWNER BUILDERS MUST PERSONALLY APPEAR AND SIGN THE BUILDING PERMIT.**

CONTRACTORS AFFIDAVIT: By my signature I understand and agree that I have informed and provided this written statement to the owner of all the above written responsibilities in Columbia County for obtaining this Building Permit including all application and permit time limitations.

[Signature]

Contractor's Signature (Permittee)

Contractor's License Number ES 0000 258
Columbia County
Competency Card Number 711

Affirmed under penalty of perjury to by the Contractor and subscribed before me this 2 day of Nov 2009.

Personally known _____ or Produced Identification FD DL

[Signature]

State of Florida Notary Signature (For the Contractor)

SEAL:



Columbia County Property Appraiser

DB Last Updated: 10/9/2009

2009 Preliminary Values

[Tax Record](#)
[Property Card](#)
[Interactive GIS Map](#)
[Print](#)

Parcel: 35-3S-16-02526-001 03

Owner & Property Info

Search Result: 1 of 1

Owner's Name	COLUMBIA COUNTY		
Site Address			
Mailing Address	P O BOX 1529 LAKE CITY, FL 32056		
Use Desc. (code)	COUNTY (008600)		
Neighborhood	035316.00	Tax District	1
UD Codes	MKTA06	Market Area	06
Total Land Area	1.550 ACRES		
Description	COMM NW COR OF SEC, RUN W COMM NW COR OF SEC, RUN W 1074.95 FT TO W R/W I-75, SE 1074.95 FT TO W R/W I-75, SE ALONG R/W 2062.22 FT TO W LINE ALONG R/W 2062.22 FT TO W LINE OF SEC FOR POB. CONT SE 472.32 FT OF SEC FOR POB. CONT SE 472.32 FT, SW 286.45 FT TO W. LINE OF FT, SW 286.45 FT TO W. LINE OF SEC, N 552.39 FT TO POB. SEC, N 552.39 FT TO POB. ORB 741-909 ORB 741-909		

GIS Aerial



Property & Assessment Values

Mkt Land Value	cnt: (1)	\$28,116.00
Ag Land Value	cnt: (0)	\$0.00
Building Value	cnt: (0)	\$0.00
XFOB Value	cnt: (0)	\$0.00
Total Appraised Value		\$28,116.00

Just Value	\$28,116.00
Class Value	\$0.00
Assessed Value	\$28,116.00
Exemptions	(code: 03) \$28,116.00
Total Taxable Value	County: \$0.00 City: \$0.00 Other: \$0.00 School: \$0.00

Sales History

Sale Date	Book/Page	Inst. Type	Sale VImp	Sale Qual	Sale RCode	Sale Price
1/25/1991	741/909	WD	V	U	11	\$0.00

Building Characteristics

Bldg Item	Bldg Desc	Year Blt	Ext. Walls	Heated S.F.	Actual S.F.	Bldg Value
NONE						

Extra Features & Out Buildings

Code	Desc	Year Blt	Value	Units	Dims	Condition (% Good)
NONE						

Land Breakdown

Lnd Code	Desc	Units	Adjustments	Eff Rate	Lnd Value
008600	COUNTY (MKT)	0000001.550 AC	1.00/1.00/1.00/1.00	\$18,139.68	\$28,116.00

Charles R. Adams & Associates, Inc.
Structural Engineers

October 8, 2009

Mr. Roger Van Houtan
Green Group Media
5521 Greenville Avenue
Suite 104-752
Dallas, TX 75206

Re: Message Board Installation
1 Mile North of I-75, Exit 427
Lake City, FL

Dear Mr. Van Houtan,

This is to advise you that I have reviewed the wind loading on the new message board at the referenced location. The new message board has an exposed surface area that is no greater than that of the sign it is replacing. It is, therefore, my professional opinion that the new lateral load will be no greater than the one imposed by the existing sign. I

If you have any questions or require additional information, please contact me.


Sincerely,



Charles R. Adams, P.E.
FL # 15113

Handwritten initials and date:
10-4-09

Handwritten signature and notes:
 #15113






ITEM NO.	QTY.	DESCRIPTION	LENGTH
1	2	TUBE SQUARE 2" X 2" X 5/16"	21 3/4"
2	2	TUBE SQUARE 2" X 2" X 5/16"	78 3/4"
3	1	TUBE SQUARE 2" X 2" X 5/16"	33 1/8"

UNLESS OTHERWISE SPECIFIED		DRAWN		DATE	
CONNECTIONS ARE IN ACCORDANCE WITH AISC 1301	WELDED JOINTS SHALL BE FULL PENETRATION BUTT JOINTS	NAME	RV	DATE	DATE
ALL DIMENSIONS ARE IN INCHES	ANGULAR MATCHES SHALL BE 1:1	NAME	RV	DATE	DATE
ALL DIMENSIONS ARE IN INCHES	ANGULAR MATCHES SHALL BE 1:1	NAME	RV	DATE	DATE

CONTRACTOR	CLIENT	PROJECT
CONTRACT NO.	CLIENT NAME	PROJECT NAME
DATE	CLIENT ADDRESS	PROJECT ADDRESS

SIZE	DWG. NO.	REV.
B	31.25 4X9 -2	A
SCALE: 1/8" = 1'-0"	WEIGHT:	SHEET 2 OF 6

Handwritten signature and notes:
 #15113



DETAIL T
 SCALE 1 : 5

DETAIL I
 SCALE 1 : 20


PROVIDER AT RISK COMMERCIAL
 THE INFORMATION CONTAINED IN THIS
 DRAWING IS THE PROPERTY OF PROVIDER AT
 RISK COMMERCIAL. IT IS TO BE USED ONLY
 FOR THE PROJECT AND SITE SPECIFICALLY
 IDENTIFIED HEREIN. ANY REPRODUCTION
 OR TRANSMISSION OF THIS DRAWING
 WITHOUT THE WRITTEN PERMISSION OF
 PROVIDER AT RISK COMMERCIAL IS
 PROHIBITED.

UNLESS OTHERWISE SPECIFIED:		DATE
DIMENSIONS ARE IN INCHES	DRAWN	RV
TOLERANCES UNLESS NOTED OTHERWISE	CHECKED	9/1/09
FINISHES UNLESS NOTED OTHERWISE	ENG APPR	
SPACING UNLESS NOTED OTHERWISE	MFG APPR	
INTERFERING COMPONENTS TO BE REMOVED OR MODIFIED	COMMENTS:	
DO NOT SCALE DRAWING	Checked by: Adam & Associates, Inc.	
	303 E. 10th Ave.	
	Minneapolis, MN 55414	
	Cert. of Auth. #4180	
	SIZE: DWG. NO. B 31.25	REV A
	SCALE: 1"=10' HEIGHT	SHEET 3 OF 6
	Lake City	
	LED Mounting Bracket	
	Attachment	


6 5 4 3 2 1

Handwritten signature and initials
 P #15113

SECTION K-K
 Floor detail



8x4x5/16 HSS



2x2x5/16 HSS

8x4x5/16 HSS

DETAIL R
 SCALE 1 : 20

PROPRIETARY AND CONFIDENTIAL
 THE INFORMATION CONTAINED IN THIS DRAWING IS THE PROPERTY OF THE DRAWING COMPANY AND IS NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, WITHOUT THE WRITTEN PERMISSION OF THE DRAWING COMPANY.


UNLESS OTHERWISE SPECIFIED:		DATE
DIMENSIONS ARE IN INCHES	DRAWN	EV
TOLERANCES	CHECKED	9/1/09
FINISHES	BY	
WELDING	BY	
PAINTS	BY	
OTHER	BY	
DO NOT SCALE DRAWING	BY	
APPROVAL	BY	
DATE	BY	
REVISIONS	BY	
NO. 1	BY	
NO. 2	BY	
NO. 3	BY	
NO. 4	BY	
NO. 5	BY	
NO. 6	BY	
NO. 7	BY	
NO. 8	BY	
NO. 9	BY	
NO. 10	BY	
NO. 11	BY	
NO. 12	BY	
NO. 13	BY	
NO. 14	BY	
NO. 15	BY	
NO. 16	BY	
NO. 17	BY	
NO. 18	BY	
NO. 19	BY	
NO. 20	BY	
NO. 21	BY	
NO. 22	BY	
NO. 23	BY	
NO. 24	BY	
NO. 25	BY	
NO. 26	BY	
NO. 27	BY	
NO. 28	BY	
NO. 29	BY	
NO. 30	BY	
NO. 31	BY	
NO. 32	BY	
NO. 33	BY	
NO. 34	BY	
NO. 35	BY	
NO. 36	BY	
NO. 37	BY	
NO. 38	BY	
NO. 39	BY	
NO. 40	BY	
NO. 41	BY	
NO. 42	BY	
NO. 43	BY	
NO. 44	BY	
NO. 45	BY	
NO. 46	BY	
NO. 47	BY	
NO. 48	BY	
NO. 49	BY	
NO. 50	BY	
NO. 51	BY	
NO. 52	BY	
NO. 53	BY	
NO. 54	BY	
NO. 55	BY	
NO. 56	BY	
NO. 57	BY	
NO. 58	BY	
NO. 59	BY	
NO. 60	BY	
NO. 61	BY	
NO. 62	BY	
NO. 63	BY	
NO. 64	BY	
NO. 65	BY	
NO. 66	BY	
NO. 67	BY	
NO. 68	BY	
NO. 69	BY	
NO. 70	BY	
NO. 71	BY	
NO. 72	BY	
NO. 73	BY	
NO. 74	BY	
NO. 75	BY	
NO. 76	BY	
NO. 77	BY	
NO. 78	BY	
NO. 79	BY	
NO. 80	BY	
NO. 81	BY	
NO. 82	BY	
NO. 83	BY	
NO. 84	BY	
NO. 85	BY	
NO. 86	BY	
NO. 87	BY	
NO. 88	BY	
NO. 89	BY	
NO. 90	BY	
NO. 91	BY	
NO. 92	BY	
NO. 93	BY	
NO. 94	BY	
NO. 95	BY	
NO. 96	BY	
NO. 97	BY	
NO. 98	BY	
NO. 99	BY	
NO. 100	BY	

LAKE CITY
 Floor Detail
 SCALE: 1/16"=1'-0"
 SHEET 4 OF 6

Handwritten signature and notes:
 #1510-2
 8-29


DETAIL AE
 SCALE 1 : 20

SECTION AC-AC



AC SECTION P-P

DETAIL Q
 SCALE 1 : 20



FORWARDER HAS CONFIRMED THAT THE WORK IS THE SOLE PROPERTY OF THE ENGINEER AND THAT ANY REPRODUCTION WITHOUT HIS WRITTEN PERMISSION IS STRICTLY PROHIBITED.

UNLESS OTHERWISE SPECIFIED:	DESIGNING ENGINEER	DRAWN	NAME	DATE
CONCRETE		CHECKED		
STEEL		ENG APPR		
WOOD		ENG APPR		
MECHANICAL		DATE		
ELECTRICAL				
OTHER				


COMMENTS:
 Checked by James S. [unclear], Inc.
 Registered Engineer
 No. 12345
 State of Florida, F.S. 37108
 Cert. of Auth. #4180

SCALE: 1:10 HEIGHT: [unclear]

SHEET 5 OF 6

Lake City
 Attachment Side View

REV A



200 amp 240V service panel / 11 - 20amp 110V breakers

Control Center

Green Group Media

Lake City 31.25 Power and Data

Power Distribution

Roger Van Houtan

Confidential Document

SIZE

ES&M NO

DWG NO

REV

SCALE

1 - 50

SHEET

1 OF 4

8

7

6

5

4

3

2

1

Column 9

Column 8

Column 7

Column 6

Column 5

Column 4

Column 3

Column 2

Column 1

Row 1

Row 2

Row 3

Row 4

A

B

C

D

E

F

G

H

A

B

C


D

E

F

G

H



Lake City 31.25 Power and Data

Data Layout


Green Group Media		Lake City 31.25 Power and Data	
Roger Van Houtan	SIZE	FRONT NO.	DRAW NO.
Confidential Document	SCALE	1.50	SHEET
			2 OF 4


Control Center

Photo/Temp Sensor

Internet connection by others

Column 9 Column 8 Column 7 Column 6 Column 5 Column 4 Column 3 Column 2 Column 1





Internal to Control system

<->DSL

Internet

Remote Computer

Data ->

To LED Display

Sensor <-

From LED Display

- Power
- - - - - KVM
- CAT5e

Green Group Media		Lake City 31 25 Power and Data	
Roger Van Houtan		Control Center	
Confidential Document	SIZE	FORM NO	DWG NO
	SCALE	1 : 50	SHEET
			3 OF 4



Florida Department of Transportation

CHARLIE CRIST
GOVERNOR

605 Suwannee Street
Tallahassee, FL 32399-0450
March 15, 2007

STEPHANIE KOPELOUSOS
INTERIM SECRETARY

Harvey Campbell
Executive Director
Tourist Development Council of Columbia County
Post Office box 1847
Lake City, FL 32056

Dear Mr. Campbell:

You have asked for the Department's input on the use of the on-premise sign currently in use at the Tourist Welcome Center at the I-75/US 90 interchange. We understand that it is your intent to upgrade this sign by installing a digital display panel which is capable of displaying full motion video.

While there are concerns about the safety aspects of full motion displays visible to drivers of motor vehicles on a high-speed facility such as I-75, there is currently no objective data on which to base regulations. The Department is undertaking a study of these signs within the State of Florida and the Federal Highway Administration (FHWA) has received funding for a study at the national level.

Until we have data from these studies, the Department's only regulation is that which applies to off-premises billboards. This regulation requires that any changeable message remain static for a minimum of six (6) seconds and that the message change in less than two (2) seconds with no scrolling. Section 316.303, Florida Statutes, prohibits the location of a television-type receiver within the view of the driver. This leads us to believe that research may support a conclusion that other moving images are similarly distracting and may be banned. We suggest that a prudent course of action for Columbia County would be to select a sign technology which will provide flexibility to limit full motion. This would be especially important if future research determines that unlimited motion constitutes a motorist distraction safety hazard and limiting regulations are promulgated at the federal or State level.

I trust this is sufficient to address your concerns and allow you to proceed with your upgrade project.

Sincerely,

A handwritten signature in black ink, appearing to read "K. M. Towcimak".

Kenneth M. Towcimak, Director
Office of Right of Way

Cc: Marianne Trussel