

Addendum 2
Bid No. 2017-M
Ft White Senior Center Pavilion

Additional information not included on the construction documents.

1. There is approximately 60ft.+/- from the electrical panel to the proposed pavilion that will not be exposed that can be ran in pvc conduit and all piping that will be exposed to be ran in emt with compression connectors.
2. Joints on the ceiling plywood should be stripped with 1x2 and also painted.