

**ADDENDUM 3  
FIRESTATION #45 RENOVATION  
BID NO. 2018-E**

1. The model no. for the micro hood is a microwave not a hood.  
Please confirm if you want a microwave or a hood?

2. Are you using the existing sink or a new one, if a new one please  
provide the type/model no.

**ANSWERS:**

1. Microwave hood combination, this comes already set up for vent-less use.
2. The kitchen faucet is a Banbury 1 handle model# 026508192627 or similar product. The County will provide a new sink to be installed.