

Addendum 2
SW Gabriel Place and SW Birley Ave Sidewalk Construction
Bid No. 2019-6

Question 1

Bid item 18 is duplicated and the Description appears to be incorrect on the second #18.

Answer 1

The description on the second #18 should read "PIPE CULVERT, OPT MATL, OTHER, 18"S/CD". The pay item and estimated quantity are correct.

Question 2

On the plan sheets, there are several driveways and one side street that are identified in the legend as "EXIST. DRWY RECONSTRUCTION". Please detail what work is to be done at these locations identified as so and provide a pay item or items for this work.

Answer 2

The "EXIST. DRWY RECONSTRUCTION" is covered with the Pay Item Note on Sheet 8. Per FDOT Specs, the cost of restoring driveways that are disturbed solely for the purpose of constructing pipe is included in the cost of the pipe.