

Addendum 2 Annual Concrete Bid No. 2019-U

Question #1

On the bid notes (#9) states item 21-23 to include cost excavate, place #5 rebar mat, place and finish concrete to grade. Does this mean to only bid one #5 rebar mat? What spacing O/C will rebar be install? Most column footers have 2 mats of #5 and vary on spacing from 6" O/C both directions to 12" O/C both directions. This could really cause the price per column footer to change.

Question #1 Response- Each Concrete column/pier footing shall include cost for 2 mats and #5 rebar spacing at 6" O/C both directions.

Question #2

On the bid notes (#7) states item 15 shall include cost to grade and compact 6" below concrete to 95% density per AASHTO T-99..... Does this mean to include pricing for proctors and density testing per job? Which would include ALL sidewalk repair, driveway repair, MES, and slab repair along with ALL new construction? This will impact pricing and time to complete projects due to waiting on test results for proctor so a density test can be achieved.

Question #2 Response- There will be a line item added for the cost to perform a density test and the proctor will need to be included in the cost. The County will then use this pay item on an as needed basis.

Question #3

Within the bid package it states the county wants 3000 psi concrete with fiber..... However the MES detail included in package shows wire mesh to be installed. Do line items 1-4 need to be bid as installing wire and fiber? Does bid need to include pricing for wire and fiber for all line items that show being reinforced?

Question #3 Response- Yes, all mitered end section (items 1-4) shall have 6"x6" welded wire mesh(per attached detail), and fiber mesh in concrete. Yes, (items 5,6, and 19) shall include pricing for 6"x6" welded wire mesh and fiber mesh for all items showing reinforced with the pay item.

All pay items that do not have reinforced in the pay item description shall include only the fiber mesh in the concrete, per Bid Note #4.

Question #4

Can you please explain how the county wants pricing for the Qty's given?

For example..... Line item 1 MES 18" Qty 75. Does this mean that there will be 75 MES to complete at one time under one work order? Or is this a projected number of MES for the length of this contract? The price difference between consecutive work and spaced out work will be a huge. Next example....Line item 11 seeding and mulching Qty 4000 sy. This Qty is over 2/3 of an acre.

What my concern is when bidding this contract with the Qty given people can read into this different ways. Prices per line item with Qty will look really expensive. What im asking is this to be bid for Qty given and will this be consecutive work? As I stated above prices can vary by a substantial amount depending on how this bid package is read.

Question #4 Response- Quantities for this Annual Contract are estimated only and based on averages of past annual contracts. All quantities are used on an as needed bases for the County's needs for that given year for each given project. Per Bid Note #1- Quantities are estimates only and may be increased, decreased, or omitted by the County.