

ADDENDUM NO. 3
BID NO. 2022-V
FIRE STATION NO. 51
EXPANSION

Date of Addenda: April 28, 2022


1. Attached is a copy of the Pre-Bid Agenda along with copy of sign-in sheet for those present.
2. Attached is a sketch and more detail with regard to the floor slab.
3. The site work and asphalt paving are to be completed in accordance with the latest FDOT specifications.
4. For the new bay, only one ridge vent is to be required, matching the same type and size as existing.
5. The roll-up door is to match existing bay doors from Overhead Door Company of Gainesville. It is a 14' x 14', motor to be included (typically a 115v); contractor to install including a 3-button surface-mounted device. All electrical hook-up to be done by County.

END OF ADDENDA NO. 3

(Please acknowledge receipt of Addenda on Bid Form)

Fire Station #51 expansion Concrete slab information

- Concrete slab will be 6" thick with 6x6 ww placed according to current Florida Bldg. Code
- There should be a min. 3' space left between the existing concrete slab and the new concrete slab until the end wall of the existing metal structure is removed to allow proper connection of both new and existing concrete slabs, at which time the space will be filled in.
- Before the voided space between the concrete slabs is filled in, there will be a #5 dowel drilled and epoxied at a min 8" deep extending out at a min 12" and will be 4' on center at the edge of both the existing and new concrete slabs for support (see diagram below).
- All elevations and measurements to be field verified by Contractor.



NOT TO SCALE

**AGENDA FOR
NON-MANDATORY
PRE-BID MEETING
APRIL 27, 2022, 1:30 PM
BID NO. 2022-V
FIRE STATION #51 EXPANSION**

1. Introductions

- Mike Null, Purchasing Officer
- Donny DuPree, Maintenance & Facilities Director
- Chad Williams, County Professional Engineer
- Chief Jeff Crawford

2. Housekeeping matters:

- Sealed Bids will be accepted no later than 2:00 PM on May 11, 2022 at the County Commissioners Office in the Courthouse Annex. Please show Bid Number and Name on outside of envelope. You are welcome to remain for the Bid opening at that time.
- Today is a Non-Mandatory Pre-Bid Meeting.
- Two (2) Addenda's have been issued to date. Any new Addenda's to be issued will be posted on our Web Portal with e-mail notices going to registered bidders at 5:00PM the day the Addenda is posted.
- Deadline for any questions regarding this project are to be submitted via email to: bccpurchasing@columbiacountyfla.com no later than 5:00PM on May 3, 2022.
- When submitting the completed Bid Form, be sure to include the Supplemental Forms that were included with the posted bid specifications.
- Bid Bonds are not a requirement for this Bid.
- We anticipate the Bid Award to take place during the regular Board meeting on May 19, 2022. This office will then prepare and send to the Contract Documents to the awarded Low Bidder. Contractor will return fully executed copies along with the required Certificates of Insurance.
- In just a moment, Donnie Dupree will go over the Scope of Work as it relates to the Building portion of the project and will identify the

Owner performed items. He will be followed by Chad Williams who will briefly cover the civil work of this project.

- The Contract Time for this project currently shows 180 calendar days for Substantial Completion.
- Following their comments, we will open the floor for questions. Some of these questions may require to show answers by way of Addenda.

PRE-BID MEETING 04/27/2022
FIRE STATION # 51 EXPANSION
BID NO. 2022-V

NAME	COMPANY NAME	EMAIL	PHONE NUMBER
WILLIAM SLONE	SLONE ASSOC.	W.SLONE@SLONE-ASSOC.COM	229-244-6709
Ryan Worthington	Advantage Contracting Group	ryan.worthington@gmail.com	904-219-3556
Ali Drandy	WMC Steel	alindrandy@gmail.com	386-935-0014
KEVIN KILPATRICK	SLONE ASSOCIATES INC	KEVIN.KILPATRICK@SLONE-ASSOC.COM	229-412-7088
Kevin Belenbaugh	Plumb-horval Construction	Plumbhorvalconstruction@gmail.com	386-792-4061
Stephen Douglas	DML Construction	Stephen@dmlc.com	386-867-5055
Chad Wilcox	Columbia County	chad.wilcox@columbiacountyfla.com	386-623-2452
Mike Null	CCBCC	bcc.purchasing@columbiacountyfla.com	386-719-2028
Donny Dupree	CCBCC	ddupree@columbiacountyfla.com	386-867-0953
Chad Williams	CCBCC County Engineer	chad_williams@columbiacountyfla.com	386-758-1019
Jeff Crawford, Fire Chief	County Fire	jeff_crawford@columbiacountyfla.com	386-788-3907
Shane Overstreet Lt	CC Fire Dept	soverstreet@columbiacountyfla.com	386-754-7051