

**ADDENDUM NO. 1  
BID NO. 2022-W  
WATER MAIN MATERIALS  
FOR  
ELLISVILLE TO FORT WHITE**

**BID SHEET A, B, C ITEM NO. 14 Hydrants shall be 42 inch depth of bury.**

**END OF ADDENDA 1**

Acknowledge receipt of Addenda on Signature Page of Bid Form