



NFPS



PO BOX 3823
LAKE CITY, FL 32056



PHONE (386) 752-4675
FAX (386) 752-4674



www.nfps.net

January 15, 2024

Columbia County Board of County Commissioners
Bethlehem Park Community Center
Engineers Project Number L220819CCB

Addendum # 7

1. Addendum 6 shows an automatic transfer switch added to the electrical service equipment; do you want a specific one? Do we need to include a generator as well? If so, what type of fuel for the generator? (propane, diesel etc.) Are you looking for something simple like a Generac system?
 - a. The Contractor shall provide a complete LP gas fired standby generator (30 kw minimum) system capable of operating all building components. The work under this item shall include an automatic transfer switch (ATS) and any other appurtenances (excluding LP gas tank to be provided by others) necessary for fully functional system. The Generac Protector Series or equal is acceptable

END OF ADDENDUM NO. 7
(Please acknowledge receipt of Addendums)