

**ADDENDUM NO 1
2026-D
WELL #3 ELECTRICAL**

QUESTIONS AND ANSWERS

- 1. Will there be a pre-bid meeting or a site visit? If not, can we schedule a site visit?**
 - a. There will not be a pre-bid meeting but there can be a site visit scheduled, below is the contact information for Robert Domingue (386)- 984-5872

- 2. Is there a preferred manufacturer for the triplex well controller?**
 - a. See Scope of Work

- 3. What is the preferred enclosure type for the 60 amp disconnect? (Nema 4X or 3R painted steel)**
 - a. Nema 4X

- 4. What is the preferred conduit for the underground work? (Sch80 or SCH40 PVC)**
 - a. Sch80

- 5. What is the preferred conduit for exposed raceways?**
 - a. See Question 4

- 6. What is the engineered budget for this project?**
 - a. There is no engineered budget

END OF ADDENDUM NO. 1
(Please acknowledge receipt of Addendums)