

**ADDENDUM NO 1  
2026-I  
FIRE STATION #51 GENERATOR**

**QUESTIONS AND ANSWERS**

1. Is the County supplying the generator, or is it part of the contractor's bid package?
  - a. To be supplied by Contractor
  
2. Is a Generac generator the only generator accepted on this project?
  - a. Generator must be compatible with Generac transfer switch and 80kwh.
  
3. Will a Winco Generator be acceptable?
  - a. If meets specifications in Question #2 and Scope of Work
  
4. Is a remote annunciator required?
  - a. Possibly – include in pricing and if not required will conduct a deductive change order
  
5. Is a remote Emergency Stop required?
  - a. No
  
6. Is the existing Generac transfer switch a two wire control?
  - a. Unknown – two or three
  
7. Is a permit required?
  - a. Required to pull permit – no fee will be associated
  
8. What source can shore power(trickle charging and water jacket circuit)?
  - a. Contractor will need to provide a dedicated circuit for the battery charger, since this is a natural gas fueled generator a block heater may not be needed
  
9. Are Light Commercial Units allowed?
  - a. Must match the specifications
  
10. Are we able to quote Light Commercial XG080 as an Alternate?
  - a. No
  
11. Will this project be under a grant?
  - a. No
  
12. Will the County accept Gillette Generator and/or Cummins as an "Approved Equal"?
  - a. See Question #3

**UPDATE SPECIFICATIONS**

1. The Industrial gaseous 9.0L V-8 Engine Driven Generator specifications are no longer available and will now need to an Industrial Gaseous 4.5L 4cylinder Engine Driven Generator. – Still a Natural Gas Powered Generator

**END OF ADDENDUM NO. 1**  
(Please acknowledge receipt of Addendums)