

ADDENDUM NO 3
S25-01
QUAIL HEIGHTS STORMWATER POND

Questions:

1. Is the temporary driveway on 247 the only access for duration of this job, or can county road be used – adjacent to Quail Heights?
Due to the location of Cannon Creek and the surrounding wetlands, the site can only be accessed from the proposed driveway off of SR 247 to prevent impacts to Cannon Creek and the surrounding wetlands.
2. Will FDOT allow temporary signalization, or flagman, for dump trucks and heavy equipment that would be condensed to a time period for export dirt trucked out onto this heavily used section of 247? The traffic count would be so great for the export of fill, that is our concern, mixing would be very complex.
This would be discussed and determined at the pre-construction meeting with the awarded contractor. The contractor is ultimately responsible for all traffic entering and exiting the construction site.
3. Can there be a line item added to the bid sheet for dewatering since this is such a weather sensitive area and wet area and is it permissible to discharge this water back into Cannon Creek?
Normal dewatering activities is included in the price of regular excavation as per FDOT Specification 120. All discharge shall follow the state water quality standards and meet the requirements of the contractor obtained NPDES permit.

END OF ADDENDUM NO. 3
(Please acknowledge receipt of Addendums)