



CAL-TECH TESTING, INC.

ENGINEERING & TESTING LABORATORY

P.O. Box 1625, Lake City, FL 32056-1625
7540 103rd St. Suite 215 • Jacksonville, FL 32210

Lake City • (386) 755-3633

Fax • (386) 752-5456

Jacksonville • (904) 381-8901

Fax • (904) 381-8902

JOB NO.: 21 491
DATE TESTED: 11.27.21

REPORT OF IN-PLACE DENSITY TEST

ASTM METHOD: X (D-2922) Nuclear (D-2937) Drive Cylinder Other

PROJECT: 206 SE SAND A WAY

CLIENT: Mike Todd

GENERAL CONTRACTOR: SAC EARTHWORK CONTRACTOR: SAC

SOIL USE (SEE NOTE): Building fill SPECIFICATION REQUIREMENTS: 95% +

TECHNICIAN: B. Spaul

MODIFIED (ASTM D-1557): X STANDARD (ASTM D-698):

TEST NO.	TEST LOCATION	TEST:	PROCTOR NO.	WET DENS. LBS./CU.FT.	DRY DENS. LBS./CU.FT.	MOIST PERCENT	% MAX. DENS.
		DEPTH ELEV. LIFT					
	NE corner of pad						
	21" (S) 11" (W)		1	109.2	106.2	2.8	99
	9" (S) 18" (W)		1	109.8	106.3	2.4	99
	10" (S) 24" (W)		1	109.4	106.1	3.1	99

REMARKS:

PROCTOR NO.	SOIL DESCRIPTION	PROCTOR VALUE	OPT. MOIST.
1	light tan sand	109.2	

NOTE: 1. Building Fill 2. Trench Backfill 3. Base Course 4. Subbase/Stabilized Subgrade 5. Embankment 6. Subgrade/Natural Soil 7. Other
The test results presented in this report are specific only to the samples tested at the time of testing. The tests were performed in accordance with generally accepted methods and standards. Since material conditions can vary between test location and change with time, sound judgement should be exercised with regard to the use and interpretation of the data.