

Manual N Calculations  
HVAC Load Calculations

Project Name: Dr Ukaegbu Office  
Unit A Tenant Fit Out

Project Address: Columbia County  
Lake City, FL 32055

Software: Carrier HAP v5.10

HAP is a multi-function tool supporting peak load calculation and system sizing for commercial buildings of any size. Peak loads are calculated with the ASHRAE Transfer Function Method. Required airflow rates and equipment capacities are derived based on the specified system type. Calculations use a full 8,760 hour-by-hour simulation approach.

HAP complies with ASHRAE Standard 183

## Air System Sizing Summary for AHU-1 CU-1

Project Name: Dr Ukaegba Office  
Prepared by: FloridaEnergyCalcs.com

04/24/2022  
06:52PM

### Air System Information

Air System Name ..... **AHU-1 CU-1**  
Equipment Class ..... **SPLT AHU**  
Air System Type ..... **SZCAV**

Number of zones ..... **1**  
Floor Area ..... **2070.0** ft<sup>2</sup>  
Location ..... **Lake City, Florida**

### Sizing Calculation Information

Calculation Months ..... **Jan to Dec**  
Sizing Data ..... **Calculated**

Zone CFM Sizing ..... **Sum of space airflow rates**  
Space CFM Sizing ..... **Individual peak space loads**

### Central Cooling Coil Sizing Data

Total coil load ..... **4.9** Tons  
Total coil load ..... **58.8** MBH  
Sensible coil load ..... **45.4** MBH  
Coil CFM at Sep 1400 ..... **2506** CFM  
Max block CFM ..... **2506** CFM  
Sum of peak zone CFM ..... **2506** CFM  
Sensible heat ratio ..... **0.772**  
CFM/Ton ..... **511.5**  
ft<sup>2</sup>/Ton ..... **422.5**  
BTU/(hr-ft<sup>2</sup>) ..... **28.4**  
Water flow @ 10.0 °F rise ..... **N/A**

Load occurs at ..... **Sep 1400**  
OA DB / WB ..... **91.5 / 75.9** °F  
Entering DB / WB ..... **74.5 / 64.6** °F  
Leaving DB / WB ..... **57.7 / 56.8** °F  
Coil ADP ..... **55.8** °F  
Bypass Factor ..... **0.100**  
Resulting RH ..... **59** %  
Design supply temp. .... **58.0** °F  
Zone T-stat Check ..... **0 of 1** OK  
Max zone temperature deviation ..... **0.0** °F

### Central Heating Coil Sizing Data

Max coil load ..... **11.7** MBH  
Coil CFM at Des Htg ..... **2506** CFM  
Max coil CFM ..... **2506** CFM  
Water flow @ 20.0 °F drop ..... **N/A**

Load occurs at ..... **Des Htg**  
BTU/(hr-ft<sup>2</sup>) ..... **5.6**  
Ent. DB / Lvg DB ..... **64.7 / 69.0** °F

### Supply Fan Sizing Data

Actual max CFM ..... **2506** CFM  
Standard CFM ..... **2503** CFM  
Actual max CFM/ft<sup>2</sup> ..... **1.21** CFM/ft<sup>2</sup>

Fan motor BHP ..... **n/a**  
Fan motor kW ..... **1.96** kW

### Outdoor Ventilation Air Data

Design airflow CFM ..... **194** CFM  
CFM/ft<sup>2</sup> ..... **0.09** CFM/ft<sup>2</sup>

CFM/person ..... **5.18** CFM/person

## Air System Sizing Summary for AHU-2 CU-2

Project Name: Dr Ukaegba Office  
Prepared by: FloridaEnergyCalcs.com

04/24/2022  
06:52PM

### Air System Information

Air System Name ..... **AHU-2 CU-2**  
Equipment Class ..... **SPLT AHU**  
Air System Type ..... **SZCAV**

Number of zones ..... **1**  
Floor Area ..... **2430.0** ft<sup>2</sup>  
Location ..... **Lake City, Florida**

### Sizing Calculation Information

Calculation Months ..... **Jan to Dec**  
Sizing Data ..... **Calculated**

Zone CFM Sizing ..... **Sum of space airflow rates**  
Space CFM Sizing ..... **Individual peak space loads**

### Central Cooling Coil Sizing Data

Total coil load ..... **4.9** Tons  
Total coil load ..... **58.3** MBH  
Sensible coil load ..... **47.3** MBH  
Coil CFM at Jul 1500 ..... **2435** CFM  
Max block CFM ..... **2435** CFM  
Sum of peak zone CFM ..... **2435** CFM  
Sensible heat ratio ..... **0.812**  
CFM/Ton ..... **501.5**  
ft<sup>2</sup>/Ton ..... **500.4**  
BTU/(hr-ft<sup>2</sup>) ..... **24.0**  
Water flow @ 10.0 °F rise ..... **N/A**

Load occurs at ..... **Jul 1500**  
OA DB / WB ..... **94.0 / 77.0** °F  
Entering DB / WB ..... **74.5 / 63.6** °F  
Leaving DB / WB ..... **56.5 / 55.5** °F  
Coil ADP ..... **54.5** °F  
Bypass Factor ..... **0.100**  
Resulting RH ..... **56** %  
Design supply temp. .... **58.0** °F  
Zone T-stat Check ..... **1 of 1** OK  
Max zone temperature deviation ..... **0.0** °F

### Central Heating Coil Sizing Data

Max coil load ..... **12.2** MBH  
Coil CFM at Des Htg ..... **2435** CFM  
Max coil CFM ..... **2435** CFM  
Water flow @ 20.0 °F drop ..... **N/A**

Load occurs at ..... **Des Htg**  
BTU/(hr-ft<sup>2</sup>) ..... **5.0**  
Ent. DB / Lvg DB ..... **64.9 / 69.5** °F

### Supply Fan Sizing Data

Actual max CFM ..... **2435** CFM  
Standard CFM ..... **2432** CFM  
Actual max CFM/ft<sup>2</sup> ..... **1.00** CFM/ft<sup>2</sup>

Fan motor BHP ..... **n/a**  
Fan motor kW ..... **1.91** kW

### Outdoor Ventilation Air Data

Design airflow CFM ..... **196** CFM  
CFM/ft<sup>2</sup> ..... **0.08** CFM/ft<sup>2</sup>

CFM/person ..... **9.11** CFM/person

## AHU-1 CU-1 Input Data

Project Name: Dr Ukaegba Office  
Prepared by: FloridaEnergyCalcs.com

04/24/2022  
06:53PM

### 1. General Details:

Air System Name ..... AHU-1 CU-1  
Equipment Type ..... Split AHU  
Air System Type ..... Single Zone CAV  
Number of zones ..... 1

### 2. Ventilation System Components:

#### Ventilation Air Data:

Airflow Control ..... Constant Ventilation Airflow  
Ventilation Sizing Method ..... Sum of Space OA Airflows  
Unocc. Damper Position ..... Closed  
Damper Leak Rate ..... 0 %  
Outdoor Air CO2 Level ..... 400 ppm

#### Central Cooling Data:

Supply Air Temperature ..... 58.0 °F  
Coil Bypass Factor ..... 0.100  
Cooling Source ..... Air-Cooled DX  
Schedule ..... JFMAMJJASOND  
Capacity Control ..... Cycled or Staged Capacity - Fan On

#### Central Heating Data:

Supply Temperature ..... 95.0 °F  
Heating Source ..... Electric Resistance  
Schedule ..... JFMAMJJASOND  
Capacity Control ..... Cycled or Staged Capacity - Fan On

#### Supply Fan Data:

Fan Type ..... ASHRAE 90.1 App G Fan Curve  
Configuration ..... Draw-thru  
Fan Performance ..... ASHRAE Std 90.1-2010 Appendix G Fan kW  
**ASHRAE Std 90.1-2010 Baseline Fan Adjustment Factor Components:**  
None

Fan Control ..... 1-speed fan, cooling and heating

#### Duct System Data:

##### Supply Duct Data:

Duct Heat Gain ..... 0 %  
Duct Leakage ..... 0 %

##### Return Duct or Plenum Data:

Return Air Via ..... Ducted Return

### 3. Zone Components:

#### Space Assignments:

Zone 1: Medical Offices	
12 Exam Room	x1
13 Business Office	x1
14 Waiting	x1
16 RR	x1
17 Private RR	x1
18 Doctors Office	x1
19 RR	x1
20 Nurse Station	x1
21 Breakroom	x1
22 Staff RR	x1
23 Procedure	x1
24 AHU Closet	x1

#### Thermostats and Zone Data:

Zone	Cooling T-Stat Occ. (°F)	Cooling T-Stat Unocc. (°F)	Heating T-Stat Occ. (°F)	Heating T-Stat Unocc. (°F)	T-Stat Throttling Range (°F)	Diversity Factor (%)	Direct Exhaust Airflow (CFM)	Direct Exhaust Fan (kW)
1	72.0	72.0	68.0	68.0	1.00	100	0.0	0.0

## AHU-1 CU-1 Input Data

Project Name: Dr Ukaegba Office  
Prepared by: FloridaEnergyCalcs.com

04/24/2022  
06:53PM

Thermostat Schedule ..... T-stat  
Unoccupied Cooling is ..... Available

### Supply Terminals Data:

Zone	Terminal Type	Air Distribution	Air Distribution Effectiveness Specification	Air Distribution Effectiveness	Minimum Airflow	Fan Performance	Fan Efficiency	Design Supply Temp.
1	Diffuser (no reheat)	Ceiling supply / ceiling return	Not Used	-	0.00 CFM/person	-	-	-

### Zone Heating Units:

Zone Unit Heat Source ..... Electric Resistance  
Zone Heating Unit Schedule ..... JFMAMJJASND

## 4. Sizing Data (Computer-Generated):

### System Sizing Data:

#### Sizing Data:

Cooling Supply Temperature ..... 58.0 °F  
Supply Fan Airflow ..... 2505.7 CFM  
Ventilation Airflow ..... 194.3 CFM  
Heating Supply Temperature ..... 95.0 °F

#### Hydronic Sizing Specifications:

Chilled Water Delta-T ..... 10.0 °F  
Hot Water Delta-T ..... 20.0 °F

#### Safety Factors:

Cooling Sensible ..... 10 %  
Cooling Latent ..... 10 %  
Heating ..... 10 %

### Zone Sizing Data:

Zone Airflow Sizing Method ..... Sum of space airflow rates  
Space Airflow Sizing Method ..... Individual peak space loads

Zone	Supply Airflow (CFM)	Zone Htg Unit (MBH)	Reheat Coil (MBH)	- (CFM)
1	2505.7	-	-	

## 5. Equipment Data

### Central Cooling Unit - Air-Cooled DX

Estimated Maximum Load ..... 58.8 MBH  
Design OAT ..... 95.0 °F  
Equipment Sizing ..... Auto-Sized  
Capacity Oversizing Factor ..... 0 %  
ARI Performance Rating ..... 11.000 EER  
DX System Configuration ..... 1-stage compression, 1 circuit  
Conventional Cutoff OAT ..... 55.0 °F  
Low Temperature Operation ..... Used  
Low Temperature Cutoff OAT ..... 0.0 °F

## AHU-2 CU-2 Input Data

Project Name: Dr Ukaegba Office  
Prepared by: FloridaEnergyCalcs.com

04/24/2022  
06:53PM

### 1. General Details:

Air System Name ..... AHU-2 CU-2  
Equipment Type ..... Split AHU  
Air System Type ..... Single Zone CAV  
Number of zones ..... 1

### 2. Ventilation System Components:

#### Ventilation Air Data:

Airflow Control ..... Constant Ventilation Airflow  
Ventilation Sizing Method ..... Sum of Space OA Airflows  
Unocc. Damper Position ..... Closed  
Damper Leak Rate ..... 0 %  
Outdoor Air CO2 Level ..... 400 ppm

#### Central Cooling Data:

Supply Air Temperature ..... 58.0 °F  
Coil Bypass Factor ..... 0.100  
Cooling Source ..... Air-Cooled DX  
Schedule ..... JFMAMJJASOND  
Capacity Control ..... Cycled or Staged Capacity - Fan On

#### Central Heating Data:

Supply Temperature ..... 95.0 °F  
Heating Source ..... Electric Resistance  
Schedule ..... JFMAMJJASOND  
Capacity Control ..... Cycled or Staged Capacity - Fan On

#### Supply Fan Data:

Fan Type ..... ASHRAE 90.1 App G Fan Curve  
Configuration ..... Draw-thru  
Fan Performance ..... ASHRAE Std 90.1-2010 Appendix G Fan kW  
ASHRAE Std 90.1-2010 Baseline Fan Adjustment Factor Components:  
None

Fan Control ..... 1-speed fan, cooling and heating

#### Duct System Data:

##### Supply Duct Data:

Duct Heat Gain ..... 0 %  
Duct Leakage ..... 0 %

##### Return Duct or Plenum Data:

Return Air Via ..... Ducted Return

### 3. Zone Components:

#### Space Assignments:

Zone 1: Backside	
15 Check In Office	x1
1 Exam Room	x1
2 Exam Room Corner	x1
3 Exam Room	x1
4 Exam Room	x1
5 Exam Room	x1
6 Exam Room	x1
7 Exam Room	x1
8 Exam Room	x1
9 Exam Room	x1
10 Exam Room	x1
11 Exam Room	x1
25 Hallways	x1

#### Thermostats and Zone Data:

Zone	Cooling T-Stat Occ. (°F)	Cooling T-Stat Unocc. (°F)	Heating T-Stat Occ. (°F)	Heating T-Stat Unocc. (°F)	T-Stat Throttling Range (°F)	Diversity Factor (%)	Direct Exhaust Airflow (CFM)	Direct Exhaust Fan (kW)
------	--------------------------------	----------------------------------	--------------------------------	----------------------------------	---------------------------------------	----------------------------	---------------------------------------	-------------------------------

## AHU-2 CU-2 Input Data

Project Name: Dr Ukaegba Office  
Prepared by: FloridaEnergyCalcs.com

04/24/2022  
06:53PM

1	72.0	72.0	68.0	68.0	1.00	100	0.0	0.0
---	------	------	------	------	------	-----	-----	-----

Thermostat Schedule ..... T-stat  
Unoccupied Cooling is ..... Available

### Supply Terminals Data:

Zone	Terminal Type	Air Distribution	Air Distribution Effectiveness Specification	Air Distribution Effectiveness	Minimum Airflow	Fan Performance	Fan Efficiency	Design Supply Temp.
1	Diffuser (no reheat)	Ceiling supply / ceiling return	Not Used	-	0.00 CFM/person	-	-	-

### Zone Heating Units:

Zone Unit Heat Source ..... Electric Resistance  
Zone Heating Unit Schedule ..... JFMAMJJASND

### 4. Sizing Data (Computer-Generated):

#### System Sizing Data:

##### Sizing Data:

Cooling Supply Temperature ..... 58.0 °F  
Supply Fan Airflow ..... 2435.0 CFM  
Ventilation Airflow ..... 195.9 CFM  
Heating Supply Temperature ..... 95.0 °F

##### Hydronic Sizing Specifications:

Chilled Water Delta-T ..... 10.0 °F  
Hot Water Delta-T ..... 20.0 °F

##### Safety Factors:

Cooling Sensible ..... 10 %  
Cooling Latent ..... 10 %  
Heating ..... 10 %

### Zone Sizing Data:

Zone Airflow Sizing Method ..... Sum of space airflow rates  
Space Airflow Sizing Method ..... Individual peak space loads

Zone	Supply Airflow (CFM)	Zone Htg Unit (MBH)	Reheat Coil (MBH)	- (CFM)
1	2435.0	-	-	

### 5. Equipment Data

#### Central Cooling Unit - Air-Cooled DX

Estimated Maximum Load ..... 58.3 MBH  
Design OAT ..... 95.0 °F  
Equipment Sizing ..... Auto-Sized  
Capacity Oversizing Factor ..... 0 %  
ARI Performance Rating ..... 11.000 EER  
DX System Configuration ..... 1-stage compression, 1 circuit  
Conventional Cutoff OAT ..... 55.0 °F  
Low Temperature Operation ..... Used  
Low Temperature Cutoff OAT ..... 0.0 °F

# Space Input Data

Dr Ukaegba Office  
FloridaEnergyCalcs.com

04/24/2022  
06:53PM

## 1 Exam Room

### 1. General Details:

Floor Area ..... 115.0 ft<sup>2</sup>  
Avg. Ceiling Height ..... 9.0 ft  
Building Weight ..... 70.0 lb/ft<sup>2</sup>

### 1.1. OA Ventilation Requirements:

Space Usage ..... User-Defined  
OA Requirement 1 ..... 5.0 CFM/person  
OA Requirement 2 ..... 0.06 CFM/ft<sup>2</sup>  
Space Usage Defaults .. ASHRAE Standard 62.1-2010

### 2. Internals:

#### 2.1. Overhead Lighting:

Fixture Type ..... Recessed (Unvented)  
Wattage ..... 0.80 W/ft<sup>2</sup>  
Ballast Multiplier ..... 1.00  
Schedule ..... Office Schedule

#### 2.4. People:

Occupancy ..... 1.5 People  
Activity Level ..... Office Work  
Sensible ..... 245.0 BTU/hr/person  
Latent ..... 205.0 BTU/hr/person  
Schedule ..... Office Schedule

#### 2.2. Task Lighting:

Wattage ..... 0.00 W/ft<sup>2</sup>  
Schedule ..... None

#### 2.5. Miscellaneous Loads:

Sensible ..... 0 BTU/hr  
Schedule ..... None  
Latent ..... 0 BTU/hr  
Schedule ..... None

#### 2.3. Electrical Equipment:

Wattage ..... 1.50 W/ft<sup>2</sup>  
Schedule ..... Office Schedule

### 3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft <sup>2</sup> )	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	100.0	1	0	0

#### 3.1. Construction Types for Exposure W

Wall Type ..... Stucco + Sheathing + R-11 Batt  
1st Window Type ..... 3x5 Window  
1st Window Shade Type ..... Reveal

### 4. Roofs, Skylights:

Exp.	Roof Gross Area (ft <sup>2</sup> )	Roof Slope (deg.)	Skylight Qty.
H	115.0	0	0

#### 4.1. Construction Types for Exposure H

Roof Type ..... Roof

### 5. Infiltration:

Design Cooling ..... 0.00 CFM  
Design Heating ..... 0.00 CFM  
Energy Analysis ..... 0.00 CFM  
Infiltration occurs only when the fan is off.

### 6. Floors:

Type ..... Slab Floor On Grade  
Floor Area ..... 115.0 ft<sup>2</sup>  
Total Floor U-Value ..... 0.100 BTU/(hr·ft<sup>2</sup>·°F)  
Exposed Perimeter ..... 0.0 ft  
Edge Insulation R-Value ..... 0.00 (hr·ft<sup>2</sup>·°F)/BTU

### 7. Partitions:

(No partition data).



# Space Input Data

Dr Ukaegba Office  
FloridaEnergyCalcs.com

04/24/2022  
06:53PM

## 10 Exam Room

### 1. General Details:

Floor Area ..... **105.0** ft<sup>2</sup>  
Avg. Ceiling Height ..... **9.0** ft  
Building Weight ..... **70.0** lb/ft<sup>2</sup>

### 1.1. OA Ventilation Requirements:

Space Usage ..... **User-Defined**  
OA Requirement 1 ..... **5.0** CFM/person  
OA Requirement 2 ..... **0.06** CFM/ft<sup>2</sup>  
Space Usage Defaults .. **ASHRAE Standard 62.1-2010**

### 2. Internals:

#### 2.1. Overhead Lighting:

Fixture Type ..... **Recessed (Unvented)**  
Wattage ..... **0.80** W/ft<sup>2</sup>  
Ballast Multiplier ..... **1.00**  
Schedule ..... **Office Schedule**

#### 2.4. People:

Occupancy ..... **1.5** People  
Activity Level ..... **Office Work**  
Sensible ..... **245.0** BTU/hr/person  
Latent ..... **205.0** BTU/hr/person  
Schedule ..... **Office Schedule**

#### 2.2. Task Lighting:

Wattage ..... **0.00** W/ft<sup>2</sup>  
Schedule ..... **None**

#### 2.5. Miscellaneous Loads:

Sensible ..... **0** BTU/hr  
Schedule ..... **None**  
Latent ..... **0** BTU/hr  
Schedule ..... **None**

#### 2.3. Electrical Equipment:

Wattage ..... **1.50** W/ft<sup>2</sup>  
Schedule ..... **Office Schedule**

### 3. Walls, Windows, Doors:

**(No Wall, Window, Door data).**

### 4. Roofs, Skylights:

Exp.	Roof Gross Area (ft <sup>2</sup> )	Roof Slope (deg.)	Skylight Qty.
H	105.0	0	0

#### 4.1. Construction Types for Exposure H

Roof Type ..... **Roof**

### 5. Infiltration:

Design Cooling ..... **0.00** CFM  
Design Heating ..... **0.00** CFM  
Energy Analysis ..... **0.00** CFM  
Infiltration occurs only when the fan is off.

### 6. Floors:

Type ..... **Slab Floor On Grade**  
Floor Area ..... **105.0** ft<sup>2</sup>  
Total Floor U-Value ..... **0.100** BTU/(hr·ft<sup>2</sup>·°F)  
Exposed Perimeter ..... **0.0** ft  
Edge Insulation R-Value ..... **0.00** (hr·ft<sup>2</sup>·°F)/BTU

### 7. Partitions:

**(No partition data).**

# Space Input Data

Dr Ukaegba Office  
FloridaEnergyCalcs.com

04/24/2022  
06:53PM

## 11 Exam Room

### 1. General Details:

Floor Area ..... **105.0** ft<sup>2</sup>  
Avg. Ceiling Height ..... **9.0** ft  
Building Weight ..... **70.0** lb/ft<sup>2</sup>

### 1.1. OA Ventilation Requirements:

Space Usage ..... **User-Defined**  
OA Requirement 1 ..... **5.0** CFM/person  
OA Requirement 2 ..... **0.06** CFM/ft<sup>2</sup>  
Space Usage Defaults .. **ASHRAE Standard 62.1-2010**

### 2. Internals:

#### 2.1. Overhead Lighting:

Fixture Type ..... **Recessed (Unvented)**  
Wattage ..... **0.80** W/ft<sup>2</sup>  
Ballast Multiplier ..... **1.00**  
Schedule ..... **Office Schedule**

#### 2.2. Task Lighting:

Wattage ..... **0.00** W/ft<sup>2</sup>  
Schedule ..... **None**

#### 2.3. Electrical Equipment:

Wattage ..... **1.50** W/ft<sup>2</sup>  
Schedule ..... **Office Schedule**

### 3. Walls, Windows, Doors:

**(No Wall, Window, Door data).**

### 4. Roofs, Skylights:

Exp.	Roof Gross Area (ft <sup>2</sup> )	Roof Slope (deg.)	Skylight Qty.
H	105.0	0	0

#### 4.1. Construction Types for Exposure H

Roof Type ..... **Roof**

### 5. Infiltration:

Design Cooling ..... **0.00** CFM  
Design Heating ..... **0.00** CFM  
Energy Analysis ..... **0.00** CFM

*Infiltration occurs only when the fan is off.*

### 6. Floors:

Type ..... **Slab Floor On Grade**  
Floor Area ..... **105.0** ft<sup>2</sup>  
Total Floor U-Value ..... **0.100** BTU/(hr·ft<sup>2</sup>·°F)  
Exposed Perimeter ..... **0.0** ft  
Edge Insulation R-Value ..... **0.00** (hr·ft<sup>2</sup>·°F)/BTU

### 7. Partitions:

**(No partition data).**

### 2.4. People:

Occupancy ..... **1.5** People  
Activity Level ..... **Office Work**  
Sensible ..... **245.0** BTU/hr/person  
Latent ..... **205.0** BTU/hr/person  
Schedule ..... **Office Schedule**

### 2.5. Miscellaneous Loads:

Sensible ..... **0** BTU/hr  
Schedule ..... **None**  
Latent ..... **0** BTU/hr  
Schedule ..... **None**

# Space Input Data

Dr Ukaegba Office  
FloridaEnergyCalcs.com

04/24/2022  
06:53PM

## 12 Exam Room

### 1. General Details:

Floor Area ..... **105.0** ft<sup>2</sup>  
Avg. Ceiling Height ..... **9.0** ft  
Building Weight ..... **70.0** lb/ft<sup>2</sup>

### 1.1. OA Ventilation Requirements:

Space Usage ..... **User-Defined**  
OA Requirement 1 ..... **5.0** CFM/person  
OA Requirement 2 ..... **0.06** CFM/ft<sup>2</sup>  
Space Usage Defaults .. **ASHRAE Standard 62.1-2010**

### 2. Internals:

#### 2.1. Overhead Lighting:

Fixture Type ..... **Recessed (Unvented)**  
Wattage ..... **0.80** W/ft<sup>2</sup>  
Ballast Multiplier ..... **1.00**  
Schedule ..... **Office Schedule**

#### 2.4. People:

Occupancy ..... **1.5** People  
Activity Level ..... **Office Work**  
Sensible ..... **245.0** BTU/hr/person  
Latent ..... **205.0** BTU/hr/person  
Schedule ..... **Office Schedule**

#### 2.2. Task Lighting:

Wattage ..... **0.00** W/ft<sup>2</sup>  
Schedule ..... **None**

#### 2.5. Miscellaneous Loads:

Sensible ..... **0** BTU/hr  
Schedule ..... **None**  
Latent ..... **0** BTU/hr  
Schedule ..... **None**

#### 2.3. Electrical Equipment:

Wattage ..... **0.15** W/ft<sup>2</sup>  
Schedule ..... **Office Schedule**

### 3. Walls, Windows, Doors:

**(No Wall, Window, Door data).**

### 4. Roofs, Skylights:

Exp.	Roof Gross Area (ft <sup>2</sup> )	Roof Slope (deg.)	Skylight Qty.
H	105.0	0	0

#### 4.1. Construction Types for Exposure H

Roof Type ..... **Roof**

### 5. Infiltration:

Design Cooling ..... **0.00** CFM  
Design Heating ..... **0.00** CFM  
Energy Analysis ..... **0.00** CFM  
*Infiltration occurs only when the fan is off.*

### 6. Floors:

Type ..... **Slab Floor On Grade**  
Floor Area ..... **105.0** ft<sup>2</sup>  
Total Floor U-Value ..... **0.100** BTU/(hr·ft<sup>2</sup>·°F)  
Exposed Perimeter ..... **0.0** ft  
Edge Insulation R-Value ..... **0.00** (hr·ft<sup>2</sup>·°F)/BTU

### 7. Partitions:

**(No partition data).**

## Space Input Data

Dr Ukaegba Office  
FloridaEnergyCalcs.com

04/24/2022  
06:53PM

### 13 Business Office

#### 1. General Details:

Floor Area ..... **275.0** ft<sup>2</sup>  
Avg. Ceiling Height ..... **9.0** ft  
Building Weight ..... **70.0** lb/ft<sup>2</sup>

#### 1.1. OA Ventilation Requirements:

Space Usage ..... **User-Defined**  
OA Requirement 1 ..... **5.0** CFM/person  
OA Requirement 2 ..... **0.06** CFM/ft<sup>2</sup>  
Space Usage Defaults .. **ASHRAE Standard 62.1-2010**

#### 2. Internals:

##### 2.1. Overhead Lighting:

Fixture Type ..... **Recessed (Unvented)**  
Wattage ..... **0.80** W/ft<sup>2</sup>  
Ballast Multiplier ..... **1.00**  
Schedule ..... **Office Schedule**

##### 2.4. People:

Occupancy ..... **5.0** People  
Activity Level ..... **Office Work**  
Sensible ..... **245.0** BTU/hr/person  
Latent ..... **205.0** BTU/hr/person  
Schedule ..... **Office Schedule**

##### 2.2. Task Lighting:

Wattage ..... **0.00** W/ft<sup>2</sup>  
Schedule ..... **None**

##### 2.5. Miscellaneous Loads:

Sensible ..... **0** BTU/hr  
Schedule ..... **None**  
Latent ..... **0** BTU/hr  
Schedule ..... **None**

#### 2.3. Electrical Equipment:

Wattage ..... **0.50** W/ft<sup>2</sup>  
Schedule ..... **Office Schedule**

#### 3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft <sup>2</sup> )	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
S	180.0	1	1	0

#### 3.1. Construction Types for Exposure S

Wall Type ..... **Stucco + Sheathing + R-11 Batt**  
1st Window Type ..... **3x5 Window**  
1st Window Shade Type ..... **Reveal**  
2nd Window Type ..... **Store Front**  
2nd Window Shade Type ..... **Reveal**

#### 4. Roofs, Skylights:

Exp.	Roof Gross Area (ft <sup>2</sup> )	Roof Slope (deg.)	Skylight Qty.
H	275.0	0	0

#### 4.1. Construction Types for Exposure H

Roof Type ..... **Roof**

#### 5. Infiltration:

Design Cooling ..... **0.00** CFM  
Design Heating ..... **0.00** CFM  
Energy Analysis ..... **0.00** CFM  
*Infiltration occurs only when the fan is off.*

#### 6. Floors:

Type ..... **Slab Floor On Grade**  
Floor Area ..... **275.0** ft<sup>2</sup>  
Total Floor U-Value ..... **0.100** BTU/(hr·ft<sup>2</sup>·°F)  
Exposed Perimeter ..... **0.0** ft  
Edge Insulation R-Value ..... **0.00** (hr·ft<sup>2</sup>·°F)/BTU

#### 7. Partitions:

**(No partition data).**

## Space Input Data

Dr Ukaegba Office  
FloridaEnergyCalcs.com

04/24/2022  
06:53PM

### 14 Waiting

#### 1. General Details:

Floor Area ..... **700.0** ft<sup>2</sup>  
Avg. Ceiling Height ..... **9.0** ft  
Building Weight ..... **70.0** lb/ft<sup>2</sup>

#### 1.1. OA Ventilation Requirements:

Space Usage ..... **User-Defined**  
OA Requirement 1 ..... **0.0** CFM  
OA Requirement 2 ..... **0.06** CFM/ft<sup>2</sup>  
Space Usage Defaults .. **ASHRAE Standard 62.1-2010**

#### 2. Internals:

##### 2.1. Overhead Lighting:

Fixture Type ..... **Recessed (Unvented)**  
Wattage ..... **0.80** W/ft<sup>2</sup>  
Ballast Multiplier ..... **1.00**  
Schedule ..... **Office Schedule**

##### 2.4. People:

Occupancy ..... **20.0** People  
Activity Level ..... **Office Work**  
Sensible ..... **245.0** BTU/hr/person  
Latent ..... **205.0** BTU/hr/person  
Schedule ..... **Office Schedule**

##### 2.2. Task Lighting:

Wattage ..... **0.00** W/ft<sup>2</sup>  
Schedule ..... **None**

##### 2.5. Miscellaneous Loads:

Sensible ..... **0** BTU/hr  
Schedule ..... **None**  
Latent ..... **0** BTU/hr  
Schedule ..... **None**

##### 2.3. Electrical Equipment:

Wattage ..... **0.00** W/ft<sup>2</sup>  
Schedule ..... **Office Schedule**

#### 3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft <sup>2</sup> )	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
S	320.0	3	1	0

#### 3.1. Construction Types for Exposure S

Wall Type ..... **Stucco + Sheathing + R-11 Batt**  
1st Window Type ..... **3x5 Window**  
1st Window Shade Type ..... **Reveal**  
2nd Window Type ..... **Store Front**  
2nd Window Shade Type ..... **Reveal**

#### 4. Roofs, Skylights:

Exp.	Roof Gross Area (ft <sup>2</sup> )	Roof Slope (deg.)	Skylight Qty.
H	700.0	0	0

#### 4.1. Construction Types for Exposure H

Roof Type ..... **Roof**

#### 5. Infiltration:

Design Cooling ..... **0.00** CFM  
Design Heating ..... **0.00** CFM  
Energy Analysis ..... **0.00** CFM  
*Infiltration occurs only when the fan is off.*

#### 6. Floors:

Type ..... **Slab Floor On Grade**  
Floor Area ..... **700.0** ft<sup>2</sup>  
Total Floor U-Value ..... **0.100** BTU/(hr·ft<sup>2</sup>·°F)  
Exposed Perimeter ..... **0.0** ft  
Edge Insulation R-Value ..... **0.00** (hr·ft<sup>2</sup>·°F)/BTU

#### 7. Partitions:

**(No partition data).**

## Space Input Data

Dr Ukaegba Office  
FloridaEnergyCalcs.com

04/24/2022  
06:53PM

### 15 Check In Office

#### 1. General Details:

Floor Area ..... **290.0** ft<sup>2</sup>  
Avg. Ceiling Height ..... **9.0** ft  
Building Weight ..... **70.0** lb/ft<sup>2</sup>

#### 1.1. OA Ventilation Requirements:

Space Usage ..... **User-Defined**  
OA Requirement 1 ..... **5.0** CFM/person  
OA Requirement 2 ..... **0.06** CFM/ft<sup>2</sup>  
Space Usage Defaults .. **ASHRAE Standard 62.1-2010**

#### 2. Internals:

##### 2.1. Overhead Lighting:

Fixture Type ..... **Recessed (Unvented)**  
Wattage ..... **0.80** W/ft<sup>2</sup>  
Ballast Multiplier ..... **1.00**  
Schedule ..... **Office Schedule**

##### 2.4. People:

Occupancy ..... **3.0** People  
Activity Level ..... **Office Work**  
Sensible ..... **245.0** BTU/hr/person  
Latent ..... **205.0** BTU/hr/person  
Schedule ..... **Office Schedule**

##### 2.2. Task Lighting:

Wattage ..... **0.00** W/ft<sup>2</sup>  
Schedule ..... **None**

##### 2.5. Miscellaneous Loads:

Sensible ..... **0** BTU/hr  
Schedule ..... **None**  
Latent ..... **0** BTU/hr  
Schedule ..... **None**

##### 2.3. Electrical Equipment:

Wattage ..... **3.00** W/ft<sup>2</sup>  
Schedule ..... **Office Schedule**

#### 3. Walls, Windows, Doors:

**(No Wall, Window, Door data).**

#### 4. Roofs, Skylights:

Exp.	Roof Gross Area (ft <sup>2</sup> )	Roof Slope (deg.)	Skylight Qty.
H	290.0	0	0

##### 4.1. Construction Types for Exposure H

Roof Type ..... **Roof**

#### 5. Infiltration:

Design Cooling ..... **0.00** CFM  
Design Heating ..... **0.00** CFM  
Energy Analysis ..... **0.00** CFM  
*Infiltration occurs only when the fan is off.*

#### 6. Floors:

Type ..... **Slab Floor On Grade**  
Floor Area ..... **290.0** ft<sup>2</sup>  
Total Floor U-Value ..... **0.100** BTU/(hr·ft<sup>2</sup>·°F)  
Exposed Perimeter ..... **0.0** ft  
Edge Insulation R-Value ..... **0.00** (hr·ft<sup>2</sup>·°F)/BTU

#### 7. Partitions:

**(No partition data).**

# Space Input Data

Dr Ukaegba Office  
FloridaEnergyCalcs.com

04/24/2022  
06:53PM

## 16 RR

### 1. General Details:

Floor Area ..... 60.0 ft<sup>2</sup>  
Avg. Ceiling Height ..... 9.0 ft  
Building Weight ..... 70.0 lb/ft<sup>2</sup>

### 1.1. OA Ventilation Requirements:

Space Usage ..... User-Defined  
OA Requirement 1 ..... 0.0 CFM  
OA Requirement 2 ..... 0.0 CFM  
Space Usage Defaults .. ASHRAE Standard 62.1-2010

### 2. Internals:

#### 2.1. Overhead Lighting:

Fixture Type ..... Recessed (Unvented)  
Wattage ..... 0.65 W/ft<sup>2</sup>  
Ballast Multiplier ..... 1.00  
Schedule ..... Office Schedule

#### 2.4. People:

Occupancy ..... 0.0 Person  
Activity Level ..... Office Work  
Sensible ..... 245.0 BTU/hr/person  
Latent ..... 205.0 BTU/hr/person  
Schedule ..... Office Schedule

#### 2.2. Task Lighting:

Wattage ..... 0.00 W/ft<sup>2</sup>  
Schedule ..... None

#### 2.5. Miscellaneous Loads:

Sensible ..... 0 BTU/hr  
Schedule ..... None  
Latent ..... 0 BTU/hr  
Schedule ..... None

#### 2.3. Electrical Equipment:

Wattage ..... 0.50 W/ft<sup>2</sup>  
Schedule ..... Office Schedule

### 3. Walls, Windows, Doors:

(No Wall, Window, Door data).

### 4. Roofs, Skylights:

Exp.	Roof Gross Area (ft <sup>2</sup> )	Roof Slope (deg.)	Skylight Qty.
H	60.0	0	0

#### 4.1. Construction Types for Exposure H

Roof Type ..... Roof

### 5. Infiltration:

Design Cooling ..... 0.00 CFM  
Design Heating ..... 0.00 CFM  
Energy Analysis ..... 0.00 CFM

Infiltration occurs only when the fan is off.

### 6. Floors:

Type ..... Slab Floor On Grade  
Floor Area ..... 60.0 ft<sup>2</sup>  
Total Floor U-Value ..... 0.100 BTU/(hr·ft<sup>2</sup>·°F)  
Exposed Perimeter ..... 0.0 ft  
Edge Insulation R-Value ..... 0.00 (hr·ft<sup>2</sup>·°F)/BTU

### 7. Partitions:

(No partition data).

# Space Input Data

Dr Ukaegba Office  
FloridaEnergyCalcs.com

04/24/2022  
06:53PM

## 17 Private RR

### 1. General Details:

Floor Area ..... 60.0 ft<sup>2</sup>  
Avg. Ceiling Height ..... 9.0 ft  
Building Weight ..... 70.0 lb/ft<sup>2</sup>

#### 1.1. OA Ventilation Requirements:

Space Usage ..... User-Defined  
OA Requirement 1 ..... 0.0 CFM  
OA Requirement 2 ..... 0.0 CFM  
Space Usage Defaults .. ASHRAE Standard 62.1-2010

### 2. Internals:

#### 2.1. Overhead Lighting:

Fixture Type ..... Recessed (Unvented)  
Wattage ..... 0.65 W/ft<sup>2</sup>  
Ballast Multiplier ..... 1.00  
Schedule ..... Office Schedule

#### 2.4. People:

Occupancy ..... 0.0 Person  
Activity Level ..... Office Work  
Sensible ..... 245.0 BTU/hr/person  
Latent ..... 205.0 BTU/hr/person  
Schedule ..... Office Schedule

#### 2.2. Task Lighting:

Wattage ..... 0.00 W/ft<sup>2</sup>  
Schedule ..... None

#### 2.5. Miscellaneous Loads:

Sensible ..... 0 BTU/hr  
Schedule ..... None  
Latent ..... 0 BTU/hr  
Schedule ..... None

#### 2.3. Electrical Equipment:

Wattage ..... 0.50 W/ft<sup>2</sup>  
Schedule ..... Office Schedule

### 3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft <sup>2</sup> )	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
S	60.0	0	0	0

#### 3.1. Construction Types for Exposure S

Wall Type ..... Stucco + Sheathing + R-11 Batt

### 4. Roofs, Skylights:

Exp.	Roof Gross Area (ft <sup>2</sup> )	Roof Slope (deg.)	Skylight Qty.
H	60.0	0	0

#### 4.1. Construction Types for Exposure H

Roof Type ..... Roof

### 5. Infiltration:

Design Cooling ..... 0.00 CFM  
Design Heating ..... 0.00 CFM  
Energy Analysis ..... 0.00 CFM  
Infiltration occurs only when the fan is off.

### 6. Floors:

Type ..... Slab Floor On Grade  
Floor Area ..... 60.0 ft<sup>2</sup>  
Total Floor U-Value ..... 0.100 BTU/(hr·ft<sup>2</sup>·°F)  
Exposed Perimeter ..... 0.0 ft  
Edge Insulation R-Value ..... 0.00 (hr·ft<sup>2</sup>·°F)/BTU

### 7. Partitions:

(No partition data).



# Space Input Data

Dr Ukaegba Office  
FloridaEnergyCalcs.com

04/24/2022  
06:53PM

## 18 Doctors Office

### 1. General Details:

Floor Area ..... **225.0** ft<sup>2</sup>  
Avg. Ceiling Height ..... **9.0** ft  
Building Weight ..... **70.0** lb/ft<sup>2</sup>

### 1.1. OA Ventilation Requirements:

Space Usage ..... **User-Defined**  
OA Requirement 1 ..... **5.0** CFM/person  
OA Requirement 2 ..... **0.06** CFM/ft<sup>2</sup>  
Space Usage Defaults .. **ASHRAE Standard 62.1-2010**

### 2. Internals:

#### 2.1. Overhead Lighting:

Fixture Type ..... **Recessed (Unvented)**  
Wattage ..... **0.80** W/ft<sup>2</sup>  
Ballast Multiplier ..... **1.00**  
Schedule ..... **Office Schedule**

#### 2.4. People:

Occupancy ..... **1.0** Person  
Activity Level ..... **Office Work**  
Sensible ..... **245.0** BTU/hr/person  
Latent ..... **205.0** BTU/hr/person  
Schedule ..... **Office Schedule**

#### 2.2. Task Lighting:

Wattage ..... **0.00** W/ft<sup>2</sup>  
Schedule ..... **None**

#### 2.5. Miscellaneous Loads:

Sensible ..... **0** BTU/hr  
Schedule ..... **None**  
Latent ..... **0** BTU/hr  
Schedule ..... **None**

#### 2.3. Electrical Equipment:

Wattage ..... **0.50** W/ft<sup>2</sup>  
Schedule ..... **Office Schedule**

### 3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft <sup>2</sup> )	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
S	135.0	1	0	0

#### 3.1. Construction Types for Exposure S

Wall Type ..... **Stucco + Sheathing + R-11 Batt**  
1st Window Type ..... **3x5 Window**  
1st Window Shade Type ..... **Reveal**

### 4. Roofs, Skylights:

Exp.	Roof Gross Area (ft <sup>2</sup> )	Roof Slope (deg.)	Skylight Qty.
H	225.0	0	0

#### 4.1. Construction Types for Exposure H

Roof Type ..... **Roof**

### 5. Infiltration:

Design Cooling ..... **0.00** CFM  
Design Heating ..... **0.00** CFM  
Energy Analysis ..... **0.00** CFM  
Infiltration occurs only when the fan is off.

### 6. Floors:

Type ..... **Slab Floor On Grade**  
Floor Area ..... **225.0** ft<sup>2</sup>  
Total Floor U-Value ..... **0.100** BTU/(hr·ft<sup>2</sup>·°F)  
Exposed Perimeter ..... **0.0** ft  
Edge Insulation R-Value ..... **0.00** (hr·ft<sup>2</sup>·°F)/BTU

### 7. Partitions:

(No partition data).

# Space Input Data

Dr Ukaegba Office  
FloridaEnergyCalcs.com

04/24/2022  
06:53PM

## 19 RR

### 1. General Details:

Floor Area ..... 60.0 ft<sup>2</sup>  
Avg. Ceiling Height ..... 9.0 ft  
Building Weight ..... 70.0 lb/ft<sup>2</sup>

### 1.1. OA Ventilation Requirements:

Space Usage ..... User-Defined  
OA Requirement 1 ..... 0.0 CFM  
OA Requirement 2 ..... 0.0 CFM  
Space Usage Defaults .. ASHRAE Standard 62.1-2010

### 2. Internals:

#### 2.1. Overhead Lighting:

Fixture Type ..... Recessed (Unvented)  
Wattage ..... 0.65 W/ft<sup>2</sup>  
Ballast Multiplier ..... 1.00  
Schedule ..... Office Schedule

#### 2.4. People:

Occupancy ..... 0.0 Person  
Activity Level ..... Office Work  
Sensible ..... 245.0 BTU/hr/person  
Latent ..... 205.0 BTU/hr/person  
Schedule ..... Office Schedule

#### 2.2. Task Lighting:

Wattage ..... 0.00 W/ft<sup>2</sup>  
Schedule ..... None

#### 2.5. Miscellaneous Loads:

Sensible ..... 0 BTU/hr  
Schedule ..... None  
Latent ..... 0 BTU/hr  
Schedule ..... None

#### 2.3. Electrical Equipment:

Wattage ..... 0.50 W/ft<sup>2</sup>  
Schedule ..... Office Schedule

### 3. Walls, Windows, Doors:

(No Wall, Window, Door data).

### 4. Roofs, Skylights:

Exp.	Roof Gross Area (ft <sup>2</sup> )	Roof Slope (deg.)	Skylight Qty.
H	60.0	0	0

#### 4.1. Construction Types for Exposure H

Roof Type ..... Roof

### 5. Infiltration:

Design Cooling ..... 0.00 CFM  
Design Heating ..... 0.00 CFM  
Energy Analysis ..... 0.00 CFM

Infiltration occurs only when the fan is off.

### 6. Floors:

Type ..... Slab Floor On Grade  
Floor Area ..... 60.0 ft<sup>2</sup>  
Total Floor U-Value ..... 0.100 BTU/(hr·ft<sup>2</sup>·°F)  
Exposed Perimeter ..... 0.0 ft  
Edge Insulation R-Value ..... 0.00 (hr·ft<sup>2</sup>·°F)/BTU

### 7. Partitions:

(No partition data).

## Space Input Data

Dr Ukaegba Office  
FloridaEnergyCalcs.com

04/24/2022  
06:53PM

### 2 Exam Room Corner

#### 1. General Details:

Floor Area ..... **125.0** ft<sup>2</sup>  
Avg. Ceiling Height ..... **9.0** ft  
Building Weight ..... **70.0** lb/ft<sup>2</sup>

#### 1.1. OA Ventilation Requirements:

Space Usage ..... **User-Defined**  
OA Requirement 1 ..... **5.0** CFM/person  
OA Requirement 2 ..... **0.06** CFM/ft<sup>2</sup>  
Space Usage Defaults .. **ASHRAE Standard 62.1-2010**

#### 2. Internals:

##### 2.1. Overhead Lighting:

Fixture Type ..... **Recessed (Unvented)**  
Wattage ..... **0.80** W/ft<sup>2</sup>  
Ballast Multiplier ..... **1.00**  
Schedule ..... **Office Schedule**

##### 2.4. People:

Occupancy ..... **1.5** People  
Activity Level ..... **Office Work**  
Sensible ..... **245.0** BTU/hr/person  
Latent ..... **205.0** BTU/hr/person  
Schedule ..... **Office Schedule**

##### 2.2. Task Lighting:

Wattage ..... **0.00** W/ft<sup>2</sup>  
Schedule ..... **None**

##### 2.5. Miscellaneous Loads:

Sensible ..... **0** BTU/hr  
Schedule ..... **None**  
Latent ..... **0** BTU/hr  
Schedule ..... **None**

##### 2.3. Electrical Equipment:

Wattage ..... **1.50** W/ft<sup>2</sup>  
Schedule ..... **Office Schedule**

#### 3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft <sup>2</sup> )	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	140.0	0	0	0
N	100.0	1	0	0

##### 3.1. Construction Types for Exposure W

Wall Type ..... **Stucco + Sheathing + R-11 Batt**

##### 3.2. Construction Types for Exposure N

Wall Type ..... **Stucco + Sheathing + R-11 Batt**  
1st Window Type ..... **3x5 Window**  
1st Window Shade Type ..... **Reveal**

#### 4. Roofs, Skylights:

Exp.	Roof Gross Area (ft <sup>2</sup> )	Roof Slope (deg.)	Skylight Qty.
H	115.0	0	0

##### 4.1. Construction Types for Exposure H

Roof Type ..... **Roof**

#### 5. Infiltration:

Design Cooling ..... **0.00** CFM  
Design Heating ..... **0.00** CFM  
Energy Analysis ..... **0.00** CFM  
*Infiltration occurs only when the fan is off.*

#### 6. Floors:

Type ..... **Slab Floor On Grade**  
Floor Area ..... **115.0** ft<sup>2</sup>  
Total Floor U-Value ..... **0.100** BTU/(hr·ft<sup>2</sup>·°F)  
Exposed Perimeter ..... **0.0** ft  
Edge Insulation R-Value ..... **0.00** (hr·ft<sup>2</sup>·°F)/BTU

#### 7. Partitions:

**(No partition data).**

## Space Input Data

Dr Ukaegba Office  
FloridaEnergyCalcs.com

04/24/2022  
06:53PM

### 20 Nurse Station

#### 1. General Details:

Floor Area ..... **115.0** ft<sup>2</sup>  
Avg. Ceiling Height ..... **9.0** ft  
Building Weight ..... **70.0** lb/ft<sup>2</sup>

#### 1.1. OA Ventilation Requirements:

Space Usage ..... **User-Defined**  
OA Requirement 1 ..... **5.0** CFM/person  
OA Requirement 2 ..... **0.06** CFM/ft<sup>2</sup>  
Space Usage Defaults .. **ASHRAE Standard 62.1-2010**

#### 2. Internals:

##### 2.1. Overhead Lighting:

Fixture Type ..... **Recessed (Unvented)**  
Wattage ..... **0.80** W/ft<sup>2</sup>  
Ballast Multiplier ..... **1.00**  
Schedule ..... **Office Schedule**

##### 2.4. People:

Occupancy ..... **3.0** People  
Activity Level ..... **Office Work**  
Sensible ..... **245.0** BTU/hr/person  
Latent ..... **205.0** BTU/hr/person  
Schedule ..... **Office Schedule**

##### 2.2. Task Lighting:

Wattage ..... **0.00** W/ft<sup>2</sup>  
Schedule ..... **None**

##### 2.5. Miscellaneous Loads:

Sensible ..... **0** BTU/hr  
Schedule ..... **None**  
Latent ..... **0** BTU/hr  
Schedule ..... **None**

##### 2.3. Electrical Equipment:

Wattage ..... **0.50** W/ft<sup>2</sup>  
Schedule ..... **Office Schedule**

#### 3. Walls, Windows, Doors:

**(No Wall, Window, Door data).**

#### 4. Roofs, Skylights:

Exp.	Roof Gross Area (ft <sup>2</sup> )	Roof Slope (deg.)	Skylight Qty.
H	115.0	0	0

##### 4.1. Construction Types for Exposure H

Roof Type ..... **Roof**

#### 5. Infiltration:

Design Cooling ..... **0.00** CFM  
Design Heating ..... **0.00** CFM  
Energy Analysis ..... **0.00** CFM

*Infiltration occurs only when the fan is off.*

#### 6. Floors:

Type ..... **Slab Floor On Grade**  
Floor Area ..... **115.0** ft<sup>2</sup>  
Total Floor U-Value ..... **0.100** BTU/(hr·ft<sup>2</sup>·°F)  
Exposed Perimeter ..... **0.0** ft  
Edge Insulation R-Value ..... **0.00** (hr·ft<sup>2</sup>·°F)/BTU

#### 7. Partitions:

**(No partition data).**

## Space Input Data

Dr Ukaegba Office  
FloridaEnergyCalcs.com

04/24/2022  
06:53PM

### 21 Breakroom

#### 1. General Details:

Floor Area ..... **160.0** ft<sup>2</sup>  
Avg. Ceiling Height ..... **9.0** ft  
Building Weight ..... **70.0** lb/ft<sup>2</sup>

#### 1.1. OA Ventilation Requirements:

Space Usage ..... **User-Defined**  
OA Requirement 1 ..... **5.0** CFM/person  
OA Requirement 2 ..... **0.06** CFM/ft<sup>2</sup>  
Space Usage Defaults .. **ASHRAE Standard 62.1-2010**

#### 2. Internals:

##### 2.1. Overhead Lighting:

Fixture Type ..... **Recessed (Unvented)**  
Wattage ..... **0.80** W/ft<sup>2</sup>  
Ballast Multiplier ..... **1.00**  
Schedule ..... **Office Schedule**

##### 2.4. People:

Occupancy ..... **1.0** Person  
Activity Level ..... **Office Work**  
Sensible ..... **245.0** BTU/hr/person  
Latent ..... **205.0** BTU/hr/person  
Schedule ..... **Office Schedule**

##### 2.2. Task Lighting:

Wattage ..... **0.00** W/ft<sup>2</sup>  
Schedule ..... **None**

##### 2.5. Miscellaneous Loads:

Sensible ..... **0** BTU/hr  
Schedule ..... **None**  
Latent ..... **0** BTU/hr  
Schedule ..... **None**

##### 2.3. Electrical Equipment:

Wattage ..... **0.50** W/ft<sup>2</sup>  
Schedule ..... **Office Schedule**

#### 3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft <sup>2</sup> )	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
S	85.0	1	0	0

##### 3.1. Construction Types for Exposure S

Wall Type ..... **Stucco + Sheathing + R-11 Batt**  
1st Window Type ..... **3x5 Window**  
1st Window Shade Type ..... **Reveal**

#### 4. Roofs, Skylights:

Exp.	Roof Gross Area (ft <sup>2</sup> )	Roof Slope (deg.)	Skylight Qty.
H	225.0	0	0

##### 4.1. Construction Types for Exposure H

Roof Type ..... **Roof**

#### 5. Infiltration:

Design Cooling ..... **0.00** CFM  
Design Heating ..... **0.00** CFM  
Energy Analysis ..... **0.00** CFM  
*Infiltration occurs only when the fan is off.*

#### 6. Floors:

Type ..... **Slab Floor On Grade**  
Floor Area ..... **160.0** ft<sup>2</sup>  
Total Floor U-Value ..... **0.100** BTU/(hr·ft<sup>2</sup>·°F)  
Exposed Perimeter ..... **0.0** ft  
Edge Insulation R-Value ..... **0.00** (hr·ft<sup>2</sup>·°F)/BTU

#### 7. Partitions:

**(No partition data).**

## Space Input Data

Dr Ukaegba Office  
FloridaEnergyCalcs.com

04/24/2022  
06:53PM

### 22 Staff RR

#### 1. General Details:

Floor Area ..... 70.0 ft<sup>2</sup>  
Avg. Ceiling Height ..... 9.0 ft  
Building Weight ..... 70.0 lb/ft<sup>2</sup>

#### 1.1. OA Ventilation Requirements:

Space Usage ..... User-Defined  
OA Requirement 1 ..... 0.0 CFM  
OA Requirement 2 ..... 0.0 CFM  
Space Usage Defaults .. ASHRAE Standard 62.1-2010

#### 2. Internals:

##### 2.1. Overhead Lighting:

Fixture Type ..... Recessed (Unvented)  
Wattage ..... 0.65 W/ft<sup>2</sup>  
Ballast Multiplier ..... 1.00  
Schedule ..... Office Schedule

##### 2.2. Task Lighting:

Wattage ..... 0.00 W/ft<sup>2</sup>  
Schedule ..... None

##### 2.3. Electrical Equipment:

Wattage ..... 0.50 W/ft<sup>2</sup>  
Schedule ..... Office Schedule

#### 3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft <sup>2</sup> )	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
S	120.0	0	0	0
W	60.0	0	0	0

##### 3.1. Construction Types for Exposure S

Wall Type ..... Stucco + Sheathing + R-11 Batt

##### 3.2. Construction Types for Exposure W

Wall Type ..... Stucco + Sheathing + R-11 Batt

#### 4. Roofs, Skylights:

Exp.	Roof Gross Area (ft <sup>2</sup> )	Roof Slope (deg.)	Skylight Qty.
H	70.0	0	0

##### 4.1. Construction Types for Exposure H

Roof Type ..... Roof

#### 5. Infiltration:

Design Cooling ..... 0.00 CFM  
Design Heating ..... 0.00 CFM  
Energy Analysis ..... 0.00 CFM  
Infiltration occurs only when the fan is off.

#### 6. Floors:

Type ..... Slab Floor On Grade  
Floor Area ..... 70.0 ft<sup>2</sup>  
Total Floor U-Value ..... 0.100 BTU/(hr·ft<sup>2</sup>·°F)  
Exposed Perimeter ..... 0.0 ft  
Edge Insulation R-Value ..... 0.00 (hr·ft<sup>2</sup>·°F)/BTU

#### 7. Partitions:

(No partition data).

##### 2.4. People:

Occupancy ..... 0.0 Person  
Activity Level ..... Office Work  
Sensible ..... 245.0 BTU/hr/person  
Latent ..... 205.0 BTU/hr/person  
Schedule ..... Office Schedule

##### 2.5. Miscellaneous Loads:

Sensible ..... 0 BTU/hr  
Schedule ..... None  
Latent ..... 0 BTU/hr  
Schedule ..... None

## Space Input Data

Dr Ukaegba Office  
FloridaEnergyCalcs.com

04/24/2022  
06:53PM

### 23 Procedure

#### 1. General Details:

Floor Area ..... **200.0** ft<sup>2</sup>  
Avg. Ceiling Height ..... **9.0** ft  
Building Weight ..... **70.0** lb/ft<sup>2</sup>

#### 1.1. OA Ventilation Requirements:

Space Usage ..... **User-Defined**  
OA Requirement 1 ..... **5.0** CFM/person  
OA Requirement 2 ..... **0.06** CFM/ft<sup>2</sup>  
Space Usage Defaults .. **ASHRAE Standard 62.1-2010**

#### 2. Internals:

##### 2.1. Overhead Lighting:

Fixture Type ..... **Recessed (Unvented)**  
Wattage ..... **0.80** W/ft<sup>2</sup>  
Ballast Multiplier ..... **1.00**  
Schedule ..... **Office Schedule**

##### 2.4. People:

Occupancy ..... **6.0** People  
Activity Level ..... **Office Work**  
Sensible ..... **245.0** BTU/hr/person  
Latent ..... **205.0** BTU/hr/person  
Schedule ..... **Office Schedule**

##### 2.2. Task Lighting:

Wattage ..... **0.00** W/ft<sup>2</sup>  
Schedule ..... **None**

##### 2.5. Miscellaneous Loads:

Sensible ..... **0** BTU/hr  
Schedule ..... **None**  
Latent ..... **0** BTU/hr  
Schedule ..... **None**

##### 2.3. Electrical Equipment:

Wattage ..... **0.15** W/ft<sup>2</sup>  
Schedule ..... **Office Schedule**

#### 3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft <sup>2</sup> )	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	150.0	0	0	0

##### 3.1. Construction Types for Exposure W

Wall Type ..... **Stucco + Sheathing + R-11 Batt**

#### 4. Roofs, Skylights:

Exp.	Roof Gross Area (ft <sup>2</sup> )	Roof Slope (deg.)	Skylight Qty.
H	200.0	0	0

##### 4.1. Construction Types for Exposure H

Roof Type ..... **Roof**

#### 5. Infiltration:

Design Cooling ..... **0.00** CFM  
Design Heating ..... **0.00** CFM  
Energy Analysis ..... **0.00** CFM  
*Infiltration occurs only when the fan is off.*

#### 6. Floors:

Type ..... **Slab Floor On Grade**  
Floor Area ..... **200.0** ft<sup>2</sup>  
Total Floor U-Value ..... **0.100** BTU/(hr·ft<sup>2</sup>·°F)  
Exposed Perimeter ..... **0.0** ft  
Edge Insulation R-Value ..... **0.00** (hr·ft<sup>2</sup>·°F)/BTU

#### 7. Partitions:

**(No partition data).**

## Space Input Data

Dr Ukaegba Office  
FloridaEnergyCalcs.com

04/24/2022  
06:53PM

### 24 AHU Closet

#### 1. General Details:

Floor Area ..... **40.0** ft<sup>2</sup>  
Avg. Ceiling Height ..... **9.0** ft  
Building Weight ..... **70.0** lb/ft<sup>2</sup>

#### 1.1. OA Ventilation Requirements:

Space Usage ..... **User-Defined**  
OA Requirement 1 ..... **0.0** CFM  
OA Requirement 2 ..... **0.0** CFM  
Space Usage Defaults .. **ASHRAE Standard 62.1-2010**

#### 2. Internals:

##### 2.1. Overhead Lighting:

Fixture Type ..... **Recessed (Unvented)**  
Wattage ..... **0.65** W/ft<sup>2</sup>  
Ballast Multiplier ..... **1.00**  
Schedule ..... **Office Schedule**

##### 2.2. Task Lighting:

Wattage ..... **0.00** W/ft<sup>2</sup>  
Schedule ..... **None**

##### 2.3. Electrical Equipment:

Wattage ..... **0.00** W/ft<sup>2</sup>  
Schedule ..... **Office Schedule**

#### 3. Walls, Windows, Doors:

**(No Wall, Window, Door data).**

#### 4. Roofs, Skylights:

Exp.	Roof Gross Area (ft <sup>2</sup> )	Roof Slope (deg.)	Skylight Qty.
H	40.0	0	0

##### 4.1. Construction Types for Exposure H

Roof Type ..... **Roof**

#### 5. Infiltration:

Design Cooling ..... **0.00** CFM  
Design Heating ..... **0.00** CFM  
Energy Analysis ..... **0.00** CFM

*Infiltration occurs only when the fan is off.*

#### 6. Floors:

Type ..... **Slab Floor On Grade**  
Floor Area ..... **40.0** ft<sup>2</sup>  
Total Floor U-Value ..... **0.100** BTU/(hr·ft<sup>2</sup>·°F)  
Exposed Perimeter ..... **0.0** ft  
Edge Insulation R-Value ..... **0.00** (hr·ft<sup>2</sup>·°F)/BTU

#### 7. Partitions:

**(No partition data).**

##### 2.4. People:

Occupancy ..... **0.0** Person  
Activity Level ..... **Office Work**  
Sensible ..... **245.0** BTU/hr/person  
Latent ..... **205.0** BTU/hr/person  
Schedule ..... **Office Schedule**

##### 2.5. Miscellaneous Loads:

Sensible ..... **0** BTU/hr  
Schedule ..... **None**  
Latent ..... **0** BTU/hr  
Schedule ..... **None**



## Space Input Data

Dr Ukaegba Office  
FloridaEnergyCalcs.com

04/24/2022  
06:53PM

### 25 Hallways

#### 1. General Details:

Floor Area ..... **790.0** ft<sup>2</sup>  
Avg. Ceiling Height ..... **9.0** ft  
Building Weight ..... **70.0** lb/ft<sup>2</sup>

#### 1.1. OA Ventilation Requirements:

Space Usage ..... **User-Defined**  
OA Requirement 1 ..... **0.0** CFM  
OA Requirement 2 ..... **0.0** CFM  
Space Usage Defaults .. **ASHRAE Standard 62.1-2010**

#### 2. Internals:

##### 2.1. Overhead Lighting:

Fixture Type ..... **Recessed (Unvented)**  
Wattage ..... **0.65** W/ft<sup>2</sup>  
Ballast Multiplier ..... **1.00**  
Schedule ..... **Office Schedule**

##### 2.4. People:

Occupancy ..... **2.0** People  
Activity Level ..... **Office Work**  
Sensible ..... **245.0** BTU/hr/person  
Latent ..... **205.0** BTU/hr/person  
Schedule ..... **Office Schedule**

##### 2.2. Task Lighting:

Wattage ..... **0.00** W/ft<sup>2</sup>  
Schedule ..... **None**

##### 2.5. Miscellaneous Loads:

Sensible ..... **0** BTU/hr  
Schedule ..... **None**  
Latent ..... **0** BTU/hr  
Schedule ..... **None**

##### 2.3. Electrical Equipment:

Wattage ..... **0.00** W/ft<sup>2</sup>  
Schedule ..... **Office Schedule**

#### 3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft <sup>2</sup> )	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
E	50.0	0	0	1
N	50.0	0	0	1

##### 3.1. Construction Types for Exposure E

Wall Type ..... **Stucco + Sheathing + R-11 Batt**  
Door Type ..... **Metal Door**

##### 3.2. Construction Types for Exposure N

Wall Type ..... **Stucco + Sheathing + R-11 Batt**  
Door Type ..... **Metal Door**

#### 4. Roofs, Skylights:

Exp.	Roof Gross Area (ft <sup>2</sup> )	Roof Slope (deg.)	Skylight Qty.
H	790.0	0	0

##### 4.1. Construction Types for Exposure H

Roof Type ..... **Roof**

#### 5. Infiltration:

Design Cooling ..... **0.00** CFM  
Design Heating ..... **0.00** CFM  
Energy Analysis ..... **0.00** CFM  
*Infiltration occurs only when the fan is off.*

#### 6. Floors:

Type ..... **Slab Floor On Grade**  
Floor Area ..... **790.0** ft<sup>2</sup>  
Total Floor U-Value ..... **0.100** BTU/(hr·ft<sup>2</sup>·°F)  
Exposed Perimeter ..... **0.0** ft  
Edge Insulation R-Value ..... **0.00** (hr·ft<sup>2</sup>·°F)/BTU

#### 7. Partitions:

**(No partition data).**

## Space Input Data

Dr Ukaegba Office  
FloridaEnergyCalcs.com

04/24/2022  
06:53PM

### 3 Exam Room

#### 1. General Details:

Floor Area ..... **105.0** ft<sup>2</sup>  
Avg. Ceiling Height ..... **9.0** ft  
Building Weight ..... **70.0** lb/ft<sup>2</sup>

#### 1.1. OA Ventilation Requirements:

Space Usage ..... **User-Defined**  
OA Requirement 1 ..... **5.0** CFM/person  
OA Requirement 2 ..... **0.06** CFM/ft<sup>2</sup>  
Space Usage Defaults .. **ASHRAE Standard 62.1-2010**

#### 2. Internals:

##### 2.1. Overhead Lighting:

Fixture Type ..... **Recessed (Unvented)**  
Wattage ..... **0.80** W/ft<sup>2</sup>  
Ballast Multiplier ..... **1.00**  
Schedule ..... **Office Schedule**

##### 2.4. People:

Occupancy ..... **1.5** People  
Activity Level ..... **Office Work**  
Sensible ..... **245.0** BTU/hr/person  
Latent ..... **205.0** BTU/hr/person  
Schedule ..... **Office Schedule**

##### 2.2. Task Lighting:

Wattage ..... **0.00** W/ft<sup>2</sup>  
Schedule ..... **None**

##### 2.5. Miscellaneous Loads:

Sensible ..... **0** BTU/hr  
Schedule ..... **None**  
Latent ..... **0** BTU/hr  
Schedule ..... **None**

##### 2.3. Electrical Equipment:

Wattage ..... **1.50** W/ft<sup>2</sup>  
Schedule ..... **Office Schedule**

#### 3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft <sup>2</sup> )	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
N	90.0	1	0	0

##### 3.1. Construction Types for Exposure N

Wall Type ..... **Stucco + Sheathing + R-11 Batt**  
1st Window Type ..... **3x5 Window**  
1st Window Shade Type ..... **Reveal**

#### 4. Roofs, Skylights:

Exp.	Roof Gross Area (ft <sup>2</sup> )	Roof Slope (deg.)	Skylight Qty.
H	105.0	0	0

##### 4.1. Construction Types for Exposure H

Roof Type ..... **Roof**

#### 5. Infiltration:

Design Cooling ..... **0.00** CFM  
Design Heating ..... **0.00** CFM  
Energy Analysis ..... **0.00** CFM  
*Infiltration occurs only when the fan is off.*

#### 6. Floors:

Type ..... **Slab Floor On Grade**  
Floor Area ..... **105.0** ft<sup>2</sup>  
Total Floor U-Value ..... **0.100** BTU/(hr·ft<sup>2</sup>·°F)  
Exposed Perimeter ..... **0.0** ft  
Edge Insulation R-Value ..... **0.00** (hr·ft<sup>2</sup>·°F)/BTU

#### 7. Partitions:

**(No partition data).**

## Space Input Data

Dr Ukaegba Office  
FloridaEnergyCalcs.com

04/24/2022  
06:53PM

### 4 Exam Room

#### 1. General Details:

Floor Area ..... **120.0** ft<sup>2</sup>  
Avg. Ceiling Height ..... **9.0** ft  
Building Weight ..... **70.0** lb/ft<sup>2</sup>

#### 1.1. OA Ventilation Requirements:

Space Usage ..... **User-Defined**  
OA Requirement 1 ..... **5.0** CFM/person  
OA Requirement 2 ..... **0.06** CFM/ft<sup>2</sup>  
Space Usage Defaults .. **ASHRAE Standard 62.1-2010**

#### 2. Internals:

##### 2.1. Overhead Lighting:

Fixture Type ..... **Recessed (Unvented)**  
Wattage ..... **0.80** W/ft<sup>2</sup>  
Ballast Multiplier ..... **1.00**  
Schedule ..... **Office Schedule**

##### 2.4. People:

Occupancy ..... **1.5** People  
Activity Level ..... **Office Work**  
Sensible ..... **245.0** BTU/hr/person  
Latent ..... **205.0** BTU/hr/person  
Schedule ..... **Office Schedule**

##### 2.2. Task Lighting:

Wattage ..... **0.00** W/ft<sup>2</sup>  
Schedule ..... **None**

##### 2.5. Miscellaneous Loads:

Sensible ..... **0** BTU/hr  
Schedule ..... **None**  
Latent ..... **0** BTU/hr  
Schedule ..... **None**

##### 2.3. Electrical Equipment:

Wattage ..... **1.50** W/ft<sup>2</sup>  
Schedule ..... **Office Schedule**

#### 3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft <sup>2</sup> )	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
N	90.0	1	0	0

##### 3.1. Construction Types for Exposure N

Wall Type ..... **Stucco + Sheathing + R-11 Batt**  
1st Window Type ..... **3x5 Window**  
1st Window Shade Type ..... **Reveal**

#### 4. Roofs, Skylights:

Exp.	Roof Gross Area (ft <sup>2</sup> )	Roof Slope (deg.)	Skylight Qty.
H	120.0	0	0

##### 4.1. Construction Types for Exposure H

Roof Type ..... **Roof**

#### 5. Infiltration:

Design Cooling ..... **0.00** CFM  
Design Heating ..... **0.00** CFM  
Energy Analysis ..... **0.00** CFM  
*Infiltration occurs only when the fan is off.*

#### 6. Floors:

Type ..... **Slab Floor On Grade**  
Floor Area ..... **120.0** ft<sup>2</sup>  
Total Floor U-Value ..... **0.100** BTU/(hr·ft<sup>2</sup>·°F)  
Exposed Perimeter ..... **0.0** ft  
Edge Insulation R-Value ..... **0.00** (hr·ft<sup>2</sup>·°F)/BTU

#### 7. Partitions:

**(No partition data).**

## Space Input Data

Dr Ukaegba Office  
FloridaEnergyCalcs.com

04/24/2022  
06:53PM

### 5 Exam Room

#### 1. General Details:

Floor Area ..... **120.0** ft<sup>2</sup>  
Avg. Ceiling Height ..... **9.0** ft  
Building Weight ..... **70.0** lb/ft<sup>2</sup>

#### 1.1. OA Ventilation Requirements:

Space Usage ..... **User-Defined**  
OA Requirement 1 ..... **5.0** CFM/person  
OA Requirement 2 ..... **0.06** CFM/ft<sup>2</sup>  
Space Usage Defaults .. **ASHRAE Standard 62.1-2010**

#### 2. Internals:

##### 2.1. Overhead Lighting:

Fixture Type ..... **Recessed (Unvented)**  
Wattage ..... **0.80** W/ft<sup>2</sup>  
Ballast Multiplier ..... **1.00**  
Schedule ..... **Office Schedule**

##### 2.4. People:

Occupancy ..... **1.5** People  
Activity Level ..... **Office Work**  
Sensible ..... **245.0** BTU/hr/person  
Latent ..... **205.0** BTU/hr/person  
Schedule ..... **Office Schedule**

##### 2.2. Task Lighting:

Wattage ..... **0.00** W/ft<sup>2</sup>  
Schedule ..... **None**

##### 2.5. Miscellaneous Loads:

Sensible ..... **0** BTU/hr  
Schedule ..... **None**  
Latent ..... **0** BTU/hr  
Schedule ..... **None**

##### 2.3. Electrical Equipment:

Wattage ..... **1.50** W/ft<sup>2</sup>  
Schedule ..... **Office Schedule**

#### 3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft <sup>2</sup> )	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
N	90.0	1	0	0

##### 3.1. Construction Types for Exposure N

Wall Type ..... **Stucco + Sheathing + R-11 Batt**  
1st Window Type ..... **3x5 Window**  
1st Window Shade Type ..... **Reveal**

#### 4. Roofs, Skylights:

Exp.	Roof Gross Area (ft <sup>2</sup> )	Roof Slope (deg.)	Skylight Qty.
H	120.0	0	0

##### 4.1. Construction Types for Exposure H

Roof Type ..... **Roof**

#### 5. Infiltration:

Design Cooling ..... **0.00** CFM  
Design Heating ..... **0.00** CFM  
Energy Analysis ..... **0.00** CFM  
*Infiltration occurs only when the fan is off.*

#### 6. Floors:

Type ..... **Slab Floor On Grade**  
Floor Area ..... **120.0** ft<sup>2</sup>  
Total Floor U-Value ..... **0.100** BTU/(hr·ft<sup>2</sup>·°F)  
Exposed Perimeter ..... **0.0** ft  
Edge Insulation R-Value ..... **0.00** (hr·ft<sup>2</sup>·°F)/BTU

#### 7. Partitions:

**(No partition data).**

## Space Input Data

Dr Ukaegba Office  
FloridaEnergyCalcs.com

04/24/2022  
06:53PM

### 6 Exam Room

#### 1. General Details:

Floor Area ..... **150.0** ft<sup>2</sup>  
Avg. Ceiling Height ..... **9.0** ft  
Building Weight ..... **70.0** lb/ft<sup>2</sup>

#### 1.1. OA Ventilation Requirements:

Space Usage ..... **User-Defined**  
OA Requirement 1 ..... **5.0** CFM/person  
OA Requirement 2 ..... **0.06** CFM/ft<sup>2</sup>  
Space Usage Defaults .. **ASHRAE Standard 62.1-2010**

#### 2. Internals:

##### 2.1. Overhead Lighting:

Fixture Type ..... **Recessed (Unvented)**  
Wattage ..... **0.80** W/ft<sup>2</sup>  
Ballast Multiplier ..... **1.00**  
Schedule ..... **Office Schedule**

##### 2.4. People:

Occupancy ..... **1.5** People  
Activity Level ..... **Office Work**  
Sensible ..... **245.0** BTU/hr/person  
Latent ..... **205.0** BTU/hr/person  
Schedule ..... **Office Schedule**

##### 2.2. Task Lighting:

Wattage ..... **0.00** W/ft<sup>2</sup>  
Schedule ..... **None**

##### 2.5. Miscellaneous Loads:

Sensible ..... **0** BTU/hr  
Schedule ..... **None**  
Latent ..... **0** BTU/hr  
Schedule ..... **None**

##### 2.3. Electrical Equipment:

Wattage ..... **1.50** W/ft<sup>2</sup>  
Schedule ..... **Office Schedule**

#### 3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft <sup>2</sup> )	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
N	110.0	1	0	0

##### 3.1. Construction Types for Exposure N

Wall Type ..... **Stucco + Sheathing + R-11 Batt**  
1st Window Type ..... **3x5 Window**  
1st Window Shade Type ..... **Reveal**

#### 4. Roofs, Skylights:

Exp.	Roof Gross Area (ft <sup>2</sup> )	Roof Slope (deg.)	Skylight Qty.
H	150.0	0	0

##### 4.1. Construction Types for Exposure H

Roof Type ..... **Roof**

#### 5. Infiltration:

Design Cooling ..... **0.00** CFM  
Design Heating ..... **0.00** CFM  
Energy Analysis ..... **0.00** CFM  
*Infiltration occurs only when the fan is off.*

#### 6. Floors:

Type ..... **Slab Floor On Grade**  
Floor Area ..... **150.0** ft<sup>2</sup>  
Total Floor U-Value ..... **0.100** BTU/(hr·ft<sup>2</sup>·°F)  
Exposed Perimeter ..... **0.0** ft  
Edge Insulation R-Value ..... **0.00** (hr·ft<sup>2</sup>·°F)/BTU

#### 7. Partitions:

**(No partition data).**

## Space Input Data

Dr Ukaegba Office  
FloridaEnergyCalcs.com

04/24/2022  
06:53PM

### 7 Exam Room

#### 1. General Details:

Floor Area ..... **140.0** ft<sup>2</sup>  
Avg. Ceiling Height ..... **9.0** ft  
Building Weight ..... **70.0** lb/ft<sup>2</sup>

#### 1.1. OA Ventilation Requirements:

Space Usage ..... **User-Defined**  
OA Requirement 1 ..... **5.0** CFM/person  
OA Requirement 2 ..... **0.06** CFM/ft<sup>2</sup>  
Space Usage Defaults .. **ASHRAE Standard 62.1-2010**

#### 2. Internals:

##### 2.1. Overhead Lighting:

Fixture Type ..... **Recessed (Unvented)**  
Wattage ..... **0.80** W/ft<sup>2</sup>  
Ballast Multiplier ..... **1.00**  
Schedule ..... **Office Schedule**

##### 2.4. People:

Occupancy ..... **1.5** People  
Activity Level ..... **Office Work**  
Sensible ..... **245.0** BTU/hr/person  
Latent ..... **205.0** BTU/hr/person  
Schedule ..... **Office Schedule**

##### 2.2. Task Lighting:

Wattage ..... **0.00** W/ft<sup>2</sup>  
Schedule ..... **None**

##### 2.5. Miscellaneous Loads:

Sensible ..... **0** BTU/hr  
Schedule ..... **None**  
Latent ..... **0** BTU/hr  
Schedule ..... **None**

##### 2.3. Electrical Equipment:

Wattage ..... **1.50** W/ft<sup>2</sup>  
Schedule ..... **Office Schedule**

#### 3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft <sup>2</sup> )	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
N	120.0	1	0	0

##### 3.1. Construction Types for Exposure N

Wall Type ..... **Stucco + Sheathing + R-11 Batt**  
1st Window Type ..... **3x5 Window**  
1st Window Shade Type ..... **Reveal**

#### 4. Roofs, Skylights:

Exp.	Roof Gross Area (ft <sup>2</sup> )	Roof Slope (deg.)	Skylight Qty.
H	140.0	0	0

##### 4.1. Construction Types for Exposure H

Roof Type ..... **Roof**

#### 5. Infiltration:

Design Cooling ..... **0.00** CFM  
Design Heating ..... **0.00** CFM  
Energy Analysis ..... **0.00** CFM  
*Infiltration occurs only when the fan is off.*

#### 6. Floors:

Type ..... **Slab Floor On Grade**  
Floor Area ..... **140.0** ft<sup>2</sup>  
Total Floor U-Value ..... **0.100** BTU/(hr·ft<sup>2</sup>·°F)  
Exposed Perimeter ..... **0.0** ft  
Edge Insulation R-Value ..... **0.00** (hr·ft<sup>2</sup>·°F)/BTU

#### 7. Partitions:

**(No partition data).**

## Space Input Data

Dr Ukaegba Office  
FloridaEnergyCalcs.com

04/24/2022  
06:53PM

### 8 Exam Room

#### 1. General Details:

Floor Area ..... **160.0** ft<sup>2</sup>  
Avg. Ceiling Height ..... **9.0** ft  
Building Weight ..... **70.0** lb/ft<sup>2</sup>

#### 1.1. OA Ventilation Requirements:

Space Usage ..... **User-Defined**  
OA Requirement 1 ..... **5.0** CFM/person  
OA Requirement 2 ..... **0.06** CFM/ft<sup>2</sup>  
Space Usage Defaults .. **ASHRAE Standard 62.1-2010**

#### 2. Internals:

##### 2.1. Overhead Lighting:

Fixture Type ..... **Recessed (Unvented)**  
Wattage ..... **0.80** W/ft<sup>2</sup>  
Ballast Multiplier ..... **1.00**  
Schedule ..... **Office Schedule**

##### 2.4. People:

Occupancy ..... **1.5** People  
Activity Level ..... **Office Work**  
Sensible ..... **245.0** BTU/hr/person  
Latent ..... **205.0** BTU/hr/person  
Schedule ..... **Office Schedule**

##### 2.2. Task Lighting:

Wattage ..... **0.00** W/ft<sup>2</sup>  
Schedule ..... **None**

##### 2.5. Miscellaneous Loads:

Sensible ..... **0** BTU/hr  
Schedule ..... **None**  
Latent ..... **0** BTU/hr  
Schedule ..... **None**

##### 2.3. Electrical Equipment:

Wattage ..... **1.50** W/ft<sup>2</sup>  
Schedule ..... **Office Schedule**

#### 3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft <sup>2</sup> )	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
N	120.0	1	0	0

##### 3.1. Construction Types for Exposure N

Wall Type ..... **Stucco + Sheathing + R-11 Batt**  
1st Window Type ..... **3x5 Window**  
1st Window Shade Type ..... **Reveal**

#### 4. Roofs, Skylights:

Exp.	Roof Gross Area (ft <sup>2</sup> )	Roof Slope (deg.)	Skylight Qty.
H	160.0	0	0

##### 4.1. Construction Types for Exposure H

Roof Type ..... **Roof**

#### 5. Infiltration:

Design Cooling ..... **0.00** CFM  
Design Heating ..... **0.00** CFM  
Energy Analysis ..... **0.00** CFM  
*Infiltration occurs only when the fan is off.*

#### 6. Floors:

Type ..... **Slab Floor On Grade**  
Floor Area ..... **160.0** ft<sup>2</sup>  
Total Floor U-Value ..... **0.100** BTU/(hr·ft<sup>2</sup>·°F)  
Exposed Perimeter ..... **0.0** ft  
Edge Insulation R-Value ..... **0.00** (hr·ft<sup>2</sup>·°F)/BTU

#### 7. Partitions:

**(No partition data).**

## Space Input Data

Dr Ukaegba Office  
FloridaEnergyCalcs.com

04/24/2022  
06:53PM

### 9 Exam Room

#### 1. General Details:

Floor Area ..... **105.0** ft<sup>2</sup>  
Avg. Ceiling Height ..... **9.0** ft  
Building Weight ..... **70.0** lb/ft<sup>2</sup>

#### 1.1. OA Ventilation Requirements:

Space Usage ..... **User-Defined**  
OA Requirement 1 ..... **5.0** CFM/person  
OA Requirement 2 ..... **0.06** CFM/ft<sup>2</sup>  
Space Usage Defaults .. **ASHRAE Standard 62.1-2010**

#### 2. Internals:

##### 2.1. Overhead Lighting:

Fixture Type ..... **Recessed (Unvented)**  
Wattage ..... **0.80** W/ft<sup>2</sup>  
Ballast Multiplier ..... **1.00**  
Schedule ..... **Office Schedule**

##### 2.4. People:

Occupancy ..... **1.5** People  
Activity Level ..... **Office Work**  
Sensible ..... **245.0** BTU/hr/person  
Latent ..... **205.0** BTU/hr/person  
Schedule ..... **Office Schedule**

##### 2.2. Task Lighting:

Wattage ..... **0.00** W/ft<sup>2</sup>  
Schedule ..... **None**

##### 2.5. Miscellaneous Loads:

Sensible ..... **0** BTU/hr  
Schedule ..... **None**  
Latent ..... **0** BTU/hr  
Schedule ..... **None**

##### 2.3. Electrical Equipment:

Wattage ..... **1.50** W/ft<sup>2</sup>  
Schedule ..... **Office Schedule**

#### 3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft <sup>2</sup> )	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
N	120.0	0	0	0

##### 3.1. Construction Types for Exposure N

Wall Type ..... **Stucco + Sheathing + R-11 Batt**

#### 4. Roofs, Skylights:

Exp.	Roof Gross Area (ft <sup>2</sup> )	Roof Slope (deg.)	Skylight Qty.
H	105.0	0	0

##### 4.1. Construction Types for Exposure H

Roof Type ..... **Roof**

#### 5. Infiltration:

Design Cooling ..... **0.00** CFM  
Design Heating ..... **0.00** CFM  
Energy Analysis ..... **0.00** CFM  
*Infiltration occurs only when the fan is off.*

#### 6. Floors:

Type ..... **Slab Floor On Grade**  
Floor Area ..... **105.0** ft<sup>2</sup>  
Total Floor U-Value ..... **0.100** BTU/(hr·ft<sup>2</sup>·°F)  
Exposed Perimeter ..... **0.0** ft  
Edge Insulation R-Value ..... **0.00** (hr·ft<sup>2</sup>·°F)/BTU

#### 7. Partitions:

**(No partition data).**



## Wall Constructions

Dr Ukaegba Office  
FloridaEnergyCalcs.com

04/24/2022  
06:53PM

### Stucco + Sheathing + R-11 Batt

#### Wall Details

Outside Surface Color ..... **Dark**  
Absorptivity ..... **0.900**  
Overall U-Value ..... **0.070** BTU/(hr·ft<sup>2</sup>·°F)

#### Wall Layers Details (Inside to Outside)

Layers	Thickness in	Density lb/ft <sup>3</sup>	Specific Ht. BTU / (lb·°F)	R-Value (hr·ft <sup>2</sup> ·°F)/BTU	Weight lb/ft <sup>2</sup>
Inside surface resistance	0.000	0.0	0.00	0.68500	0.0
1/2-in gypsum board	0.500	50.0	0.26	0.44803	2.1
R-11 batt insulation	3.500	0.5	0.20	11.21795	0.1
Sheathing	0.500	70.0	0.35	1.43678	2.9
1-in stucco	1.000	116.0	0.20	0.19984	9.7
Outside surface resistance	0.000	0.0	0.00	0.33300	0.0
<b>Totals</b>	<b>5.500</b>	<b>-</b>		<b>14.32060</b>	<b>14.8</b>

## Window Constructions

Dr Ukaegba Office  
FloridaEnergyCalcs.com

04/24/2022  
06:54PM

### 3x5 Window

#### Window Details:

Detailed Input ..... **No**  
Height ..... **5.00** ft  
Width ..... **3.00** ft  
Overall U-Value ..... **0.500** BTU/(hr·ft<sup>2</sup>·°F)  
Overall Shade Coefficient ..... **0.400**

### Store Front

#### Window Details:

Detailed Input ..... **Yes**  
Height ..... **7.00** ft  
Width ..... **4.00** ft  
Frame Type ..... **Aluminum without thermal breaks**  
Internal Shade Type ..... **None**  
Overall U-Value ..... **1.228** BTU/(hr·ft<sup>2</sup>·°F)  
Overall Shade Coefficient ..... **0.916**

#### Glass Details:

Gap Type ..... **1/4" Air Space**

Glazing	Glass Type	Transmissivity	Reflectivity	Absorptivity
Outer Glazing	1/8" clear	0.841	0.078	0.081
Glazing #2	not used	1.000	0.000	0.000
Glazing #3	not used	1.000	0.000	0.000

## Roof Constructions

Dr Ukaegba Office  
FloridaEnergyCalcs.com

04/24/2022  
06:54PM

### Roof

#### Roof Details

Outside Surface Color ..... **Dark**  
Absorptivity ..... **0.900**  
Overall U-Value ..... **0.038** BTU/(hr·ft²·°F)

#### Roof Layers Details (Inside to Outside)

Layers	Thickness in	Density lb/ft³	Specific Ht. BTU / (lb·°F)	R-Value (hr·ft²·°F)/BTU	Weight lb/ft²
Inside surface resistance	0.000	0.0	0.00	0.68500	0.0
Steel deck	0.034	489.0	0.12	0.00011	1.4
R-25 batt insulation	7.800	0.5	0.20	25.00000	0.3
Built-up roofing	0.150	70.0	0.35	0.13298	0.9
Outside surface resistance	0.000	0.0	0.00	0.33300	0.0
<b>Totals</b>	<b>7.984</b>	<b>-</b>		<b>26.15109</b>	<b>2.6</b>

## Design Weather Parameters & MSHGs

Dr Ukaegba Office  
FloridaEnergyCalcs.com

04/24/2022  
06:54PM

### Design Parameters:

City Name ..... **Lake City**  
 Location ..... **Florida**  
 Latitude ..... **30.5** Deg.  
 Longitude ..... **81.7** Deg.  
 Elevation ..... **30.0** ft  
 Summer Design Dry-Bulb ..... **94.0** °F  
 Summer Coincident Wet-Bulb ..... **77.0** °F  
 Summer Daily Range ..... **17.8** °F  
 Winter Design Dry-Bulb ..... **29.0** °F  
 Winter Design Wet-Bulb ..... **24.4** °F  
 Atmospheric Clearness Number ..... **0.90**  
 Average Ground Reflectance ..... **0.20**  
 Soil Conductivity ..... **0.800** BTU/(hr·ft·°F)  
 Local Time Zone (GMT +/- N hours) ..... **5.0** hours  
 Consider Daylight Savings Time ..... **No**  
 Simulation Weather Data ..... **N/A**  
 Current Data is ..... **User Modified**  
 Design Cooling Months ..... **January to December**

### Design Day Maximum Solar Heat Gains

(The MSHG values are expressed in BTU/(hr·ft²) )

Month	N	NNE	NE	ENE	E	ESE	SE	SSE	S
January	21.8	21.8	29.5	95.1	162.7	208.0	225.4	223.2	219.1
February	25.1	25.1	63.9	135.4	185.2	220.3	221.2	205.4	194.0
March	28.8	34.0	101.2	166.9	205.2	213.7	202.3	171.2	152.0
April	32.2	73.6	134.5	180.9	204.2	196.4	165.2	121.2	96.4
May	35.4	101.3	154.9	186.4	197.0	178.3	134.7	83.3	60.5
June	43.9	110.9	159.4	187.9	192.5	168.6	121.5	69.1	49.8
July	36.3	100.6	150.2	185.7	193.8	173.1	132.1	81.1	59.0
August	33.7	72.8	129.6	176.6	197.2	188.1	159.7	116.9	93.2
September	29.7	32.5	95.0	156.4	195.9	205.6	194.5	166.2	148.2
October	25.8	25.8	58.8	130.0	183.5	208.3	216.2	200.6	188.2
November	22.0	22.0	24.9	99.3	157.1	203.2	223.0	221.9	215.5
December	20.3	20.3	20.3	82.8	148.5	199.7	221.8	226.7	224.8
Month	SSW	SW	WSW	W	WNW	NW	NNW	HOR	Mult
January	224.8	225.4	207.8	157.7	100.6	26.7	21.8	165.3	1.00
February	206.8	223.6	215.8	190.1	136.2	57.2	25.1	200.7	1.00
March	171.3	202.3	214.7	206.1	165.6	99.6	34.3	231.2	1.00
April	121.4	165.8	194.9	204.4	182.7	133.3	73.4	246.2	1.00
May	83.8	136.1	177.1	198.1	189.4	152.6	100.7	250.2	1.00
June	69.2	121.9	168.4	192.8	188.7	158.5	110.8	249.4	1.00
July	80.9	131.5	173.7	193.4	184.5	151.4	101.0	246.8	1.00
August	117.0	159.7	187.9	197.2	176.7	129.9	72.7	241.1	1.00
September	165.6	193.9	206.5	192.1	157.9	98.4	30.1	223.4	1.00
October	198.9	213.7	212.7	181.6	126.0	63.2	25.8	196.2	1.00
November	221.1	223.2	202.8	161.3	92.5	29.5	22.0	163.7	1.00
December	226.4	223.4	198.9	150.4	78.5	20.3	20.3	149.7	1.00

Mult. = User-defined solar multiplier factor.