

37863



---

**Britt Surveying and Mapping, LLC**  
2086 SW Main Blvd Ste 112 • Lake City, FL 32025  
386-752-7163 P • 386-752-5573 F • [www.brittsurvey.com](http://www.brittsurvey.com)

04/18/19

L-25792

Re: Lot 48 Woodborough Phase 1

Bryan Zecher Construction

To Whom It May Concern:

The elevation of the top of the stem wall is found to be 140.44 feet. The lowest adjacent grade is found to be 138.0 feet, and the highest adjacent grade is found to be 139.8 feet. The centerline of NE Scenic Lake Drive in the center of lot 48 is 145.02 feet. The required minimum floor elevation is 139.20 feet. The elevations shown hereon are based on plat datum (NGVD 29).

Sincerely,

L. Scott Britt  
LS 5757

*Sealed  
jwb*