

CAROL CHADWICK, P.E.

*Civil Engineer*

1208 S.W. Fairfax Glen

Lake City, FL 32025

307.680.1772

ccpewyo@gmail.com

www.carolchadwickpe.com

June 2, 2022

Twilla & Art Mckibbin

twillamyfirealtor@gmail.com

re: FRAMING LETTER

Revisions & additions to the plans dated February 4, 2022:

- Sheet S-3, Stem Wall Foundation Detail A: change "2x10 floor joists" to "2x8 floor joists"
- Install Simpson MSTA 24Z straps at 32" o.c. from stem wall to rim/floor joists.

In my professional opinion, this structure meets the requirements for a residential dwelling per the Florida Building Code 2020, 7<sup>th</sup> Edition, Residential. Should you have any questions, please don't hesitate to contact me.

Respectfully,



Digitally signed by  
Carol Chadwick  
DN: c=US, o=Florida,  
dnQualifier=A01410  
D0000017EB6D924C  
E0005954C,  
cn=Carol Chadwick  
Date: 2022.06.02  
15:18:26 -04'00'

Carol Chadwick, P.E.

Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

CC Job #FL22026

