Job: J-9735 - C-1309 Date: May 02, 2023 LaTisha Furmon

Project Information

PARRISH RESIDENCE 157 SE SHADY WAY, LULU, FL For:

Notes:

Design Information

Weather: Gainesville Regional, FL, US

Winter Design Conditions

Summer Design Conditions

Outside db Inside db	33 °F 70 °F	Outside db Inside db	92 °F 75 °F
Design TD	37 °F	Design TD Daily range	17 °F M
		Relative humidity Moisture difference	50 % 44 gr/lb

Heating Summary

Sensible Cooling Equipment Load Sizing

Structure	15855	Btuh	Structure	21159 Btuh
Ducts	4344	Btuh	Ducts	6455 Btuh
Central vent (0 cfm)	0	Btuh	Central vent (0 cfm)	0 Btuh
(none) `			(none)	
Humidification	0	Btuh	Blower ´	0 Btuh
Piping	0	Btuh		
Piping Equipment load	20199	Btuh	Use manufacturer's data	n
• •			Rate/swing multiplier	0.97
	Infiltration		Equipment sensible load	26841 Btuh

Method	Simplified
Construction quality	Average

Latent Cooling Equipment Load Sizing

Fireplaces		Average 0	Structure Ducts Central vent (0 cfm)	2438 1350 0	Btuh Btuh Btuh
Area (ft²) Volume (ft³)	Heating 1814 14550	Cooling 1814 14550	(none) Equipment latent load	3788	
Air changes/hour Equiv. AVF (cfm)	0.38 92	0.20 49	Equipment Total Load (Sen+Lat) Req. total capacity at 0.80 SHR	30629 2.8	Btuh ton

Heating Equipment Summary

Cooling Equipment Summary

	Trane TRANE 4TWR4036N1 209842226			Make Trade Cond Coil AHRI ref	Trane TRANE 4TWR4036 TEM4B0C3 209842226	37M31++TDR		
Efficiency Heating input Heating outpu Temperature Actual air flow Air flow factor Static pressur Space thermo	ut rise v · re	32600 26 1153 0.057	SPF2 Btuh @ 47°F °F cfm cfm/Btuh in H2O	Efficiency Sensible co Latent coolin Total coolin Actual air flo Air flow facto Static press	oling ng g ow or	, 11.7 EER2,14.3	27680 6920 34600 1153 0.042	Btuh Btuh Btuh cfm cfm/Btuh in H2O

Capacity balance point = 20 °F

Backup:

Input = 7 kW, Output = 23269 Btuh, 100 AFUE

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Manual S Compliance Report Entire House

J-9735 - C-1309 Job: Date: May 02, 2023 LaTisha Furmon

Project Information

PARRISH RESIDENCE For:

157 SE SHADY WAY, LULU, FL

Cooling Equipment

Design Conditions

Outdoor design DB:	92.2°F	Sensible gain:	27614	Btuh	Entering coil DB:	77.9°F
Outdoor design WB:	75.8°F	Latent gain:	3788	Btuh	Entering coil WB:	63.9°F
Indoor design DB:	75.0°F	Total gain:	31402	Btuh	· ·	

Indoor RH: 50% Estimated airflow: 1153 cfm

Manufacturer's Performance Data at Actual Design Conditions

Equipment type: **Split ASHP**

Manufacturer: Trane Model: 4TWR4036N1+TEM4B0C37M31++TDR

Actual airflow: 1153 cfm

Sensible capacity: 100% of load 27680 Btuh Latent capacity: 183% of load 6920 Btuh

Total capacity: 34600 Btuh 110% of load SHR: 80%

Heating Equipment

Design Conditions

Outdoor design DB: 33.2°F Heat loss: 20199 **Btuh** Entering coil DB: 68.6°F

Indoor design DB: 70.0°F

Manufacturer's Performance Data at Actual Design Conditions

Split ASHP Equipment type:

Manufacturer: Trane Model: 4TWR4036N1+TEM4B0C37M31++TDR

Actual airflow: 1153 cfm

20 °F 161% of load Capacity balance: Output capacity: 32600 Btuh Supplemental heat required: 0 Btuh Economic balance: -99 °F

Backup equipment type: Elec strip

Manufacturer: Model:

Actual airflow: 1153 cfm

Output capacity: 6.8 kW 115% of load Temp. rise: 50 °F

Meets all requirements of ACCA Manual S.



2023-May-02 12:01:42