

April 7, 2021

Karla Laguna
SW Baron Glen
Fort White, FL 32038

Subject: Permit # 41218 - Lot 6, Southern Meadows, Ph 1 - Elevation Letter

Dear Mrs. Laguna:

Daniel & Gore, LLC has performed a vertical survey on Lot 6, Southern Meadows, Phase 1, Columbia County, Florida from a benchmark being a FDOT concrete monument (2902007 BM 8) on the West right of way of State Road No. 47 (elevation – 75.66', NAVD 1988) and have determined the following:

- The Subdivision plat requires the minimum finish floor elevation to be 87.0' (datum unknown).
- The finished floor elevation of the residence is 89.65', being 2.65' above the required minimum finish floor elevation.

If you have any questions, please call me.

Sincerely,



Scott Daniel, PSM

