



Britt Surveying and Mapping, LLC
2086 SW Main Blvd Ste 112 • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

05/4/2021

Permit # 000041288

L-27514

Don Little Construction

Re: Lot 13 Turkey Creek

To Whom It May Concern:

The top of the finished slab on said Lot 13 is 160.75 feet. The minimum floor elevation is 160.75 feet per the building permit. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,


L. Scott Britt
LS 5757

