



Britt Surveying and Mapping, LLC
2086 SW Main Blvd Ste 112 • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

10/13/20

Permit #000040169 & #000039741

L-27024

Re: Lot 9 Southern Approaches

Blake Lunde

To Whom It May Concern:

The finished floor elevation of the residence on Lot 9 of Southern Approaches Unit 1 is determined to be an elevation of 113.21 feet. The minimum floor elevation per the permit is shown to be 111.4 feet. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,


L. Scott Britt
LS 5757