



Lumber design values are in accordance with ANSI/TPI 1 section 6.3
These truss designs rely on lumber values established by others.

RE: 2652828 - WOODMAN PARK - WINNETTE RES.

MiTek USA, Inc.

6904 Parke East Blvd.
Tampa, FL 33610-4115

Site Information:

Customer Info: Woodman Park Bldrs. Project Name: Winnette Res. Model: Custom
Lot/Block: N/A Subdivision: N/A
Address: 719 Happy Jack Drive, N/A
City: Columbia Cty State: FL

Name Address and License # of Structural Engineer of Record, If there is one, for the building.

Name: License #:
Address:
City: State:

General Truss Engineering Criteria & Design Loads (Individual Truss Design Drawings Show Special Loading Conditions):

Design Code: FBC2020/TPI2014 Design Program: MiTek 20/20 8.4
Wind Code: N/A Wind Speed: 130 mph
Roof Load: 37.0 psf Floor Load: N/A psf

This package includes 8 individual, Truss Design Drawings and 0 Additional Drawings.
With my seal affixed to this sheet, I hereby certify that I am the Truss Design Engineer and this index sheet conforms to 61G15-31.003, section 5 of the Florida Board of Professional Engineers Rules.

No.	Seal#	Truss Name	Date
1	T23020752	T01	3/1/21
2	T23020753	T01G	3/1/21
3	T23020754	T02	3/1/21
4	T23020755	T02G	3/1/21
5	T23020756	T03	3/1/21
6	T23020757	T04	3/1/21
7	T23020758	T05	3/1/21
8	T23020759	T06	3/1/21



The truss drawing(s) referenced above have been prepared by MiTek USA, Inc. under my direct supervision based on the parameters provided by Builders FirstSource-Jacksonville.

Truss Design Engineer's Name: Lee, Julius
My license renewal date for the state of Florida is February 28, 2023.

IMPORTANT NOTE: The seal on these truss component designs is a certification that the engineer named is licensed in the jurisdiction(s) identified and that the designs comply with ANSI/TPI 1. These designs are based upon parameters shown (e.g., loads, supports, dimensions, shapes and design codes), which were given to MiTek or TRENCO. Any project specific information included is for MiTek's or TRENCO's customers file reference purpose only, and was not taken into account in the preparation of these designs. MiTek or TRENCO has not independently verified the applicability of the design parameters or the designs for any particular building. Before use, the building designer should verify applicability of design parameters and properly incorporate these designs into the overall building design per ANSI/TPI 1, Chapter 2.



Julius Lee PE No.34869
MiTek USA, Inc. FL Cert 6634
6904 Parke East Blvd. Tampa FL 33610
Date:

March 1, 2021

Lee, Julius

1 of 1

Job	Truss	Truss Type	Qty	Ply	WOODMAN PARK - WINNETTE RES.
2652828	T01	Roof Special	6	1	

Builders FirstSource, Lake City, FL 32055

Run: 8.420 s Nov 10 2020 Print: 8.430 s Nov 30 2020 MiTek Industries, Inc. Mon Mar 1 15:23:00 2021 Page 1
ID: I6cHoKCOPy60Oihh9X8Oejzh775-JkK8SfDuZyyQENUq?OfLE2wFdfCmBEZbg0QB0zzfGFP

2-0-0	6-0-0	12-6-0	18-10-8	25-2-4	31-6-2	37-10-15	43-4-8	50-2-12	56-4-8	58-4-8
2-0-0	6-0-0	6-6-0	6-4-8	6-3-12	6-3-14	6-4-13	5-5-9	6-10-4	6-1-12	2-0-0

Scale = 1.99.2




Plate Offsets (X,Y)=-	[2:0-0-0,0-1-14], [4:0-4-0,0-4-8], [8:0-4-0,0-4-8], [14:0-1-8,0-3-4], [19:0-4-0,0-4-8]
-----------------------	--

LOADING (psf)	SPACING-	2-0-0	CSI.	DEFL.	in (loc)	l/defl	L/d	PLATES	GRIP
TCLL 20.0	Plate Grip DOL	1.25	TC 0.64	Vert(LL)	-0.31 18-19	>999	240	MT20	244/190
TCDL 7.0	Lumber DOL	1.25	BC 0.77	Vert(CT)	-0.52 18-19	>999	180		
BCLL 0.0 *	Rep Stress Incr	YES	WB 0.95	Horz(CT)	0.12 13	n/a	n/a		
BCDL 10.0	Code FBC2020/TPI2014		Matrix-MS					Weight: 414 lb	FT = 20%

LUMBER-	BRACING-
TOP CHORD 2x6 SP No.2	TOP CHORD Sheathed or 2-11-9 oc purlins.
BOT CHORD 2x6 SP No.2 *Except*	Rigid ceiling directly applied or 10-0-0 oc bracing. Except:
2-19: 2x6 SP M 26	6-0-0 oc bracing: 13-14, 11-13.
WEBS 2x4 SP No.3 *Except*	1 Row at midpt 5-18, 7-18, 10-14
10-14: 2x4 SP No.2	
WEDGE	MiTek recommends that Stabilizers and required cross bracing
Left: 2x4 SP No.3	be installed during truss erection, in accordance with Stabilizer
	Installation guide.

REACTIONS. (lb/size) 2=1925/0-3-8 (min. 0-2-8), 13=2462/0-3-8 (min. 0-3-3)
Max Horz 2=170(LC 16)
Max Uplift 2=-432(LC 12), 13=-629(LC 9)
Max Grav 2=2133(LC 2), 13=2703(LC 2)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
TOP CHORD 2-27=-4068/882, 3-27=-3983/899, 3-4=-3941/883, 4-5=-3541/850, 5-28=-2645/683,
6-28=-2592/702, 6-29=-2592/692, 7-29=-2646/674, 7-8=-3409/748, 8-9=-3508/627,
9-10=-3360/532, 10-30=-1145/1036, 11-30=-1153/1003
BOT CHORD 2-20=-796/3663, 20-31=-667/3464, 31-32=-667/3464, 19-32=-667/3464, 19-33=-484/2938,
33-34=-484/2938, 18-34=-484/2938, 18-35=-440/2873, 17-35=-440/2873, 17-36=-440/2873,
16-36=-440/2873, 16-37=-493/3243, 37-38=-493/3243, 15-38=-493/3243,
14-15=-493/3243, 13-14=-955/1158, 13-39=-955/1158, 11-39=-955/1158
WEBS 4-20=-54/288, 4-19=-492/235, 5-19=-162/839, 5-18=-911/330, 6-18=-361/1715,
7-18=-806/296, 7-16=-111/685, 8-16=-313/187, 8-14=-98/328, 9-14=-710/240,
10-14=-1375/4201, 10-13=-2379/909

NOTES-

- Unbalanced roof live loads have been considered for this design.
- Wind: ASCE 7-16; Vult=130mph (3-second gust) Vasd=101mph; TCDL=4.2psf; BCDL=3.0psf; h=20ft; Cat. II; Exp B; Encl., GCpi=0.18; MWFRS (envelope) gable end zone and C-C Exterior(2E) -2-0-0 to 3-7-10, Interior(1) 3-7-10 to 25-2-4, Exterior(2R) 25-2-4 to 30-9-14, Interior(1) 30-9-14 to 58-4-8 zone; cantilever right exposed ;C-C for members and forces & MWFRS for reactions shown; Lumber DOL=1.60 plate grip DOL=1.60
- Building Designer / Project engineer responsible for verifying applied roof live load shown covers rain loading requirements specific to the use of this truss component.
- This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
- * This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members, with BCDL = 10.0psf.
- Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 432 lb uplift at joint 2 and 629 lb uplift at joint 13.

LOAD CASE(S) Standard



Julius Lee PE No.34869
MiTek USA, Inc. FL Cert 6634
6904 Parke East Blvd. Tampa FL 33610
Date:

March 1, 2021

WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 5/19/2020 BEFORE USE.
Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria, DSB-89 and BCSI Building Component Safety Information** available from Truss Plate Institute, 2670 Crain Highway, Suite 203 Waldorf, MD 20601

MiTek
6904 Parke East Blvd.
Tampa, FL 36610

Job	Truss	Truss Type	Qty	Ply	WOODMAN PARK - WINNETTE RES.
2652828	T01G	GABLE	1	1	Job Reference (optional)

Builders FirstSource, Lake City, FL 32055

Run: 8.420 s Nov 10 2020 Print: 8.430 s Nov 30 2020 MiTek Industries, Inc. Mon Mar 1 15:23:03 2021 Page 1
ID: I6cHoKCOpy600ihh9X8Oejzh775-jJ7G4hGmstK75qCPhWD2sgYk_SGtOjn1M_frdlzfGFM

2-0-0	25-2-4	43-4-8	56-4-8	58-4-8
2-0-0	25-2-4	18-2-4	13-0-0	2-0-0

Scale = 1:102.5




Plate Offsets (X,Y)--- [2:0-5-15,Edge], [25:0-3-0,0-0-8], [30:0-2-4,0-2-0], [30:0-2-4,0-2-1]

LOADING (psf)	SPACING-	CSI.	DEFL.	in (loc)	l/defl	L/d	PLATES	GRIP
TCLL 20.0	Plate Grip DOL 1.25	TC 0.83	Vert(LL)	-0.11 30-31	n/r	120	MT20	244/190
TCDL 7.0	Lumber DOL 1.25	BC 0.62	Vert(CT)	-0.20 30-31	n/r	120		
BCLL 0.0 *	Rep Stress Incr YES	WB 0.41	Horz(CT)	-0.05 32	n/a	n/a		
BCDL 10.0	Code FBC2020/TPI2014	Matrix-S					Weight: 475 lb	FT = 20%

LUMBER-

TOP CHORD 2x6 SP No.2
BOT CHORD 2x6 SP No.2
OTHERS 2x4 SP No.3

BRACING-

TOP CHORD
BOT CHORD
WEBS

Sheathed or 7-0-6 oc purlins.

Rigid ceiling directly applied or 5-10-10 oc bracing.

1 Row at midpt 15-46, 14-47, 13-48, 16-44, 17-43

MiTek recommends that Stabilizers and required cross bracing be installed during truss erection, in accordance with Stabilizer Installation guide.

REACTIONS.

All bearings 50-4-8.
(lb) - Max Horz 2=161(LC 16)
Max Uplift All uplift 100 lb or less at joint(s) 47, 48, 49, 50, 52, 53, 54, 55, 56,
57, 44, 43, 42, 41, 40, 39, 38, 36 except 2=269(LC 24), 46=238(LC 9),
35=166(LC 1), 34=222(LC 9), 33=972(LC 1), 32=682(LC 9)
Max Grav All reactions 250 lb or less at joint(s) 2, 48, 49, 50, 52, 53, 54, 55, 56,
43, 42, 41, 40, 39, 38, 36, 35 except 46=788(LC 1), 47=264(LC 1), 57=322(LC
23), 44=264(LC 1), 34=487(LC 1), 33=541(LC 9), 32=1355(LC 1)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.

TOP CHORD 2-3=858/1041, 3-4=848/1091, 4-5=806/1058, 5-6=781/1070, 6-7=751/1068,
7-8=722/1049, 8-9=718/1069, 9-10=692/1069, 10-11=663/1069, 11-12=634/1068,
12-13=598/1046, 13-14=595/1069, 14-15=555/1081, 15-16=484/1037, 16-17=475/1038,
17-18=525/1082, 18-19=559/1071, 19-20=562/1033, 20-21=598/1069,
21-22=627/1070, 22-23=656/1070, 23-24=682/1071, 24-25=709/1061,
25-26=754/1086, 26-27=727/1003, 27-28=774/1051, 28-29=699/914, 29-30=810/1021,
30-31=968/803, 31-32=968/803, 32-33=968/803, 33-34=968/803, 34-35=968/803,
35-36=968/803, 36-37=968/803, 37-38=968/803, 38-39=968/803, 39-40=968/803,
40-41=968/803, 41-42=968/803, 42-43=968/803, 43-44=968/803, 44-45=968/803,
45-46=968/803, 46-47=968/803, 47-48=968/803, 48-49=968/803, 49-50=968/803,
50-51=968/803, 51-52=968/803, 52-53=968/803, 53-54=968/803, 54-55=968/803,
55-56=968/803, 56-57=968/803, 57-58=968/803, 58-59=968/803, 59-60=968/803,
60-61=968/803, 61-62=968/803, 62-63=968/803, 63-64=968/803, 64-65=968/803,
65-66=968/803, 66-67=968/803, 67-68=968/803, 68-69=968/803, 69-70=968/803,
70-71=968/803, 71-72=968/803, 72-73=968/803, 73-74=968/803, 74-75=968/803,
75-76=968/803, 76-77=968/803, 77-78=968/803, 78-79=968/803, 79-80=968/803,
80-81=968/803, 81-82=968/803, 82-83=968/803, 83-84=968/803, 84-85=968/803,
85-86=968/803, 86-87=968/803, 87-88=968/803, 88-89=968/803, 89-90=968/803,
90-91=968/803, 91-92=968/803, 92-93=968/803, 93-94=968/803, 94-95=968/803,
95-96=968/803, 96-97=968/803, 97-98=968/803, 98-99=968/803, 99-100=968/803,
100-101=968/803, 101-102=968/803, 102-103=968/803, 103-104=968/803, 104-105=968/803,
105-106=968/803, 106-107=968/803, 107-108=968/803, 108-109=968/803, 109-110=968/803,
110-111=968/803, 111-112=968/803, 112-113=968/803, 113-114=968/803, 114-115=968/803,
115-116=968/803, 116-117=968/803, 117-118=968/803, 118-119=968/803, 119-120=968/803,
120-121=968/803, 121-122=968/803, 122-123=968/803, 123-124=968/803, 124-125=968/803,
125-126=968/803, 126-127=968/803, 127-128=968/803, 128-129=968/803, 129-130=968/803,
130-131=968/803, 131-132=968/803, 132-133=968/803, 133-134=968/803, 134-135=968/803,
135-136=968/803, 136-137=968/803, 137-138=968/803, 138-139=968/803, 139-140=968/803,
140-141=968/803, 141-142=968/803, 142-143=968/803, 143-144=968/803, 144-145=968/803,
145-146=968/803, 146-147=968/803, 147-148=968/803, 148-149=968/803, 149-150=968/803,
150-151=968/803, 151-152=968/803, 152-153=968/803, 153-154=968/803, 154-155=968/803,
155-156=968/803, 156-157=968/803, 157-158=968/803, 158-159=968/803, 159-160=968/803,
160-161=968/803, 161-162=968/803, 162-163=968/803, 163-164=968/803, 164-165=968/803,
165-166=968/803, 166-167=968/803, 167-168=968/803, 168-169=968/803, 169-170=968/803,
170-171=968/803, 171-172=968/803, 172-173=968/803, 173-174=968/803, 174-175=968/803,
175-176=968/803, 176-177=968/803, 177-178=968/803, 178-179=968/803, 179-180=968/803,
180-181=968/803, 181-182=968/803, 182-183=968/803, 183-184=968/803, 184-185=968/803,
185-186=968/803, 186-187=968/803, 187-188=968/803, 188-189=968/803, 189-190=968/803,
190-191=968/803, 191-192=968/803, 192-193=968/803, 193-194=968/803, 194-195=968/803,
195-196=968/803, 196-197=968/803, 197-198=968/803, 198-199=968/803, 199-200=968/803,
200-201=968/803, 201-202=968/803, 202-203=968/803, 203-204=968/803, 204-205=968/803,
205-206=968/803, 206-207=968/803, 207-208=968/803, 208-209=968/803, 209-210=968/803,
210-211=968/803, 211-212=968/803, 212-213=968/803, 213-214=968/803, 214-215=968/803,
215-216=968/803, 216-217=968/803, 217-218=968/803, 218-219=968/803, 219-220=968/803,
220-221=968/803, 221-222=968/803, 222-223=968/803, 223-224=968/803, 224-225=968/803,
225-226=968/803, 226-227=968/803, 227-228=968/803, 228-229=968/803, 229-230=968/803,
230-231=968/803, 231-232=968/803, 232-233=968/803, 233-234=968/803, 234-235=968/803,
235-236=968/803, 236-237=968/803, 237-238=968/803, 238-239=968/803, 239-240=968/803,
240-241=968/803, 241-242=968/803, 242-243=968/803, 243-244=968/803, 244-245=968/803,
245-246=968/803, 246-247=968/803, 247-248=968/803, 248-249=968/803, 249-250=968/803,
250-251=968/803, 251-252=968/803, 252-253=968/803, 253-254=968/803, 254-255=968/803,
255-256=968/803, 256-257=968/803, 257-258=968/803, 258-259=968/803, 259-260=968/803,
260-261=968/803, 261-262=968/803, 262-263=968/803, 263-264=968/803, 264-265=968/803,
265-266=968/803, 266-267=968/803, 267-268=968/803, 268-269=968/803, 269-270=968/803,
270-271=968/803, 271-272=968/803, 272-273=968/803, 273-274=968/803, 274-275=968/803,
275-276=968/803, 276-277=968/803, 277-278=968/803, 278-279=968/803, 279-280=968/803,
280-281=968/803, 281-282=968/803, 282-283=968/803, 283-284=968/803, 284-285=968/803,
285-286=968/803, 286-287=968/803, 287-288=968/803, 288-289=968/803, 289-290=968/803,
290-291=968/803, 291-292=968/803, 292-293=968/803, 293-294=968/803, 294-295=968/803,
295-296=968/803, 296-297=968/803, 297-298=968/803, 298-299=968/803, 299-300=968/803,
300-301=968/803, 301-302=968/803, 302-303=968/803, 303-304=968/803, 304-305=968/803,
305-306=968/803, 306-307=968/803, 307-308=968/803, 308-309=968/803, 309-310=968/803,
310-311=968/803, 311-312=968/803, 312-313=968/803, 313-314=968/803, 314-315=968/803,
315-316=968/803, 316-317=968/803, 317-318=968/803, 318-319=968/803, 319-320=968/803,
320-321=968/803, 321-322=968/803, 322-323=968/803, 323-324=968/803, 324-325=968/803,
325-326=968/803, 326-327=968/803, 327-328=968/803, 328-329=968/803, 329-330=968/803,
330-331=968/803, 331-332=968/803, 332-333=968/803, 333-334=968/803, 334-335=968/803,
335-336=968/803, 336-337=968/803, 337-338=968/803, 338-339=968/803, 339-340=968/803,
340-341=968/803, 341-342=968/803, 342-343=968/803, 343-344=968/803, 344-345=968/803,
345-346=968/803, 346-347=968/803, 347-348=968/803, 348-349=968/803, 349-350=968/803,
350-351=968/803, 351-352=968/803, 352-353=968/803, 353-354=968/803, 354-355=968/803,
355-356=968/803, 356-357=968/803, 357-358=968/803, 358-359=968/803, 359-360=968/803,
360-361=968/803, 361-362=968/803, 362-363=968/803, 363-364=968/803, 364-365=968/803,
365-366=968/803, 366-367=968/803, 367-368=968/803, 368-369=968/803, 369-370=968/803,
370-371=968/803, 371-372=968/803, 372-373=968/803, 373-374=968/803, 374-375=968/803,
375-376=968/803, 376-377=968/803, 377-378=968/803, 378-379=968/803, 379-380=968/803,
380-381=968/803, 381-382=968/803, 382-383=968/803, 383-384=968/803, 384-385=968/803,
385-386=968/803, 386-387=968/803, 387-388=968/803, 388-389=968/803, 389-390=968/803,
390-391=968/803, 391-392=968/803, 392-393=968/803, 393-394=968/803, 394-395=968/803,
395-396=968/803, 396-397=968/803, 397-398=968/803, 398-399=968/803, 399-400=968/803,
400-401=968/803, 401-402=968/803, 402-403=968/803, 403-404=968/803, 404-405=968/803,
405-406=968/803, 406-407=968/803, 407-408=968/803, 408-409=968/803, 409-410=968/803,
410-411=968/803, 411-412=968/803, 412-413=968/803, 413-414=968/803, 414-415=968/803,
415-416=968/803, 416-417=968/803, 417-418=968/803, 418-419=968/803, 419-420=968/803,
420-421=968/803, 421-422=968/803, 422-423=968/803, 423-424=968/803, 424-425=968/803,
425-426=968/803, 426-427=968/803, 427-428=968/803, 428-429=968/803, 429-430=968/803,
430-431=968/803, 431-432=968/803, 432-433=968/803, 433-434=968/803, 434-435=968/803,
435-436=968/803, 436-437=968/803, 437-438=968/803, 438-439=968/803, 439-440=968/803,
440-441=968/803, 441-442=968/803, 442-443=968/803, 443-444=968/803, 444-445=968/803,
445-446=968/803, 446-447=968/803, 447-448=968/803, 448-449=968/803, 449-450=968/803,
450-451=968/803, 451-452=968/803, 452-453=968/803, 453-454=968/803, 454-455=968/803,
455-456=968/803, 456-457=968/803, 457-458=968/803, 458-459=968/803, 459-460=968/803,
460-461=968/803, 461-462=968/803, 462-463=968/803, 463-464=968/803, 464-465=968/803,
465-466=968/803, 466-467=968/803, 467-468=968/803, 468-469=968/803, 469-470=968/803,
470-471=968/803, 471-472=968/803, 472-473=968/803, 473-474=968/803, 474-475=968/803,
475-476=968/803, 476-477=968/803, 477-478=968/803, 478-479=968/803, 479-480=968/803,
480-481=968/803, 481-482=968/803, 482-483=968/803, 483-484=968/803, 484-485=968/803,
485-486=968/803, 486-487=968/803, 487-488=968/803, 488-489=968/803, 489-490=968/803,
490-491=968/803, 491-492=968/803, 492-493=968/803, 493-494=968/803, 494-495=968/803,
495-496=968/803, 496-497=968/803, 497-498=968/803, 498-499=968/803, 499-500=968/803,
500-501=968/803, 501-502=968/803, 502-503=968/803, 503-504=968/803, 504-505=968/803,
505-506=968/803, 506-507=968/803, 507-508=968/803, 508-509=968/803, 509-510=968/803,
510-511=968/803, 511-512=968/803, 512-513=968/803, 513-514=968/803, 514-515=968/803,
515-516=968/803, 516-517=968/803, 517-518=968/803, 518-519=968/803, 519-520=968/803,
520-521=968/803, 521-522=968/803, 522-523=968/803, 523-524=968/803, 524-525=968/803,
525-526=968/803, 526-527=968/803, 527-528=968/803, 528-529=968/803, 529-530=968/803,
530-531=968/803, 531-532=968/803, 532-533=968/803, 533-534=968/803, 534-535=968/803,
535-536=968/803, 536-537=968/803, 537-538=968/803, 538-539=968/803, 539-540=968/803,
540-541=968/803, 541-542=968/803, 542-543=968/803, 543-544=968/803, 544-545=968/803,
545-546=968/803, 546-547=968/803, 547-548=968/803, 548-549=968/803, 549-550=968/803,
550-551=968/803, 551-552=968/803, 552-553=968/803, 553-554=968/803, 554-555=968/803,
555-556=968/803, 556-557=968/803, 557-558=968/803, 558-559=968/803, 559-560=968/803,
560-561=968/803, 561-562=968/803, 562-563=968/803, 563-564=968/803, 564-565=968/803,
565-566=968/803, 566-567=968/803, 567-568=968/803, 568-569=968/803, 569-570=968/803,
570-571=968/803, 571-572=968/803, 572-573=968/803, 573-574=968/803, 574-575=968/803,
575-576=968/803, 576-577=968/803, 577-578=968/803, 578-579=968/803, 579-580=968/803,
580-581=968/803, 581-582=968/803, 582-583=968/803, 583-584=968/803, 584-585=968/803,
585-586=968/803, 586-587=968/803, 587-588=968/803, 588-589=968/803, 589-590=968/803,
590-591=968/803, 591-592=968/803, 592-593=968/803, 593-594=968/803, 594-595=968/803,
595-596=968/803, 596-597=968/803, 597-598=968/803, 598-599=968/803, 599-600=968/803,
600-601=968/803, 601-602=968/803, 602-603=968/803, 603-604=968/803,

Job	Truss	Truss Type	Qty	Ply	WOODMAN PARK - WINNETTE RES.
2652828	T01G	GABLE	1	1	Job Reference (optional)

Builders FirstSource, Lake City, FL 32055

Run: 8.420 s Nov 10 2020 Print: 8.430 s Nov 30 2020 MiTek Industries, Inc. Mon Mar 1 15:23:03 2021 Page 2
ID:16cHoKCoPy600ihh9X8Oejzh775-jJ?G4hGmstK75qCPhWD2sgYk_SGtOjn1M_frdlzfGFM

NOTES-

- 5) All plates are 2x4 MT20 unless otherwise indicated.
- 6) Gable studs spaced at 2'-0" oc.
- 7) This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
- 8) * This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3'-6" tall by 2'-0" wide will fit between the bottom chord and any other members.
- 9) Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) 47, 48, 49, 50, 52, 53, 54, 55, 56, 57, 44, 43, 42, 41, 40, 39, 38, 36 except (jt=lb) 2=269, 46=238, 35=166, 34=222, 33=972, 32=682.
- 10) Non Standard bearing condition. Review required.

LOAD CASE(S) Standard



WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 5/19/2020 BEFORE USE.

Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see

ANSI/TPI1 Quality Criteria, DSB-89 and BCSI Building Component

Safety Information available from Truss Plate Institute, 2670 Crain Highway, Suite 203 Waldorf, MD 20601



6904 Parke East Blvd.
Tampa, FL 33610

Job	Truss	Truss Type	Qty	Ply	WOODMAN PARK - WINNETTE RES.
2652628	T02	Roof Special	2	1	Job Reference (optional)

Builders FirstSource, Lake City, FL 32055

Run: 8.420 s Nov 10 2020 Print: 8.430 s Nov 30 2020 MiTek Industries, Inc. Mon Mar 1 15:23:04 2021 Page 1
ID: l6cHoKCoPy600ihh9X80ejzh75-BVZfH1G0dBSsj_nbEDkH0u5_yscx73UBbeOP9kzfGFL

2-0-0	6-0-0	12-6-0	18-10-8	25-2-4	31-6-2	37-10-15	43-4-8	50-2-12	56-4-8	58-4-8
2-0-0	6-0-0	6-6-0	6-4-8	6-3-12	6-3-14	6-4-13	5-5-9	6-10-4	6-1-12	2-0-0

Scale = 1.99.2




Plate Offsets (X,Y)---	[2:0-0-0,0-0-14], [4:0-4-0,0-4-8], [8:0-4-0,0-4-8], [14:0-1-8,0-2-12], [19:0-4-0,0-4-8]
------------------------	---

LOADING (psf)	SPACING-	2-0-0	CSI.	DEFL.	in (loc)	I/defl	L/d	PLATES	GRIP
TCLL 20.0	Plate Grip DOL	1.25	TC 0.49	Vert(LL)	-0.19 14-16	>999	240	MT20	244/190
TCDL 7.0	Lumber DOL	1.25	BC 0.63	Vert(CT)	-0.32 14-16	>999	180		
BCLL 0.0 *	Rep Stress Incr	YES	WB 0.89	Horz(CT)	0.05 13	n/a	n/a		
BCDL 10.0	Code FBC2020/TPI2014		Matrix-MS						
								Weight: 414 lb	FT = 20%

LUMBER-
TOP CHORD 2x6 SP No.2
BOT CHORD 2x6 SP No.2
WEBS 2x4 SP No.3 *Except*
10-14: 2x4 SP No.2
WEDGE
Left: 2x4 SP No.3

BRACING-
TOP CHORD Sheathed or 4-4-8 oc purlins.
BOT CHORD Rigid ceiling directly applied or 6-0-0 oc bracing.
WEBS 1 Row at midpt 4-20, 5-19, 5-18, 7-18

MiTek recommends that Stabilizers and required cross bracing be installed during truss erection, in accordance with Stabilizer Installation guide.

REACTIONS. (lb/size) 20=2298/0-3-8 (min. 0-3-0), 13=2090/0-3-8 (min. 0-2-11)
Max Horz 20=170(LC 16)
Max Uplift 20=515(LC 12), 13=585(LC 9)
Max Grav 20=2546(LC 2), 13=2290(LC 2)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
TOP CHORD 2-27=-773/664, 3-27=-757/748, 3-4=-839/999, 4-5=-1347/282, 5-28=-1618/368,
6-28=-1561/386, 6-29=-1561/370, 7-29=-1617/351, 7-8=-2402/502, 8-9=-2600/525,
9-10=-2494/435, 10-30=-1157/1054, 11-30=-1165/1004
BOT CHORD 2-31=-613/765, 20-31=-613/765, 20-32=-96/695, 32-33=-96/695, 19-33=-96/695,
19-34=-166/1366, 34-35=-166/1366, 18-35=-166/1366, 18-36=-168/1937, 17-36=-168/1937,
17-37=-168/1937, 16-37=-168/1937, 16-38=-310/2332, 38-39=-310/2332,
15-39=-310/2332, 14-15=-310/2332, 13-14=-974/1170, 13-40=-974/1170, 11-40=-974/1170
WEBS 3-20=-399/289, 4-20=-2431/891, 4-19=-302/996, 5-19=-581/373, 6-18=-176/938,
7-18=-824/299, 7-16=-114/700, 8-16=-330/191, 8-14=-9/294, 9-14=-582/226,
10-14=-1106/3376, 10-13=-1981/779

NOTES-

- Unbalanced roof live loads have been considered for this design.
- Wind: ASCE 7-16; Vult=130mph (3-second gust) Vasd=101mph; TCDL=4.2psf; BCDL=3.0psf; h=20ft; Cat. II; Exp B; Encl., GCpi=0.18; MWFRS (envelope) gable end zone and C-C Exterior(2E) -2-0-0 to 3-7-10, Interior(1) 3-7-10 to 25-2-4, Exterior(2R) 25-2-4 to 30-9-14, Interior(1) 30-9-14 to 58-4-8 zone; cantilever left and right exposed ;C-C for members and forces & MWFRS for reactions shown; Lumber DOL=1.60 plate grip DOL=1.60
- Building Designer / Project engineer responsible for verifying applied roof live load shown covers rain loading requirements specific to the use of this truss component.
- This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
- * This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members, with BCDL = 10.0psf.
- Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) except (jt=lb) 20=515, 13=585.

LOAD CASE(S) Standard



Julius Lee PE No.34869
MiTek USA, Inc. FL Cert 6634
6904 Parke East Blvd. Tampa FL 33610
Date:

March 1, 2021



WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 5/19/2020 BEFORE USE.

Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria, DSB-89 and BCSI Building Component Safety Information** available from Truss Plate Institute, 2670 Crain Highway, Suite 203 Waldorf, MD 20601



6904 Parke East Blvd.
Tampa, FL 36610

Job	Truss	Truss Type	Qty	Ply	WOODMAN PARK - WINNETTE RES.
2652828	T02G	GABLE	1	1	

Builders FirstSource, Lake City, FL 32055

Job Reference (optional)

8.430 s Nov 30 2020 MiTek Industries, Inc. Mon Mar 1 15:24:34 2021 Page 1

ID:16cHoKCOPy600ih9X8Oejzh775-Yp?gAoMsQqp4WpguW7LO2sqMy8HbC1DQHeBAJXzfGDx




Plate Offsets (X,Y)- [2:0-5-15,Edge], [25:0-3-0,0-0-8], [30:0-2-4,0-2-0], [30:0-2-4,0-2-1]

LOADING (psf)	SPACING-	2-0-0	CSI.	DEFL.	in (loc)	l/defl	L/d	PLATES	GRIP
TCLL 20.0	Plate Grip DOL	1.25	TC 0.51	Vert(LL)	-0.19 30-31	n/r	120	MT20	244/190
TCDL 7.0	Lumber DOL	1.25	BC 0.78	Vert(CT)	-0.27 30-31	n/r	120		
BCLL 0.0 *	Rep Stress Incr	YES	WB 0.41	Horz(CT)	-0.04 32	n/a	n/a		
BCDL 10.0	Code FBC2020/TPI2014		Matrix-S					Weight: 473 lb	FT = 20%

LUMBER-
TOP CHORD 2x6 SP No.2 *Except*
25-30: 2x6 SP M 26
BOT CHORD 2x6 SP No.2
OTHERS 2x4 SP No.3

BRACING-
TOP CHORD Sheathed or 6-11-2 oc purlins.
BOT CHORD Rigid ceiling directly applied or 6-0-0 oc bracing.
WEBS 1 Row at midpt 15-46, 14-47, 13-48, 16-44, 17-43

MiTek recommends that Stabilizers and required cross bracing be installed during truss erection, in accordance with Stabilizer Installation guide.

REACTIONS. All bearings 42-4-8.
(lb) - Max Horz 55=161(LC 12)
Max Uplift All uplift 100 lb or less at joint(s) 47, 48, 49, 50, 52, 53, 44, 43, 42, 41, 40, 39, 38 except 46=123(LC 8), 54=484(LC 23), 55=355(LC 8), 36=102(LC 9), 35=176(LC 24), 34=334(LC 9), 33=1491(LC 24), 32=1047(LC 9)
Max Grav All reactions 250 lb or less at joint(s) 48, 49, 50, 52, 54, 43, 42, 41, 40, 39, 38, 35 except 46=797(LC 1), 47=265(LC 1), 53=278(LC 23), 55=1010(LC 23), 44=265(LC 1), 36=275(LC 24), 34=649(LC 24), 33=896(LC 9), 32=1895(LC 24)

FORCES. (lb) - Max. Comp/Max. Ten. - All forces 250 (lb) or less except when shown.
TOP CHORD 2-3=-1024/1040, 3-58=-1013/1058, 4-58=-1010/1079, 4-5=-1036/1109, 5-6=-1005/1131, 6-7=-864/1028, 7-8=-909/1061, 8-9=-905/1089, 9-10=-872/1082, 10-11=-842/1082, 11-12=-812/1081, 12-59=-784/1045, 13-59=-781/1083, 13-14=-763/1095, 14-15=-704/1050, 15-16=-707/1050, 16-17=-774/1095, 17-60=-799/1083, 18-60=-803/1045, 18-19=-834/1081, 19-20=-863/1082, 20-21=-893/1082, 21-22=-918/1083, 22-23=-922/1061, 23-24=-949/1074, 24-25=-983/1095, 25-26=-957/1015, 26-27=-991/1061, 27-28=-943/957, 28-29=-1027/1077, 29-30=-1030/1023
BOT CHORD 2-61=-980/1020, 57-61=-980/1020, 56-57=-980/1020, 55-56=-980/1020, 54-55=-980/1021, 53-54=-980/1021, 52-53=-980/1021, 51-52=-980/1021, 50-51=-980/1021, 49-50=-980/1021, 48-49=-980/1021, 47-48=-980/1021, 46-47=-980/1021, 45-46=-980/1021, 44-45=-980/1021, 43-44=-980/1021, 42-43=-980/1021, 41-42=-980/1021, 40-41=-980/1021, 39-40=-980/1021, 38-39=-980/1021, 37-38=-980/1021, 36-37=-980/1021, 35-36=-980/1021, 34-35=-990/1030, 33-34=-990/1030, 32-33=-990/1030, 32-62=-990/1030, 30-62=-990/1030
WEBS 15-46=-757/502, 6-55=-465/351, 26-34=-420/268, 27-33=-602/828, 28-32=-1118/712

NOTES-
1) Unbalanced roof live loads have been considered for this design.
2) Wind: ASCE 7-16; Vult=130mph (3-second gust) Vasd=101mph; TCDL=4.2psf; BCDL=3.0psf; h=20ft; Cat. II; Exp B; Encl., GCpi=0.18; MWFRS (envelope) gable end zone and C-C Exterior(2E) -2-0-0 to 3-7-10, Interior(1) 3-7-10 to 25-2-4, Exterior(2R) 25-2-4 to 30-9-14, Interior(1) 30-9-14 to 58-4-8 zone; cantilever left and right exposed ;C-C for members and forces & MWFRS for reactions shown; Lumber DOL=1.60 plate grip DOL=1.60
3) Truss designed for wind loads in the plane of the truss only. For studs exposed to wind (normal to the face), see Standard Industry Gable End Details as applicable, or consult qualified building designer as per ANSI/TPI 1.



Julius Lee PE No.34869
MiTek USA, Inc. FL Cert 6634
6904 Parke East Blvd. Tampa FL 33610
Date:

March 1, 2021

Continued on page 2

WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 5/19/2020 BEFORE USE.
Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see ANSI/TPI1 Quality Criteria, DSB-89 and BCSI Building Component Safety Information available from Truss Plate Institute, 2670 Crain Highway, Suite 203 Waldorf, MD 20601

MiTek
6904 Parke East Blvd.
Tampa, FL 33610

Job	Truss	Truss Type	Qty	Ply	WOODMAN PARK - WINNETTE RES.
2652828	T02G	GABLE	1	1	Job Reference (optional)

Builders FirstSource, Lake City, FL 32055

8 430 s Nov 30 2020 MiTek Industries, Inc. Mon Mar 1 15:24:35 2021 Page 2
ID:16cHoKCOPy600ihh9X8Oejzh775-10Z208NUB8wx7zE44rsda4MXiYdqxKTaWlxjrzzfGDw

NOTES-

- 4) Building Designer / Project engineer responsible for verifying applied roof live load shown covers rain loading requirements specific to the use of this truss component.
- 5) All plates are 2x4 MT20 unless otherwise indicated.
- 6) Gable studs spaced at 2-0-0 oc.
- 7) This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
- 8) * This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members.
- 9) Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) 47, 48, 49, 50, 52, 53, 44, 43, 42, 41, 40, 39, 38 except (jt=lb) 46=123, 54=484, 55=355, 36=102, 35=176, 34=334, 33=1491, 32=1047.
- 10) Non Standard bearing condition. Review required.
- 11) This truss has large uplift reaction(s) from gravity load case(s). Proper connection is required to secure truss against upward movement at the bearings. Building designer must provide for uplift reactions indicated.

LOAD CASE(S) Standard



WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 5/19/2020 BEFORE USE.

Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria, DSB-89 and BCSI Building Component Safety Information** available from Truss Plate Institute, 2670 Crain Highway, Suite 203 Waldorf, MD 20601




6904 Parke East Blvd.
Tampa, FL 36610

Builders FirstSource, Lake City, FL 32055

Run: 8:420 s Nov 10 2020 Print: 8:430 s Nov 30 2020 MiTek Industries, Inc. Mon Mar 1 15:23:07 2021 Page 1
ID:16cHoKcOPy60iOh9X8Oejzh775-b4Fmw2JHw5qQaSWAwMH_OWjVK3fFKPdTcd3m3zGFI

2-0-0	6-0-0	10-3-8	17-8-14	25-2-4	31-6-2	37-10-15	43-4-8	50-2-12	56-4-8	58-4-8
2-0-0	6-0-0	4-3-8	7-5-6	7-5-6	6-3-14	6-4-13	5-5-9	6-10-4	6-1-12	2-0-0




REACTIONS. (lb/size) 26=2309/0-3-8 (min. 0-2-15), 14=2097/0-3-8 (min. 0-2-10)
 Max Horz 26=170(LC 16)
 Max Uplift 26=-512(LC 12), 14=-583(LC 9)
 Max Grav 26=2478(LC 2), 14=2230(LC 2)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.

TOP CHORD 2-34=-746/677, 3-34=-732/755, 3-4=-794/936, 4-5=-1686/268, 5-6=-1621/290,
6-35=-1682/358, 7-35=-1614/380, 7-36=-1610/366, 8-36=-1666/347, 8-9=-2070/452,
9-10=-2462/508, 10-11=-2312/428, 11-37=-1157/1048, 12-37=-1165/998

BOT CHORD 2-38=-625/750, 26-38=-625/750, 25-26=-229/721, 24-25=-206/378, 4-24=-118/380,
23-24=-200/812, 23-39=-188/1496, 22-39=-188/1496, 7-22=-168/956, 18-19=-301/2254,
17-18=-301/2254, 16-17=-317/2222, 15-16=-969/1170, 14-15=-969/1170, 14-40=-969/1170,
12-40=-969/1170

WEBS 3-26=-331/221, 4-26=-1943/414, 4-23=-714/1629, 6-23=-461/375, 19-22=-145/1716,
8-22=-598/268, 8-19=-54/317, 9-19=-522/187, 9-17=0/258, 10-16=-642/342,
11-16=-1092/3193, 11-14=-1897/776

A circular stamp with a serrated edge. The text "JULIUS LEE" is curved along the top inner edge, and "LICENSE" is curved along the bottom inner edge. In the center, the number "No. 21882" is printed.

NOTES:-

- 1) Unbalanced roof live loads have been considered for this design.
- 2) Wind: ASCE 7-16; Vult=130mph (3-second gust) Vasd=101mph; TCDF=4.2psf; BCDL=3.0psf; h=20ft; Cat. II; Exp B; Encl., GCpi=0.18; MWFRS (envelope) gable end zone and C-C Exterior(2E) -2-0-0 to 3-7-10, Interior(1) 3-7-10 to 25-2-4, Exterior(2R) 25-2-4 to 30-9-14, Interior(1) 30-9-14 to 58-4-8 zone; Cantilever left and right exposed ; C-C for members and forces & MWFRS for reactions shown; Lumber DOL=1.60 plate grip DOL=1.60
- 3) Building Designer / Project engineer responsible for verifying applied roof live load shown covers rain loading requirements specific to the use of this truss component.
- 4) This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
- 5) * This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members, with BCDL = 10.0psf.
- 6) Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) except (jt=lb) 26=512, 14=583.

LOAD CASE(S) Standard Date: March 1, 2010



Julius Lee PE No.34869
MiTek USA, Inc. FL Cert 6634
6904 Parke East Blvd. Tampa FL 33610
Date:

March 1, 2021

WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MI-7473 rev. 5/19/2020 BEFORE USE.
Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria, DSB-89 and BCSI Building Component Safety Information** available from Truss Plate Institute, 2670 Crain Highway, Suite 203 Waldorf, MD 20601

MiTek
6904 Parke East Blvd.
Tampa, FL 36610

Job	Truss	Truss Type	Qty	Ply	WOODMAN PARK - WINNETTE RES.
2652828	T04	Roof Special	5	1	Job Reference (optional)

Builders FirstSource, Lake City, FL 32055

Run: 8.420 s Nov 10 2020 Print: 8.430 s Nov 30 2020 MiTek Industries, Inc. Mon Mar 1 15:23:08 2021 Page 1
ID: I6cHoKCPy600ihh9X8Oejzh775-4Gp97OJvgPyHBb5MT3pDYkGg3T1E3jmWfMcJWzfGFH

2-0-0	6-0-0	8-3-8	12-6-0	18-10-8	25-2-4	31-6-2	38-3-8	43-4-8	50-2-12	56-4-8	58-4-8
2-0-0	6-0-0	2-3-8	4-2-8	6-4-8	6-3-12	6-3-14	6-9-6	5-1-0	6-10-4	6-1-12	2-0-0

Scale = 1:100.8




Plate Offsets (X,Y)~	[2:0-0-0,0-0-14], [5:0-4-0,0-4-8], [17:0-3-8,0-2-8], [18:0-5-4,0-3-8], [23:0-5-4,0-3-8]
----------------------	---

LOADING (psf)	SPACING-	2-0-0	CSI.	DEFL.	in (loc)	I/defl	L/d	PLATES	GRIP
TCLL 20.0	Plate Grip DOL	1.25	TC 0.48	Vert(LL)	-0.16	19	>999	240	MT20
TCDL 7.0	Lumber DOL	1.25	BC 0.41	Vert(CT)	-0.31	19-20	>999	180	244/190
BCLL 0.0 *	Rep Stress Incr	YES	WB 0.87	Horz(CT)	0.17	15	n/a	n/a	
BCDL 10.0	Code FBC2020/TP12014		Matrix-MS						
								Weight: 410 lb	FT = 20%

LUMBER-
TOP CHORD 2x6 SP No.2
BOT CHORD 2x6 SP No.2
WEBS 2x4 SP No.3 *Except*
12-17: 2x4 SP No.2

WEDGE
Left: 2x4 SP No.3

REACTIONS. (lb/size) 23=2306/0-3-8 (min. 0-2-12), 15=2082/0-3-8 (min. 0-2-7)
Max Horz 23=170(LC 16)
Max Uplift 23=517(LC 12), 15=584(LC 9)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
TOP CHORD 2-30=-801/711, 3-30=-785/794, 3-4=-884/941, 4-5=-884/990, 5-6=-1620/299,
6-31=-2590/406, 7-31=-2518/425, 7-32=-2140/382, 8-32=-2212/363, 8-9=-2444/518,
9-10=-2531/507, 10-11=-2215/516, 11-12=-2041/429, 12-33=-1156/1048, 13-33=-1164/998
BOT CHORD 2-34=-657/787, 23-34=-657/787, 22-23=-115/625, 21-22=-302/2074, 20-21=-158/2076,
19-20=-242/2415, 18-19=-332/2135, 17-18=-318/1952, 16-17=-968/1170, 15-16=-968/1170,
15-35=-968/1170, 13-35=-968/1170
WEBS 3-23=-325/321, 5-23=-2409/696, 5-22=-233/1131, 6-22=-1139/390, 6-21=-74/476,
7-21=-179/1134, 7-20=-205/457, 8-20=-429/290, 10-19=-5/292, 10-18=-575/182,
11-17=-637/341, 12-17=-1087/2965, 12-15=-1850/775

NOTES-

- Unbalanced roof live loads have been considered for this design.
- Wind: ASCE 7-16; Vult=130mph (3-second gust) Vasd=101mph; TCDL=4.2psf; BCDL=3.0psf; h=20ft; Cat. II; Exp B; Encl., GCpi=0.18; MWFRS (envelope) gable end zone and C-C Exterior(2E) -2-0-0 to 3-7-10, Interior(1) 3-7-10 to 25-2-4, Exterior(2R) 25-2-4 to 30-9-14, Interior(1) 30-9-14 to 58-4-8 zone; cantilever left and right exposed ;C-C for members and forces & MWFRS for reactions shown; Lumber DOL=1.60 plate grip DOL=1.60
- Building Designer / Project engineer responsible for verifying applied roof live load shown covers rain loading requirements specific to the use of this truss component.
- This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
- * This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members.
- Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) except (jt=lb) 23=517, 15=584.

LOAD CASE(S) Standard

BRACING-
TOP CHORD Sheathed or 4-6-0 oc purlins.
BOT CHORD Rigid ceiling directly applied or 6-0-0 oc bracing.
WEBS 1 Row at midpt 5-23

MiTek recommends that Stabilizers and required cross bracing be installed during truss erection, in accordance with Stabilizer Installation guide.



Julius Lee PE No.34869
MiTek USA, Inc. FL Cert 6634
6904 Parke East Blvd. Tampa FL 33610
Date:

March 1,2021



WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 5/19/2020 BEFORE USE.

Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria, DSB-89 and BCSI Building Component Safety Information** available from Truss Plate Institute, 2670 Crain Highway, Suite 203 Waldorf, MD 20601



6904 Parke East Blvd.
Tampa, FL 33610

Job	Truss	Truss Type	Qty	Ply	WOODMAN PARK - WINNETTE RES.
2652828	T05	Roof Special	4	1	Job Reference (optional)

Builders FirstSource, Lake City, FL 32055

Run: 8.420 s Nov 10 2020 Print: 8.430 s Nov 30 2020 MiTek Industries, Inc. Mon Mar 1 15:23:09 2021 Page 1
ID: l6cHoKCOPy600ih9X8Oejzh775-YTNyLkKXRj48plgZ1nKS5xoqjOToMRwlv6AryzfGFG

2-0-0	6-0-0	8-3-8	12-6-0	18-10-8	25-2-4	31-6-2	38-3-8	43-4-8	50-2-12	56-4-8	58-4-8
2-0-0	6-0-0	2-3-8	4-2-8	6-4-8	6-3-12	6-3-14	6-9-6	5-1-0	6-10-4	6-1-12	2-0-0

Scale = 1:100.8




Plate Offsets (X,Y)~	[2:0-0-0,0-0-14], [5:0-4-0,0-4-8], [11:0-5-8,0-3-8], [19:0-5-8,0-3-8], [24:0-5-4,0-3-8]
----------------------	---

LOADING (psf)	SPACING-	CSL	DEFL.	in (loc)	I/defl	L/d	PLATES	GRIP
TCLL 20.0	Plate Grip DOL 1.25	TC 0.55	Vert(LL)	-0.09	22	>999	MT20	244/190
TCDL 7.0	Lumber DOL 1.25	BC 0.35	Vert(CT)	-0.18	22-23	>999		
BCLL 0.0 *	Rep Stress Incr YES	WB 0.72	Horz(CT)	0.11	16	n/a		
BCDL 10.0	Code FBC2020/TPI2014	Matrix-MS						
							Weight: 412 lb	FT = 20%

LUMBER-

TOP CHORD 2x6 SP No.2
BOT CHORD 2x6 SP No.2
WEBS 2x4 SP No.3
WEDGE
Left: 2x4 SP No.3

BRACING-

TOP CHORD Sheathed or 5-1-13 oc purlins.
BOT CHORD Rigid ceiling directly applied or 6-0-0 oc bracing.
WEBS 1 Row at midpt 5-24

MiTek recommends that Stabilizers and required cross bracing be installed during truss erection, in accordance with Stabilizer Installation guide.

REACTIONS. (lb/size) 24=2059/0-3-8 (min. 0-2-7), 16=2329/0-3-8 (min. 0-2-12)
Max Horz 24=170(LC 16)
Max Uplift 24=493(LC 12), 16=731(LC 9)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
TOP CHORD 2-31=-801/711, 3-31=-785/794, 3-4=-885/941, 4-5=-888/994, 5-6=-1160/255,
6-32=-1799/330, 7-32=-1727/348, 7-33=-1440/314, 8-33=-1514/296, 8-9=-1403/275,
9-10=-1490/263, 10-11=-757/171, 11-12=-2002/2085, 12-34=-1195/1219,
13-34=-1203/1169
BOT CHORD 2-35=-656/786, 24-35=-656/786, 23-24=-90/739, 22-23=-246/1490, 21-22=-92/1396,
20-21=-117/1403, 19-20=-67/792, 18-19=-699/1418, 17-18=-699/1418, 16-17=-700/1422,
15-16=-1134/1209, 15-36=-1134/1209, 13-36=-1134/1209
WEBS 3-24=-329/325, 5-24=-2014/513, 5-23=-123/892, 6-23=-853/258, 6-22=0/266,
7-22=-152/858, 8-20=-404/209, 10-20=-234/759, 10-19=-911/357, 11-19=-970/1519,
11-16=-2305/1068, 12-16=-904/891, 12-15=-273/206

NOTES-

- Unbalanced roof live loads have been considered for this design.
- Wind: ASCE 7-16; Vult=130mph (3-second gust) Vasd=101mph; TCCL=4.2psf; BCDL=3.0psf; h=20ft; Cat. II; Exp B; Encl., GCpi=0.18; MWFRS (envelope) gable end zone and C-C Exterior(2E) -2-0-0 to 3-7-10, Interior(1) 3-7-10 to 25-2-4, Exterior(2R) 25-2-4 to 30-9-14, Interior(1) 30-9-14 to 58-4-8 zone; cantilever left and right exposed ;C-C for members and forces & MWFRS for reactions shown; Lumber DOL=1.60 plate grip DOL=1.60
- Building Designer / Project engineer responsible for verifying applied roof live load shown covers rain loading requirements specific to the use of this truss component.
- All plates are 4x4 MT20 unless otherwise indicated.
- This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
- * This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members.
- Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) except (jt=lb) 24=493, 16=731.

LOAD CASE(S) Standard



Julius Lee PE No.34869
MiTek USA, Inc. FL Cert 6634
6904 Parke East Blvd. Tampa FL 33610
Date:

March 1, 2021




WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 5/19/2020 BEFORE USE.

Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria, DSB-89 and BCSI Building Component Safety Information** available from Truss Plate Institute, 2670 Crain Highway, Suite 203 Waldorf, MD 20601



6904 Parke East Blvd.
Tampa, FL 36610

Run: 8.420 s Nov 10 2020 Print: 8.430 s Nov 30 2020 MiTek Industries, Inc. Mon Mar 1 15:23:10 2021 Page 1
 ID: I6cHoKcOPy600ihh9X8Oejzh775-OfwwY4L9C0C?RvFibUrhe9LOYHiiXnC3zZrjNozfGFF




LUMBER-		BRACING-	
TOP CHORD	2x6 SP No.2	TOP CHORD	Sheathed or 4-6-0 oc purlins.
BOT CHORD	2x6 SP No.2 *Except*	BOT CHORD	Rigid ceiling directly applied or 6-0-0 oc bracing.
	18-24: 2x4 SP No.3	WEBS	1 Row at midpt 5-23
WEBS	2x4 SP No.3 *Except*		
	12-17: 2x4 SP No.2		
WEDGE			
Left: 2x4 SP No.3			

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.


TOP CHORD	2-32=-801/711, 3-32=-785/794, 3-4=-884/941, 4-5=-884/990, 5-6=-1620/299, 6-33=-2590/406, 7-33=-2518/425, 7-34=-2140/382, 8-34=-2212/363, 8-9=-2445/518, 9-10=-2531/507, 10-11=-2215/516, 11-12=-2041/429, 12-35=-1156/1048, 13-35=-1164/998
BOT CHORD	2-36=-657/787, 23-36=-657/787, 22-23=-115/625, 21-22=-302/2074, 20-21=-158/2076, 19-20=-242/2415, 18-19=-332/2135, 17-18=-318/1952, 16-17=-968/1170, 15-16=-968/1170, 15-37=-968/1170, 13-37=-968/1170
WEBS	3-23=-325/321, 5-23=-2409/696, 5-22=-233/1131, 6-22=-1139/390, 6-21=-74/476, 7-21=-179/1134, 7-20=-205/457, 8-20=-429/290, 10-19=-5/292, 10-18=-575/182, 11-17=-637/341, 12-17=-1087/2965, 12-15=-1850/775

- LOAD CASE(S) Standard





March 1, 2021

WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 5/19/2020 BEFORE USE. Design valid for use only with MITEK® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria, DSB-89 and BCSI Building Components Safety Information** available from Truss Plate Institute, 2670 Crain Highway, Suite 203 Waldorf, MD 20601



Symbols

PLATE LOCATION AND ORIENTATION




This symbol indicates the required direction of slots in connector plates.

* Plate location details available in MiTek 20/20 software or upon request.


PLATE SIZE

4 X 4
The first dimension is the plate width measured perpendicular to slots. Second dimension is the length parallel to slots.

LATERAL BRACING LOCATION




BEARING



Industry Standards:
ANSI/TP11: National Design Specification for Metal Plate Connected Wood Truss Construction.
DSB-89: Design Standard for Bracing.
BCSI: Building Component Safety Information, Guide to Good Practice for Handling, Installing & Bracing of Metal Plate Connected Wood Trusses.

Numbering System



JOINTS ARE GENERALLY NUMBERED/CLOCKWISE AROUND THE TRUSS STARTING AT THE JOINT FARTHEST TO THE LEFT.

CHORDS AND WEBS ARE IDENTIFIED BY END JOINT NUMBERS/LETTERS.

PRODUCT CODE APPROVALS

ICC-ES Reports:

ESR-1311, ESR-1352, ESR1988
ER-3907, ESR-2362, ESR-1397, ESR-3282

Trusses are designed for wind loads in the plane of the truss unless otherwise shown.

Lumber design values are in accordance with ANSI/TP1 1 section 6.3. These truss designs rely on lumber values established by others.

© 2012 MiTek® All Rights Reserved



MiTek Engineering Reference Sheet: MIL-7473 rev. 5/19/2020

General Safety Notes

Failure to Follow Could Cause Property Damage or Personal Injury


1. Additional stability bracing for truss system, e.g. diagonal or X-bracing, is always required. See BCSI.
2. Truss bracing must be designed by an engineer. For wide truss spacing, individual lateral braces themselves may require bracing, or alternative Tor I bracing should be considered.
3. Never exceed the design loading shown and never stack materials on inadequately braced trusses.
4. Provide copies of this truss design to the building designer, erection supervisor, property owner and all other interested parties.
5. Cut members to bear tightly against each other.
6. Place plates on each face of truss at each joint and embed fully. Knots and wane at joint locations are regulated by ANSI/TP1 1.
7. Design assumes trusses will be suitably protected from the environment in accord with ANSI/TP1 1.
8. Unless otherwise noted, moisture content of lumber shall not exceed 19% at time of fabrication.
9. Unless expressly noted, this design is not applicable for use with fire retardant, preservative treated, or green lumber.
10. Camber is a non-structural consideration and is the responsibility of truss fabricator. General practice is to camber for dead load deflection.
11. Plate type, size, orientation and location dimensions indicated are minimum plating requirements.
12. Lumber used shall be of the species and size, and in all respects, equal to or better than that specified.
13. Top chords must be sheathed or purlins provided at spacing indicated on design.
14. Bottom chords require lateral bracing at 10 ft. spacing, or less, if no ceiling is installed, unless otherwise noted.
15. Connections not shown are the responsibility of others.
16. Do not cut or alter truss member or plate without prior approval of an engineer.
17. Install and load vertically unless indicated otherwise.
18. Use of green or treated lumber may pose unacceptable environmental, health or performance risks. Consult with project engineer before use.
19. Review all portions of this design (front, back, words and pictures) before use. Reviewing pictures alone is not sufficient.
20. Design assumes manufacture in accordance with ANSI/TP1 1 Quality Criteria.
21. The design does not take into account any dynamic or other loads other than those expressly stated.

AUGUST 1, 2016

T-BRACE / I-BRACE DETAIL WITH 2X BRACE ONLY

MII-T-BRACE 2

MiTek USA, Inc. Page 1 of 1



MiTek USA, Inc.

ENGINEERED BY
TRENCO
A MiTek Affiliate

Note: T-Bracing / I-Bracing to be used when continuous lateral bracing is impractical. T-Brace / I-Brace must cover 90% of web length.

Note: This detail NOT to be used to convert T-Brace / I-Brace webs to continuous lateral braced webs.

Nailing Pattern

T-Brace size	Nail Size	Nail Spacing
2x4 or 2x6 or 2x8	10d (0.131" X 3")	6" o.c.

Note: Nail along entire length of T-Brace / I-Brace
(On Two-Ply's Nail to Both Plies)

Brace Size for One-Ply Truss

Specified Continuous Rows of Lateral Bracing




Web Size	1	2
2x3 or 2x4	2x4 T-Brace	2x4 I-Brace
2x6	2x6 T-Brace	2x6 I-Brace
2x8	2x8 T-Brace	2x8 I-Brace

Brace Size for Two-Ply Truss

Specified Continuous Rows of Lateral Bracing

Web Size	1	2
2x3 or 2x4	2x4 T-Brace	2x4 I-Brace
2x6	2x6 T-Brace	2x6 I-Brace
2x8	2x8 T-Brace	2x8 I-Brace

T-Brace / I-Brace must be same species and grade (or better) as web member.



Thomas A. Albani PE No. 39380
MiTek USA, Inc. FL Cert 6634
6904 Parke East Blvd. Tampa FL 33610
Date:

February 12, 2018


AUGUST 1, 2016

SCAB-BRACE DETAIL

MII-SCAB-BRACE

MiTek USA, Inc.


Page 1 of 1




Note: Scab-Bracing to be used when continuous lateral bracing at midpoint (or T-Brace) is impractical.
Scab must cover full length of web +/- 6".

*** THIS DETAIL IS NOT APPLICABLE WHEN BRACING IS REQUIRED AT 1/3 POINTS OR I-BRACE IS SPECIFIED.

APPLY 2x SCAB TO ONE FACE OF WEB WITH 2 ROWS OF 10d (0.131" X 3") NAILS SPACED 6" O.C. SCAB MUST BE THE SAME GRADE, SIZE AND SPECIES (OR BETTER) AS THE WEB.




Scab-Brace must be same species grade (or better) as web member.




Thomas A. Albani PE No.39380
MiTek USA, Inc. FL Cert 6634
6904 Parke East Blvd. Tampa FL 33610
Date:


February 12, 2018



1. THIS IS A SPECIFIC REPAIR DETAIL TO BE USED ONLY FOR ITS ORIGINAL INTENTION. THIS REPAIR DOES NOT IMPLY THAT THE REMAINING PORTION OF THE TRUSS IS UNDAMAGED. THE ENTIRE TRUSS SHALL BE INSPECTED TO VERIFY THAT NO FURTHER REPAIRS ARE REQUIRED. WHEN THE REQUIRED REPAIRS ARE PROPERLY APPLIED, THE TRUSS WILL BE CAPABLE OF SUPPORTING THE LOADS INDICATED.
2. ALL MEMBERS MUST BE RETURNED TO THEIR ORIGINAL POSITIONS BEFORE APPLYING REPAIR AND HELD IN PLACE DURING APPLICATION OF REPAIR.
3. THE END DISTANCE, EDGE DISTANCE, AND SPACING OF NAILS SHALL BE SUCH AS TO AVOID SPLITTING OF THE WOOD.
4. LUMBER MUST BE CUT CLEANLY AND ACCURATELY AND THE REMAINING WOOD MUST BE UNDAMAGED.
5. THIS REPAIR IS TO BE USED FOR SINGLE PLY TRUSSES IN THE 4X ORIENTATION ONLY.
6. CONNECTOR PLATES MUST BE FULLY IMBEDDED AND UNDISTURBED.




REFER TO INDIVIDUAL
TRUSS DESIGN FOR
PLATE SIZES AND
LUMBER GRADES



TRUSSES BUILT
WITH 4x2 MEMBERS



REFER TO INDIVIDUAL
TRUSS DESIGN FOR
PLATE SIZES AND
LUMBER GRADES







TRUSSES BUILT
WITH 4x2 MEMBERS

ATTACH 2x4 SQUASH BLOCK (CUT TO FIT TIGHTLY)
TO BOTH SIDES OF THE TRUSS AS SHOWN WITH
10d (0.131" X 3") NAILS SPACED 3" O.C.



Thomas A. Albani PE No. 39380
MiTek USA, Inc. FL Cert 6634
6904 Parke East Blvd. Tampa FL 33610
Date:

February 12, 2018



NOTE:



1. MINIMUM GRADE OF #2 MATERIAL IN THE TOP AND BOTTOM CHORDS.
2. CONNECTION BETWEEN BOTTOM CHORD OF GABLE END TRUSS AND WALL TO BE PROVIDED BY PROJECT ENGINEER OR ARCHITECT.
3. BRACING SHOWN IS FOR INDIVIDUAL TRUSS ONLY. CONSULT BLDG. ARCHITECT OR ENGINEER FOR TEMPORARY AND PERMANENT BRACING OF ROOF SYSTEM.
4. "L" BRACES SPECIFIED ARE TO BE FULL LENGTH. GRADES: 1x4 SRB OR 2x4 STUD OR BETTER WITH ONE ROW OF 10d NAILS SPACED 6" O.C.
5. DIAGONAL BRACE TO BE APPROXIMATELY 45 DEGREES TO ROOF DIAPHRAM AT 4'-0" O.C.
6. CONSTRUCT HORIZONTAL BRACE CONNECTING A 2x6 STUD AND A 2x4 STUD AS SHOWN WITH 16d NAILS SPACED 6" O.C. HORIZONTAL BRACE TO BE LOCATED AT THE MIDSPAN OF THE LONGEST STUD. ATTACH TO VERTICAL STUDS WITH (4) 10d NAILS THROUGH 2x4. (REFER TO SECTION A-A)
7. GABLE STUD DEFLECTION MEETS OR EXCEEDS $L/240$.
8. THIS DETAIL DOES NOT APPLY TO STRUCTURAL GABLES.
9. DO NOT USE FLAT BOTTOM CHORD GABLES NEXT TO SCISSOR TYPE TRUSSES.
10. SOUTHERN PINE LUMBER DESIGN VALUES ARE THOSE EFFECTIVE 06-01-13 BY SPIB/ALSC.
11. NAILS DESIGNATED 10d ARE (0.131" X 3") AND NAILS DESIGNATED 16d ARE (0.131" X 3.5")

Minimum Stud Size Species and Grade	Stud Spacing	Without Brace	1x4 L-Brace	2x4 L-Brace	DIAGONAL BRACE	2 DIAGONAL BRACES AT 1/3 POINTS
		Maximum Stud Length				
2x4 SP No. 3 / Stud	12" O.C.	3-9-13	4-1-1	5-9-6	7-1-3	11-5-7
2x4 SP No. 3 / Stud	16" O.C.	3-5-4	3-6-8	5-0-2	6-10-8	10-3-13
2x4 SP No. 3 / Stud	24" O.C.	2-9-11	2-10-11	4-1-1	5-7-6	8-5-1

- * Diagonal braces over 6'-3" require a 2x4 T-Brace attached to one edge. Diagonal braces over 12'-6" require 2x4 I-braces attached to both edges. Fasten T and I braces to narrow edge of diagonal brace with 10d nails 8" o.c., with 3" minimum end distance. Brace must cover 90% of diagonal length.





MAX MEAN ROOF HEIGHT = 30 FEET
CATEGORY II BUILDING
EXPOSURE D
ASCE 7-98, ASCE 7-02, ASCE 7-05 130 MPH
ASCE 7-10 160 MPH
DURATION OF LOAD INCREASE : 1.60

STUD DESIGN IS BASED ON COMPONENTS AND CLADDING.
CONNECTION OF BRACING IS BASED ON MWFRS.



Thomas A. Albani PE No.39380
MiTek USA, Inc. FL Cert 6634
6904 Parke East Blvd. Tampa FL 33610
Date:

February 12, 2018




NOTE:

1. MINIMUM GRADE OF #2 MATERIAL IN THE TOP AND BOTTOM CHORDS.
2. CONNECTION BETWEEN BOTTOM CHORD OF GABLE END TRUSS AND WALL TO BE PROVIDED BY PROJECT ENGINEER OR ARCHITECT.
3. BRACING SHOWN IS FOR INDIVIDUAL TRUSS ONLY. CONSULT BLDG. ARCHITECT OR ENGINEER FOR TEMPORARY AND PERMANENT BRACING OF ROOF SYSTEM.
4. "L" BRACES SPECIFIED ARE TO BE FULL LENGTH. GRADES: 1x4 SRB OR 2x4 STUD OR BETTER WITH ONE ROW OF 10d NAILS SPACED 6" O.C.
5. DIAGONAL BRACE TO BE APPROXIMATELY 45 DEGREES TO ROOF DIAPHRAM AT 4'-0" O.C.
6. CONSTRUCT HORIZONTAL BRACE CONNECTING A 2x6 STUD AND A 2x4 STUD AS SHOWN WITH 16d NAILS SPACED 6" O.C. HORIZONTAL BRACE TO BE LOCATED AT THE MIDSPAN OF THE LONGEST STUD. ATTACH TO VERTICAL STUDS WITH (4) 10d NAILS THROUGH 2x4. (REFER TO SECTION A-A)
7. GABLE STUD DEFLECTION MEETS OR EXCEEDS L/240.
8. THIS DETAIL DOES NOT APPLY TO STRUCTURAL GABLES.
9. DO NOT USE FLAT BOTTOM CHORD GABLES NEXT TO SCISSOR TYPE TRUSSES.
10. SOUTHERN PINE LUMBER DESIGN VALUES ARE THOSE EFFECTIVE 06-01-13 BY SPIB/ALSC.
11. NAILS DESIGNATED 10d ARE (0.131" X 3") AND NAILS DESIGNATED 16d ARE (0.131" X 3.5")

PROVIDE 2x4 BLOCKING BETWEEN THE FIRST TWO TRUSSES AS NOTED. TOENAIL BLOCKING TO TRUSSES WITH (2) - 10d NAILS AT EACH END. ATTACH DIAGONAL BRACE TO BLOCKING WITH (5) - 10d NAILS.

(4) - 8d (0.131" X 2.5") NAILS MINIMUM, PLYWOOD SHEATHING TO 2x4 STD SPF BLOCK



Minimum Stud Size Species and Grade	Stud Spacing	Without Brace	1x4 L-Brace	2x4 L-Brace	DIAGONAL BRACE	2 DIAGONAL BRACES AT 1/3 POINTS
		Maximum Stud Length				
2x4 SP No. 3 / Stud	12" O.C.	4-0-7	4-5-6	6-3-8	8-0-15	12-1-6
2x4 SP No. 3 / Stud	16" O.C.	3-8-0	3-10-4	5-5-6	7-4-1	11-0-1
2x4 SP No. 3 / Stud	24" O.C.	3-0-10	3-1-12	4-5-6	6-1-5	9-1-15

- * Diagonal braces over 6'-3" require a 2x4 T-Brace attached to one edge. Diagonal braces over 12'-6" require 2x4 I-braces attached to both edges. Fasten T and I braces to narrow edge of diagonal brace with 10d nails 8" o.c., with 3" minimum end distance. Brace must cover 90% of diagonal length.





MAX MEAN ROOF HEIGHT = 30 FEET
CATEGORY II BUILDING
EXPOSURE B or C
ASCE 7-98, ASCE 7-02, ASCE 7-05 130 MPH
ASCE 7-10 160 MPH
DURATION OF LOAD INCREASE : 1.60

STUD DESIGN IS BASED ON COMPONENTS AND CLADDING.
CONNECTION OF BRACING IS BASED ON MWFRS.



Thomas A. Albani PE No.39380
MiTek USA, Inc. FL Cert 6634
6904 Parke East Blvd. Tampa FL 33610
Date:

February 12, 2018




NOTE:

1. MINIMUM GRADE OF #2 MATERIAL IN THE TOP AND BOTTOM CHORDS.
2. CONNECTION BETWEEN BOTTOM CHORD OF GABLE END TRUSS AND WALL TO BE PROVIDED BY PROJECT ENGINEER OR ARCHITECT.
3. BRACING SHOWN IS FOR INDIVIDUAL TRUSS ONLY. CONSULT BLDG. ARCHITECT OR ENGINEER FOR TEMPORARY AND PERMANENT BRACING OF ROOF SYSTEM.
4. "L" BRACES SPECIFIED ARE TO BE FULL LENGTH. GRADES: 1x4 SRB OR 2x4 STUD OR BETTER WITH ONE ROW OF 10d NAILS SPACED 6" O.C.
5. DIAGONAL BRACE TO BE APPROXIMATELY 45 DEGREES TO ROOF DIAPHRAM AT 4'-0" O.C.
6. CONSTRUCT HORIZONTAL BRACE CONNECTING A 2x6 STUD AND A 2x4 STUD AS SHOWN WITH 16d NAILS SPACED 6" O.C. HORIZONTAL BRACE TO BE LOCATED AT THE MIDSPAN OF THE LONGEST STUD. ATTACH TO VERTICAL STUDS WITH (4) 10d NAILS THROUGH 2x4. (REFER TO SECTION A-A)
7. GABLE STUD DEFLECTION MEETS OR EXCEEDS L/240.
8. THIS DETAIL DOES NOT APPLY TO STRUCTURAL GABLES.
9. DO NOT USE FLAT BOTTOM CHORD GABLES NEXT TO SCISSOR TYPE TRUSSES.
10. NAILS DESIGNATED 10d ARE (0.131" X 3") AND NAILS DESIGNATED 16d ARE (0.131" X 3.5")

PROVIDE 2x4 BLOCKING BETWEEN THE FIRST TWO TRUSSES AS NOTED. TOENAIL BLOCKING TO TRUSSES WITH (2) - 10d NAILS AT EACH END. ATTACH DIAGONAL BRACE TO BLOCKING WITH (5) - 10d NAILS.

(4) - 8d (0.131" X 2.5") NAILS MINIMUM, PLYWOOD SHEATHING TO 2x4 STD DF/SPF BLOCK



Minimum Stud Size Species and Grade	Stud Spacing	Without Brace	1x4 L-Brace	2x4 L-Brace	DIAGONAL BRACE	2 DIAGONAL BRACES AT 1/3 POINTS
			Maximum Stud Length			
2x4 DF/SPF Std/Stud	12" O.C.	3-10-1	3-11-7	5-7-2	7-8-2	11-6-4
2x4 DF/SPF Std/Stud	16" O.C.	3-3-14	3-5-1	4-10-2	6-7-13	9-11-11
2x4 DF/SPF Std/Stud	24" O.C.	2-8-9	2-9-8	3-11-7	5-5-2	8-1-12

- * Diagonal braces over 6'-3" require a 2x4 T-Brace attached to one edge. Diagonal braces over 12'-6" require 2x4 I-braces attached to both edges. Fasten T and I braces to narrow edge of web with 10d nails 8" o.c., with 3" minimum end distance. Brace must cover 90% of diagonal length.


MAXIMUM WIND SPEED = 140 MPH
MAX MEAN ROOF HEIGHT = 30 FEET
CATEGORY II BUILDING
EXPOSURE B or C
ASCE 7-98, ASCE 7-02, ASCE 7-05
DURATION OF LOAD INCREASE : 1.60

STUD DESIGN IS BASED ON COMPONENTS AND CLADDING.
CONNECTION OF BRACING IS BASED ON MWFRS.



Thomas A. Albani PE No.39380
MiTek USA, Inc. FL Cert 6634
6904 Parke East Blvd. Tampa FL 33610
Date:

January 19, 2018



MiTek USA, Inc.

ENGINEERED BY
TRENCO
 A MiTek Affiliate


 Typical 2x4 L-Brace Nailed To
 2x4 Verticals w/10d Nails spaced 6" o.c.

Vertical Stud

SECTION B-B


 TRUSS GEOMETRY AND CONDITIONS
 SHOWN ARE FOR ILLUSTRATION ONLY.

Varies to Common Truss

 SEE INDIVIDUAL MITTEK ENGINEERING
 DRAWINGS FOR DESIGN CRITERIA


SECTION A-A

 PROVIDE 2x4 BLOCKING BETWEEN THE FIRST
 TWO TRUSSES AS NOTED. TOENAIL BLOCKING
 TO TRUSSES WITH (2) - 10d NAILS AT EACH END.
 ATTACH DIAGONAL BRACE TO BLOCKING WITH
 (5) - 10d NAILS.

 (4) - 8d (0.131" X 2.5") NAILS MINIMUM, PLYWOOD
 SHEATHING TO 2x4 STD SPF BLOCK

 * - Diagonal Bracing
 Refer to Section A-A

 ** - L-Bracing Refer
 to Section B-B

NOTE:

1. MINIMUM GRADE OF #2 MATERIAL IN THE TOP AND BOTTOM CHORDS.
2. CONNECTION BETWEEN BOTTOM CHORD OF GABLE END TRUSS AND WALL TO BE PROVIDED BY PROJECT ENGINEER OR ARCHITECT.
3. BRACING SHOWN IS FOR INDIVIDUAL TRUSS ONLY. CONSULT BLDG. ARCHITECT OR ENGINEER FOR TEMPORARY AND PERMANENT BRACING OF ROOF SYSTEM.
4. "L" BRACES SPECIFIED ARE TO BE FULL LENGTH, SPF or SP No.3 OR BETTER WITH ONE ROW OF 10d NAILS SPACED 6" O.C.
5. DIAGONAL BRACE TO BE APPROXIMATELY 45 DEGREES TO ROOF DIAPHRAM AT 4'-0" O.C.
6. CONSTRUCT HORIZONTAL BRACE CONNECTING A 2x6 AND A 2x4 AS SHOWN WITH 16d NAILS SPACED 6" O.C. HORIZONTAL BRACE TO BE LOCATED AT THE MIDSPAN OF THE LONGEST GABLE STUD. ATTACH TO VERTICAL GABLE STUDS WITH (4) 10d NAILS THROUGH 2x4. (REFER TO SECTION A-A)
7. GABLE STUD DEFLECTION MEETS OR EXCEEDS L/240.
8. THIS DETAIL DOES NOT APPLY TO STRUCTURAL GABLES.
9. DO NOT USE FLAT BOTTOM CHORD GABLES NEXT TO SCISSOR TYPE TRUSSES.
10. SOUTHERN PINE LUMBER DESIGN VALUES ARE THOSE EFFECTIVE 06-01-13 BY SPIB/ALSC.
11. NAILS DESIGNATED 10d ARE (0.131" X 3") AND NAILS DESIGNATED 16d ARE (0.131" X 3.5")

Minimum Stud Size Species and Grade	Stud Spacing	Without Brace	2x4 L-Brace	DIAGONAL BRACE	2 DIAGONAL BRACES AT 1/3 POINTS
		Maximum Stud Length			
2x4 SP No. 3 / Stud	12" O.C.	3-9-7	5-8-8	6-11-1	11-4-4
2x4 SP No. 3 / Stud	16" O.C.	3-4-12	4-11-15	6-9-8	10-2-3
2x4 SP No. 3 / Stud	24" O.C.	2-9-4	4-0-7	5-6-8	8-3-13
2x4 SP No. 2	12" O.C.	3-11-13	5-8-8	6-11-1	11-11-7
2x4 SP No. 2	16" O.C.	3-7-7	4-11-5	6-11-1	10-10-5
2x4 SP No. 2	24" O.C.	3-1-15	4-0-7	6-3-14	9-5-14


- * Diagonal braces over 6'-3" require a 2x4 T-Brace attached to one edge. Diagonal braces over 12'-6" require 2x4 I-braces attached to both edges. Fasten T and I braces to narrow edge of diagonal brace with 10d nails 6" o.c., with 3" minimum end distance. Brace must cover 90% of diagonal length. T or I braces must be 2x4 SPF No. 2 or SP No. 2.

 MAX MEAN ROOF HEIGHT = 30 FEET
 EXPOSURE D
 ASCE 7-10 170 MPH
 DURATION OF LOAD INCREASE : 1.60

 STUD DESIGN IS BASED ON COMPONENTS AND CLADDING.
 CONNECTION OF BRACING IS BASED ON MWFRS.

 Thomas A. Albani PE No.39380
 MiTek USA, Inc. FL Cert 6634
 6904 Parke East Blvd. Tampa FL 33610
 Date:

February 12, 2018



NOTE:


1. MINIMUM GRADE OF #2 MATERIAL IN THE TOP AND BOTTOM CHORDS.
2. CONNECTION BETWEEN BOTTOM CHORD OF GABLE END TRUSS AND WALL TO BE PROVIDED BY PROJECT ENGINEER OR ARCHITECT.
3. BRACING SHOWN IS FOR INDIVIDUAL TRUSS ONLY. CONSULT BLDG. ARCHITECT OR ENGINEER FOR TEMPORARY AND PERMANENT BRACING OF ROOF SYSTEM.
4. "L" BRACES SPECIFIED ARE TO BE FULL LENGTH, SPF or SP No.3 OR BETTER WITH ONE ROW OF 10d NAILS SPACED 6" O.C.
5. DIAGONAL BRACE TO BE APPROXIMATELY 45 DEGREES TO ROOF DIAPHRAM AT 4'-0" O.C.
6. CONSTRUCT HORIZONTAL BRACE CONNECTING A 2x6 AND A 2x4 AS SHOWN WITH 16d NAILS SPACED 6" O.C. HORIZONTAL BRACE TO BE LOCATED AT THE MIDSPAN OF THE LONGEST GABLE STUD. ATTACH TO VERTICAL GABLE STUDS WITH (4) 10d NAILS THROUGH 2x4. (REFER TO SECTION A-A)
7. GABLE STUD DEFLECTION MEETS OR EXCEEDS L/240.
8. THIS DETAIL DOES NOT APPLY TO STRUCTURAL GABLES.
9. DO NOT USE FLAT BOTTOM CHORD GABLES NEXT TO SCISSOR TYPE TRUSSES.
10. SOUTHERN PINE LUMBER DESIGN VALUES ARE THOSE EFFECTIVE 06-01-13 BY SPIB/ALSC.
11. NAILS DESIGNATED 10d ARE (0.131" X 3") AND NAILS DESIGNATED 16d ARE (0.131" X 3.5")

Minimum Stud Size Species and Grade	Stud Spacing	Without Brace	2x4 L-Brace	DIAGONAL BRACE	2 DIAGONAL BRACES AT 1/3 POINTS
		Maximum Stud Length			
2x4 SP No. 3 / Stud	12" O.C.	3-7-12	5-4-11	6-2-1	10-11-3
2x4 SP No. 3 / Stud	16" O.C.	3-2-8	4-8-1	6-2-1	9-7-7
2x4 SP No. 3 / Stud	24" O.C.	2-7-7	3-9-12	5-2-13	7-10-4
2x4 SP No. 2	12" O.C.	3-10-0	5-4-11	6-2-1	11-6-1
2x4 SP No. 2	16" O.C.	3-5-13	4-8-1	6-2-1	10-5-7
2x4 SP No. 2	24" O.C.	3-0-8	3-9-12	6-1-1	9-1-9

* Diagonal braces over 6'-3" require a 2x4 T-Brace attached to one edge. Diagonal braces over 12'-6" require 2x4 I-braces attached to both edges. Fasten T and I braces to narrow edge of diagonal brace with 10d nails 6in o.c., with 3in minimum end distance. Brace must cover 90% of diagonal length. T or I braces must be 2x4 SPF No. 2 or SP No. 2.



MAX MEAN ROOF HEIGHT = 30 FEET
EXPOSURE D
ASCE 7-10 180 MPH
DURATION OF LOAD INCREASE : 1.60

STUD DESIGN IS BASED ON COMPONENTS AND CLADDING.
CONNECTION OF BRACING IS BASED ON MWERS.




PROVIDE 2x4 BLOCKING BETWEEN THE FIRST TWO TRUSSES AS NOTED. TOENAIL BLOCKING TO TRUSSES WITH (2) - 10d NAILS AT EACH END. ATTACH DIAGONAL BRACE TO BLOCKING WITH (5) - 10d NAILS.

(4) - 8d (0.131" X 2.5") NAILS MINIMUM, PLYWOOD SHEATHING TO 2x4 STD SPF BLOCK



Thomas A. Albani PE No.39380
MiTek USA, Inc. FL Cert 6634
6904 Parke East Blvd. Tampa FL 33610
Date:

February 12, 2018




MiTek USA, Inc.

ENGINEERED BY
TRENCO
 A MiTek Affiliate

MAXIMUM WIND SPEED = REFER TO NOTES D AND OR E
 MAX MEAN ROOF HEIGHT = 30 FEET
 MAX TRUSS SPACING = 24" O.C.
 CATEGORY II BUILDING
 EXPOSURE B or C
 ASCE 7-10
 DURATION OF LOAD INCREASE : 1.60

DETAIL IS NOT APPLICABLE FOR TRUSSES
 TRANSFERRING DRAG LOADS (SHEAR TRUSSES).
 ADDITIONAL CONSIDERATIONS BY BUILDING
 ENGINEER/DESIGNER ARE REQUIRED.


- A - PIGGYBACK TRUSS, REFER TO MITEK TRUSS DESIGN DRAWING. SHALL BE CONNECTED TO EACH PURLIN WITH (2) (0.131" X 3.5") TOE-NAILED.
- B - BASE TRUSS, REFER TO MITEK TRUSS DESIGN DRAWING.
- C - PURLINS AT EACH BASE TRUSS JOINT AND A MAXIMUM 24" O.C. UNLESS SPECIFIED CLOSER ON MITEK TRUSS DESIGN DRAWING. CONNECT TO BASE TRUSS WITH (2) (0.131" X 3.5") NAILS EACH.
- D - 2 x ____ x 4'-0" SCAB, SIZE TO MATCH TOP CHORD OF PIGGYBACK TRUSS, MIN GRADE #2, ATTACHED TO ONE FACE, CENTERED ON INTERSECTION, WITH (2) ROWS OF (0.131" X 3") NAILS @ 4" O.C. SCAB MAY BE OMITTED PROVIDED THE TOP CHORD SHEATHING IS CONTINUOUS OVER INTERSECTION AT LEAST 1 FT. IN BOTH DIRECTIONS AND:
1. WIND SPEED OF 115 MPH OR LESS FOR ANY PIGGYBACK SPAN, OR
 2. WIND SPEED OF 116 MPH TO 160 MPH WITH A MAXIMUM PIGGYBACK SPAN OF 12 ft.
- E - FOR WIND SPEEDS BETWEEN 126 AND 160 MPH, ATTACH MITEK 3X8 20 GA Nail-On PLATES TO EACH FACE OF TRUSSES AT 72" O.C. W/ (4) (0.131" X 1.5") NAILS PER MEMBER. STAGGER NAILS FROM OPPOSING FACES. ENSURE 0.5" EDGE DISTANCE. (MIN. 2 PAIRS OF PLATES REQ. REGARDLESS OF SPAN)




WHEN NO GAP BETWEEN PIGGYBACK AND BASE TRUSS EXISTS:

REPLACE TOE NAILING OF PIGGYBACK TRUSS TO PURLINS WITH Nail-On PLATES AS SHOWN, AND INSTALL PURLINS TO BOTTOM EDGE OF BASE TRUSS TOP CHORD AT SPECIFIED SPACING SHOWN ON BASE TRUSS MITEK DESIGN DRAWING.

SCAB CONNECTION PER
NOTE D ABOVE




FOR ALL WIND SPEEDS, ATTACH MITEK 3X6 20 GA Nail-On PLATES TO EACH FACE OF TRUSSES AT 48" O.C. W/ (4) (0.131" X 1.5") PER MEMBER. STAGGER NAILS FROM OPPOSING FACES ENSURE 0.5" EDGE DISTANCE.



This sheet is provided as a Piggyback connection detail only. Building Designer is responsible for all permanent bracing per standard engineering practices or refer to BCSI for general guidance on lateral restraint and diagonal bracing requirements.

VERTICAL WEB TO
EXTEND THROUGH
BOTTOM CHORD
OF PIGGYBACK



FOR LARGE CONCENTRATED LOADS APPLIED
TO CAP TRUSS REQUIRING A VERTICAL WEB:

- 1) VERTICAL WEBS OF PIGGYBACK AND BASE TRUSS MUST MATCH IN SIZE, GRADE, AND MUST LINE UP AS SHOWN IN DETAIL.
- 2) ATTACH 2 x ____ x 4'-0" SCAB TO EACH FACE OF TRUSS ASSEMBLY WITH 2 ROWS OF 10d (0.131" X 3") NAILS SPACED 4" O.C. FROM EACH FACE. (SIZE AND GRADE TO MATCH VERTICAL WEBS OF PIGGYBACK AND BASE TRUSS.) (MINIMUM 2X4)
- 3) THIS CONNECTION IS ONLY VALID FOR A MAXIMUM CONCENTRATED LOAD OF 4000 LBS (@1.15). REVIEW BY A QUALIFIED ENGINEER IS REQUIRED FOR LOADS GREATER THAN 4000 LBS.
- 4) FOR PIGGYBACK TRUSSES CARRYING GIRDER LOADS, NUMBER OF PLYS OF PIGGYBACK TRUSS TO MATCH BASE TRUSS.
- 5) CONCENTRATED LOAD MUST BE APPLIED TO BOTH THE PIGGYBACK AND THE BASE TRUSS DESIGN.



Thomas A. Albani PE No.39380
 MiTek USA, Inc. FL Cert 6634
 6904 Parke East Blvd. Tampa FL 33610
 Date:


February 12, 2018

AUGUST 1, 2016

STANDARD PIGGYBACK TRUSS CONNECTION DETAIL

MII-PIGGY-ALT
7-10

MiTek USA, Inc. Page 1 of 1




MiTek USA, Inc.



MAXIMUM WIND SPEED = REFER TO NOTES D AND OR E
MAX MEAN ROOF HEIGHT = 30 FEET
MAX TRUSS SPACING = 24" O.C.
CATEGORY II BUILDING
EXPOSURE B or C
ASCE 7-10
DURATION OF LOAD INCREASE : 1.60

DETAIL IS NOT APPLICABLE FOR TRUSSES
TRANSFERING DRAG LOADS (SHEAR TRUSSES).
ADDITIONAL CONSIDERATIONS BY BUILDING
ENGINEER/DESIGNER ARE REQUIRED.


- A - PIGGYBACK TRUSS, REFER TO MITEK TRUSS DESIGN DRAWING. SHALL BE CONNECTED TO EACH PURLIN WITH (2) 0(0.131" X 3.5") TOE-NAILED.
- B - BASE TRUSS, REFER TO MITEK TRUSS DESIGN DRAWING.
- C - PURLINS AT EACH BASE TRUSS JOINT AND A MAXIMUM 24" O.C. UNLESS SPECIFIED CLOSER ON MITEK TRUSS DESIGN DRAWING. CONNECT TO BASE TRUSS WITH (2) (0.131" X 3.5") NAILS EACH.
- D - 2 X ____ X 4'-0" SCAB, SIZE TO MATCH TOP CHORD OF PIGGYBACK TRUSS, MIN GRADE #2, ATTACHED TO ONE FACE, CENTERED ON INTERSECTION, WITH (2) ROWS OF (0.131" X 3") NAILS @ 4" O.C. SCAB MAY BE OMITTED PROVIDED THE TOP CHORD SHEATHING IS CONTINUOUS OVER INTERSECTION AT LEAST 1 FT. IN BOTH DIRECTIONS AND:
1. WIND SPEED OF 115 MPH OR LESS FOR ANY PIGGYBACK SPAN, OR
 2. WIND SPEED OF 116 MPH TO 160 MPH WITH A MAXIMUM PIGGYBACK SPAN OF 12 ft.
- E - FOR WIND SPEED IN THE RANGE 126 MPH - 160 MPH ADD 9" x 9" x 1/2" PLYWOOD (or 7/16" OSB) GUSSET EACH SIDE AT 48" O.C. OR LESS. ATTACH WITH 3 - 6d (0.113" X 2") NAILS INTO EACH CHORD FROM EACH SIDE (TOTAL - 12 NAILS)




WHEN NO GAP BETWEEN PIGGYBACK AND BASE TRUSS EXISTS:

REPLACE TOE NAILING OF PIGGYBACK TRUSS TO PURLINS WITH PLYWOOD GUSSETS AS SHOWN, AND INSTALL PURLINS TO BOTTOM EDGE OF BASE TRUSS TOP CHORD AT SPECIFIED SPACING SHOWN ON BASE TRUSS MITEK DESIGN DRAWING.

SCAB CONNECTION PER
NOTE D ABOVE




7" x 7" x 1/2" PLYWOOD (or 7/16" OSB) GUSSET EACH SIDE AT 24" O.C. ATTACH WITH 3 - 6d (0.113" X 2") NAILS INTO EACH CHORD FROM EACH SIDE (TOTAL - 12 NAILS)




This sheet is provided as a Piggyback connection detail only. Building Designer is responsible for all permanent bracing per standard engineering practices or refer to BCSI for general guidance on lateral restraint and diagonal bracing requirements.

VERTICAL WEB TO
EXTEND THROUGH
BOTTOM CHORD
OF PIGGYBACK




FOR LARGE CONCENTRATED LOADS APPLIED
TO CAP TRUSS REQUIRING A VERTICAL WEB:

- 1) VERTICAL WEBS OF PIGGYBACK AND BASE TRUSS MUST MATCH IN SIZE, GRADE, AND MUST LINE UP AS SHOWN IN DETAIL.
- 2) ATTACH 2 x ____ x 4'-0" SCAB TO EACH FACE OF TRUSS ASSEMBLY WITH 2 ROWS OF 10d (0.131" X 3") NAILS SPACED 4" O.C. FROM EACH FACE. (SIZE AND GRADE TO MATCH VERTICAL WEBS OF PIGGYBACK AND BASE TRUSS.) (MINIMUM 2X4)
- 3) THIS CONNECTION IS ONLY VALID FOR A MAXIMUM CONCENTRATED LOAD OF 4000 LBS (@1.15). REVIEW BY A QUALIFIED ENGINEER IS REQUIRED FOR LOADS GREATER THAN 4000 LBS.
- 4) FOR PIGGYBACK TRUSSES CARRYING GIRDER LOADS, NUMBER OF PLYS OF PIGGYBACK TRUSS TO MATCH BASE TRUSS.
- 5) CONCENTRATED LOAD MUST BE APPLIED TO BOTH THE PIGGYBACK AND THE BASE TRUSS DESIGN.



Thomas A. Albani PE No.39380
MiTek USA, Inc. FL Cert 6634
6904 Parke East Blvd. Tampa FL 33610
Date:

January 19, 2018




TOTAL NUMBER OF NAILS EACH SIDE OF BREAK *		X INCHES	MAXIMUM FORCE (lbs) 15% LOAD DURATION							
			SP		DF		SPF		HF	
2x4	2x6		2x4	2x6	2x4	2x6	2x4	2x6	2x4	2x6
20	30	24"	1706	2559	1561	2342	1320	1980	1352	2028
26	39	30"	2194	3291	2007	3011	1697	2546	1738	2608
32	48	36"	2681	4022	2454	3681	2074	3111	2125	3187
38	57	42"	3169	4754	2900	4350	2451	3677	2511	3767
44	66	48"	3657	5485	3346	5019	2829	4243	2898	4347

* DIVIDE EQUALLY FRONT AND BACK

ATTACH 2x SCAB OF THE SAME SIZE AND GRADE AS THE BROKEN MEMBER TO EACH FACE OF THE TRUSS (CENTER ON BREAK OR SPLICE) WITH 10d (0.131" X 3") NAILS (TWO ROWS FOR 2x4, THREE ROWS FOR 2x6) SPACED 4" O.C. AS SHOWN. STAGGER NAIL SPACING FROM FRONT FACE AND BACK FACE FOR A NET 0-2-0 O.C. SPACING IN THE MAIN MEMBER. USE A MIN. 0-3-0 MEMBER END DISTANCE.

THE LENGTH OF THE BREAK (C) SHALL NOT EXCEED 12". (C=PLATE LENGTH FOR SPLICE REPAIRS)
THE MINIMUM OVERALL SCAB LENGTH REQUIRED (L) IS CALCULATED AS FOLLOWS:
 $L = (2) X + C$




THE LOCATION OF THE BREAK MUST BE GREATER THAN OR EQUAL TO THE REQUIRED X DIMENSION FROM ANY PERIMETER BREAK OR HEEL JOINT AND A MINIMUM OF 6" FROM ANY INTERIOR JOINT (SEE SKETCH ABOVE)

DO NOT USE REPAIR FOR JOINT SPLICES


NOTES:

1. THIS REPAIR DETAIL IS TO BE USED ONLY FOR THE APPLICATION SHOWN. THIS REPAIR DOES NOT IMPLY THAT THE REMAINING PORTION OF THE TRUSS IS UNDAMAGED. THE ENTIRE TRUSS SHALL BE INSPECTED TO VERIFY THAT NO FURTHER REPAIRS ARE REQUIRED. WHEN THE REQUIRED REPAIRS ARE PROPERLY APPLIED, THE TRUSS WILL BE CAPABLE OF SUPPORTING THE LOADS INDICATED.
2. ALL MEMBERS MUST BE RETURNED TO THEIR ORIGINAL POSITIONS BEFORE APPLYING REPAIR AND HELD IN PLACE DURING APPLICATION OF REPAIR.
3. THE END DISTANCE, EDGE DISTANCE AND SPACING OF NAILS SHALL BE SUCH AS TO AVOID UNUSUAL SPLITTING OF THE WOOD.
4. WHEN NAILING THE SCABS, THE USE OF A BACKUP WEIGHT IS RECOMMENDED TO AVOID LOOSENING OF THE CONNECTOR PLATES AT THE JOINTS OR SPLICES.
5. THIS REPAIR IS TO BE USED FOR SINGLE PLY TRUSSES IN THE 2x ORIENTATION ONLY.
6. THIS REPAIR IS LIMITED TO TRUSSES WITH NO MORE THAN THREE BROKEN MEMBERS.



Thomas A. Albani PE No. 39380
MiTek USA, Inc. FL Cert 6634
6904 Parke East Blvd. Tampa FL 33610
Date:

January 19, 2018



NOTES:

1. TOE-NAILS SHALL BE DRIVEN AT AN ANGLE OF 45 DEGREES WITH THE MEMBER AND MUST HAVE FULL WOOD SUPPORT. (NAIL MUST BE DRIVEN THROUGH AND EXIT AT THE BACK CORNER OF THE MEMBER END AS SHOWN.)
2. THE END DISTANCE, EDGE DISTANCE, AND SPACING OF NAILS SHALL BE SUCH AS TO AVOID UNUSUAL SPLITTING OF THE WOOD.
3. ALLOWABLE VALUE SHALL BE THE LESSER VALUE OF THE TWO SPECIES FOR MEMBERS OF DIFFERENT SPECIES.

THIS DETAIL APPLICABLE TO THE
THREE END DETAILS SHOWN BELOW

VIEWS SHOWN ARE FOR
ILLUSTRATION PURPOSES ONLY

TOE-NAIL SINGLE SHEAR VALUES PER NDS 2001 (lb/nail)						
	DIAM.	SP	DF	HF	SPF	SPF-S
3.5" LONG	.131	88.0	80.6	69.9	68.4	59.7
	.135	93.5	85.6	74.2	72.6	63.4
	.162	108.8	99.6	86.4	84.5	73.8
3.25" LONG	.128	74.2	67.9	58.9	57.6	50.3
	.131	75.9	69.5	60.3	59.0	51.1
	.148	81.4	74.5	64.6	63.2	52.5


VALUES SHOWN ARE CAPACITY PER TOE-NAIL.
APPLICABLE DURATION OF LOAD INCREASES MAY BE APPLIED.

EXAMPLE:

(3) - 16d (0.162" X 3.5") NAILS WITH SPF SPECIES BOTTOM CHORD

For load duration increase of 1.15:


3 (nails) X 84.5 (lb/nail) X 1.15 (DOL) = 291.5 lb Maximum Capacity




Thomas A. Albani PE No. 39380
MiTek USA, Inc. FL Cert 6634
6904 Parke East Blvd. Tampa FL 33610
Date:

January 19, 2018





SIDE VIEW
(2x3)
2 NAILS



SIDE VIEW
(2x4)
3 NAILS




SIDE VIEW
(2x6)
4 NAILS





GENERAL SPECIFICATIONS

1. NAIL SIZE 10d (0.131" X 3")
2. WOOD SCREW = 3" WS3 USP OR EQUIVALENT
DO NOT USE DRYWALL OR DECKING TYPE SCREW
3. INSTALL VALLEY TRUSSES (24" O.C. MAXIMUM) AND SECURE PER DETAIL A
4. BRACE VALLEY WEBS IN ACCORDANCE WITH THE INDIVIDUAL DESIGN DRAWINGS.
5. BASE TRUSS SHALL BE DESIGNED WITH A PURLIN SPACING EQUIVALENT TO THE RAKE DIMENSION OF THE VALLEY TRUSS SPACING.
6. NAILING DONE PER NDS - 01
7. VALLEY STUD SPACING NOT TO EXCEED 48" O.C.



SECURE VALLEY TRUSS
W/ ONE ROW OF 10d
NAILS 6" O.C.

ATTACH 2x4 CONTINUOUS NO.2 SP
TO THE ROOF W/ TWO USP WS3 (1/4" X 3")
WOOD SCREWS INTO EACH BASE TRUSS.


DETAIL A
(NO SHEATHING)
N.T.S.

WIND DESIGN PER ASCE 7-98, ASCE 7-02, ASCE 7-05 146 MPH
WIND DESIGN PER ASCE 7-10 160 MPH
MAX MEAN ROOF HEIGHT = 30 FEET
ROOF PITCH = MINIMUM 3/12 MAXIMUM 6/12
CATEGORY II BUILDING
EXPOSURE C
WIND DURATION OF LOAD INCREASE : 1.60
MAX TOP CHORD TOTAL LOAD = 50 PSF
MAX SPACING = 24" O.C. (BASE AND VALLEY)
MINIMUM REDUCED DEAD LOAD OF 6 PSF
ON THE TRUSSES




Thomas A. Albani PE No.39380
MiTek USA, Inc. FL Cert 6634
6904 Parke East Blvd. Tampa FL 33610
Date:

January 19, 2018




GENERAL SPECIFICATIONS


1. NAIL SIZE 10d (0.131" X 3")
2. WOOD SCREW = 4.5" WS45 USP OR EQUIVANT
3. INSTALL SHEATHING TO TOP CHORD OF BASE TRUSSES.
4. INSTALL VALLEY TRUSSES (24" O.C. MAXIMUM) AND SECURE TO BASE TRUSSES AS PER DETAIL A
5. BRACE VALLEY WEBS IN ACCORDANCE WITH THE INDIVIDUAL DESIGN DRAWINGS.
6. NAILING DONE PER NDS-01
7. VALLEY STUD SPACING NOT TO EXCEED 48" O.C.



SECURE VALLEY TRUSS
W/ ONE ROW OF 10d
NAILS 6" O.C.




WIND DESIGN PER ASCE 7-98, ASCE 7-02, ASCE 7-05 146 MPH
WIND DESIGN PER ASCE 7-10 160 MPH
MAX MEAN ROOF HEIGHT = 30 FEET
ROOF PITCH = MINIMUM 3/12 MAXIMUM 6/12
CATEGORY II BUILDING
EXPOSURE C
WIND DURATION OF LOAD INCREASE : 1.60
MAX TOP CHORD TOTAL LOAD = 50 PSF
MAX SPACING = 24" O.C. (BASE AND VALLEY)
MINIMUM REDUCED DEAD LOAD OF 6 PSF
ON THE TRUSSES




Thomas A. Albani PE No.39380
MiTek USA, Inc. FL Cert 6634
6904 Parke East Blvd. Tampa FL 33610
Date:

February 12, 2018




GENERAL SPECIFICATIONS

1. NAIL SIZE 16d (0.131" X 3.5")
2. INSTALL VALLEY TRUSSES (24" O.C. MAXIMUM) AND SECURE PER DETAIL A
3. BRACE VALLEY WEBS IN ACCORDANCE WITH THE INDIVIDUAL DESIGN DRAWINGS.
4. BASE TRUSS SHALL BE DESIGNED WITH A PURLIN SPACING EQUIVANT TO THE RAKE DIMENSION OF THE VALLEY TRUSS SPACING.
5. NAILING DONE PER NDS - 01
6. VALLEY STUD SPACING NOT TO EXCEED 48" O.C.
7. ALL LUMBER SPECIES TO BE SP.




SECURE VALLEY TRUSS
W/ ONE ROW OF 16d
NAILS 6" O.C.



DETAIL A
(MAXIMUM 1" SHEATHING)
N.T.S.

WIND DESIGN PER ASCE 7-98, ASCE 7-02, ASCE 7-05 120 MPH
WIND DESIGN PER ASCE 7-10 150 MPH
MAX MEAN ROOF HEIGHT = 30 FEET
ROOF PITCH = MINIMUM 3/12 MAXIMUM 10/12
CATEGORY II BUILDING
EXPOSURE C OR B
WIND DURATION OF LOAD INCREASE : 1.60
MAX TOP CHORD TOTAL LOAD = 60 PSF
MAX SPACING = 24" O.C. (BASE AND VALLEY)
MINIMUM REDUCED DEAD LOAD OF 4.2 PSF
ON THE TRUSSES



Thomas A. Albani PE No.39380
MiTek USA, Inc. FL Cert 6634
6904 Parke East Blvd. Tampa FL 33610
Date:


February 12, 2018

AUGUST 1, 2016

TRUSSED VALLEY SET DETAIL
(HIGH WIND VELOCITY)

MII-VALLEY


MiTek USA, Inc. Page 1 of 1




MiTek USA, Inc.

ENGINEERED BY
TRENCO
A MiTek Affiliate


NOTE: VALLEY STUD SPACING NOT
TO EXCEED 48" O.C. SPACING



ATTACH VALLEY TRUSSES TO
LOWER TRUSSES WITH
USP RT7 OR EQUIVALENT



FOR BEVELED BOTTOM
CHORD, CLIP MAY BE
APPLIED TO EITHER FACE



CLIP MAY BE APPLIED
TO THIS FACE UP TO
A MAXIMUM 6/12 PITCH

WIND DESIGN PER ASCE 7-98, ASCE 7-02, ASCE 7-05 146 MPH
WIND DESIGN PER ASCE 7-10 160 MPH
MAX MEAN ROOF HEIGHT = 30 FEET
CATEGORY II BUILDING
EXPOSURE B or C
WIND DURATION OF LOAD INCREASE : 1.6
MAX TOP CHORD TOTAL LOAD = 50 PSF
MAX SPACING = 24" O.C. (BASE AND VALLEY)

SUPPORTING TRUSSES DIRECTLY UNDER
VALLEY TRUSSES MUST BE DESIGNED
WITH A MAXIMUM UNBRACED LENGTH OF
2'-10" ON AFFECTED TOP CHORDS.

NOTES:

- SHEATHING APPLIED AFTER
INSTALLATION OF VALLEY TRUSSES
- THIS DETAIL IS NOT APPLICABLE FOR
SPF-S SPECIES LUMBER.

NON-BEVELED
BOTTOM CHORD




NON-BEVELED
BOTTOM CHORD

CLIP MUST BE APPLIED
TO THIS FACE WHEN
PITCH EXCEEDS 6/12.
(MAXIMUM 12/12 PITCH)



Thomas A. Albani PE No. 39380
MiTek USA, Inc. FL Cert 6634
6904 Parke East Blvd. Tampa FL 33610
Date:

January 19, 2018




NOTE:

1. MINIMUM GRADE OF #2 MATERIAL IN THE TOP AND BOTTOM CHORDS.
2. CONNECTION BETWEEN BOTTOM CHORD OF GABLE END TRUSS AND WALL TO BE PROVIDED BY PROJECT ENGINEER OR ARCHITECT.
3. BRACING SHOWN IS FOR INDIVIDUAL TRUSS ONLY. CONSULT BLDG. ARCHITECT OR ENGINEER FOR TEMPORARY AND PERMANENT BRACING OF ROOF SYSTEM.
4. "L" BRACES SPECIFIED ARE TO BE FULL LENGTH. GRADES: 2x4 No 3/STUD SP OR BETTER WITH ONE ROW OF 10d NAILS SPACED 6" O.C.
5. DIAGONAL BRACE TO BE APPROXIMATELY 45 DEGREES TO ROOF DIAPHRAM AT 4'-0" O.C.
6. CONSTRUCT HORIZONTAL BRACE CONNECTING A 2x6 STUD AND A 2x4 STUD AS SHOWN WITH 16d NAILS SPACED 6" O.C. HORIZONTAL BRACE TO BE LOCATED AT THE MIDSPAN OF THE LONGEST STUD. ATTACH TO VERTICAL STUDS WITH (4) 10d NAILS THROUGH 2x4. (REFER TO SECTION A-A)
7. GABLE STUD DEFLECTION MEETS OR EXCEEDS L/240.
8. THIS DETAIL DOES NOT APPLY TO STRUCTURAL GABLES.
9. DO NOT USE FLAT BOTTOM CHORD GABLES NEXT TO SCISSOR TYPE TRUSSES.
10. NAILS DESIGNATED 10d ARE (0.131" X 3") AND NAILS DESIGNATED 16d ARE (0.131" X 3.5")

PROVIDE 2x4 BLOCKING BETWEEN THE FIRST TWO TRUSSES AS NOTED. TOENAIL BLOCKING TO TRUSSES WITH (2) - 10d NAILS AT EACH END. ATTACH DIAGONAL BRACE TO BLOCKING WITH (5) - 10d NAILS.

(4) - 8d (0.131" X 2.5") NAILS MINIMUM, PLYWOOD SHEATHING TO 2x4 STD SP BLOCK



Minimum Stud Size Species and Grade	Stud Spacing	Without Brace	2x4 L-Brace	DIAGONAL BRACE	2 DIAGONAL BRACES AT 1/3 POINTS
		Maximum Stud Length			
2x4 SP No 3/Stud	12" O.C.	3-11-3	6-8-0	7-2-14	11-9-10
2x4 SP No 3/Stud	16" O.C.	3-6-14	5-9-5	7-1-13	10-8-11
2x4 SP No 3/Stud	24" O.C.	3-1-8	4-8-9	6-2-15	9-4-7

- * Diagonal braces over 6'-3" require a 2x4 T-Brace attached to one edge. Diagonal braces over 12'-6" require 2x4 I-braces attached to both edges. Fasten T and I braces to narrow edge of web with 10d nails 8" o.c., with 3" minimum end distance. Brace must cover 90% of diagonal length.


MAXIMUM WIND SPEED = 146 MPH
MAX MEAN ROOF HEIGHT = 30 FEET
CATEGORY II BUILDING
EXPOSURE B or C
ASCE 7-98, ASCE 7-02, ASCE 7-05
DURATION OF LOAD INCREASE : 1.60

STUD DESIGN IS BASED ON COMPONENTS AND CLADDING.
CONNECTION OF BRACING IS BASED ON MWFRS.



Thomas A. Albani PE No.39380
MiTek USA, Inc. FL Cert 6634
6904 Parke East Blvd, Tampa FL 33610
Date:

January 19, 2018



MiTek USA, Inc.



MiTek USA, Inc.

Page 1 of 1

TRUSS CRITERIA:

LOADING: 40-10-0-10

DURATION FACTOR: 1.15

SPACING: 24" O.C.

TOP CHORD: 2x4 OR 2x6


PITCH: 4/12 - 12/12

HEEL HEIGHT: STANDARD HEEL UP TO 12" ENERGY HEEL

END BEARING CONDITION

NOTES:

1. ATTACH 2x_ SCAB (MINIMUM NO.2 GRADE SPF, HF, SP, DF) TO ONE FACE OF TRUSS WITH TWO ROWS OF 10d (0.131" X 3") SPACED 6" O.C.
2. THE END DISTANCE, EDGE DISTANCE, AND SPACING OF NAILS SHALL BE SUCH AS TO AVOID UNUSUAL SPLITTING OF THE WOOD.
3. WHEN NAILING THE SCABS, THE USE OF A BACKUP WEIGHT IS RECOMMENDED TO AVOID LOOSENING OF THE CONNECTOR PLATES AT THE JOINTS OR SPLICES.




IMPORTANT

This detail to be used only with trusses (spans less than 40') spaced 24" o.c. maximum and having pitches between 4/12 and 12/12 and total top chord loads not exceeding 50 psf.


Trusses not fitting these criteria should be examined individually.

REFER TO INDIVIDUAL TRUSS DESIGN
FOR PLATE SIZES AND LUMBER GRADES



Thomas A. Albani PE No.39380
MiTek USA, Inc. FL Cert 6634
6904 Parke East Blvd. Tampa FL 33610
Date:



February 12, 2018



TO MINIMIZE VIBRATION COMMON TO ALL SHALLOW FRAMING SYSTEMS, 2x6 "STRONGBACK" IS RECOMMENDED, LOCATED EVERY 8 TO 10 FEET ALONG A FLOOR TRUSS.

NOTE 1: 2X6 STRONGBACK ORIENTED VERTICALLY MAY BE POSITIONED DIRECTLY UNDER THE TOP CHORD OR DIRECTLY ABOVE THE BOTTOM CHORD. SECURELY FASTENED TO THE TRUSS USING ANY OF THE METHODS ILLUSTRATED BELOW.

NOTE 2: STRONGBACK BRACING ALSO SATISFIES THE LATERAL BRACING REQUIREMENTS FOR THE BOTTOM CHORD OF THE TRUSS WHEN IT IS PLACED ON TOP OF THE BOTTOM CHORD, IS CONTINUOUS FROM END TO END, CONNECTED WITH A METHOD OTHER THAN METAL FRAMING ANCHOR, AND PROPERLY CONNECTED, BY OTHERS, AT THE ENDS.



ALTERNATE METHOD OF SPLICING:
OVERLAP STRONGBACK MEMBERS A MINIMUM OF 4'-0" AND FASTEN WITH (12) - 10d (0.131" X 3") NAILS STAGGERED AND EQUALLY SPACED.
(TO BE USED ONLY WHEN STRONGBACK IS NOT ALIGNED WITH A VERTICAL)



Thomas A. Albani PE No. 39380
MiTek USA, Inc. FL Cert 6634
6904 Parke East Blvd. Tampa FL 33610
Date:

February 12, 2018

