
## **SHEET INDEX**

COVER SHEET	1
GENERAL NOTES	1
FOUNDATION PLAN BLDG. NOS. 700, 800, 900 & 1000	3
FLECT - FIREWALL PLAN BLDG, NOS, 700, 800, 900 & 1000	2



**BUILDING NOS. 700, 800, 900 & 1000 ELEVATIONS** 

THIS DOCUMENT HAS BEEN DIGITALLY SIGNED AND

STATE OF

PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED. THE SIGNATURE MUST BE VERIFIED IN THE ELECTRONIC DOCUMENTS.

NORTH FLORIDA PROFESSIONAL SERVICES, INC. P.O. BOX 3823 LAKE CITY, FL 32056 CERTIFICATE OF AUTHORIZATION: 29011 ROBERT PHILLIP BISHOP, JR., P.E. NO. 38546

THE ABOVE NAMED PROFESSIONAL ENGINEER SHALL BE RESPONSIBLE FOR THE FOLLOWING SHEETS IN ACCORDANCE WITH RULE 61G15-23.004, F.A.C. SHEET Nos 1-4

## PLANS PREPARED FOR:

**MINI STORAGE & RECORD** STORAGE OF LAKE CITY 442 SW SAINT MARGARET ST LAKE CITY, FL 32025 386-752-7092





Ш Ш 王 S

COVE

- CONTRACTOR SHALL VERIFY ALL DIMENSIONS AND DETAILS SHOWN.
   NOTIFY THE ENGINEER OF ANY CHANGES OR MODIFICATIONS TO THE
- 2. ALL CONSTRUCTION, EQUIPMENT AND FINISHES SHALL MEET OR EXCEED ALL LOCAL CODES, FLORIDA BUILDING CODE, NFPA 101 LIFE SAFETY CODE AND ALL OTHER GOVERNING CODES AND REVISIONS.
- 3. DO NOT USE ANY MATERIALS CONTAINING ASBESTOS.
- 4. THE CONTRACTOR SHALL VERIFY ALL DIMENSIONS AND DETAILS SHOWN AND NOTIFY THE ENGINEER OF ANY CHANGES OR MODIFICATIONS.
- 5. THE CONTRACTOR SHALL VERIFY ALL EXISTING CONDITIONS AND DIMENSIONS AT THE JOB SITE TO INSURE THAT ALL NEW WORK WILL FIT IN THE MANNER INTENDED AND ON THE PLANS. SHOULD ANY CONDITIONS EXIST THAT ARE CONTRARY TO THOSE SHOWN ON THE PLANS, THE CONTRACTOR SHALL NOTIFY THE ENGINEER OF SUCH DIFFERENCES IMMEDIATELY AND PRIOR TO PROCEEDING WITH THE
- 6. ANY WOOD OR TIMBER THAT COMES IN CONTACT WITH CONCRETE OR MASONRY SHALL BE PRESSURE TREATED.
  7. SEE STRUCTURAL DRAWINGS FOR ALL SIZES, SHAPES AND CONDITIONS OF ALL STRUCTURAL MEMBERS, CONNECTIONS FOOTINGS, BRACING,
- 8. ALL INTERIOR FINISHES SHALL MEET THE REQUIREMENTS OF THE FLORIDA BUILDING CODE AND LIFE SAFETY CODE, NFPA 101 SECTOIN
- 9. ALL FLOOR FINISHES SHALL BE LEVEL AND SHALL AVOID ANY CHANGES IN ELEVATION GREATER THAN 1/2" INCLUDING DOOR THRESHOLDS AND STEP DOWNS AT EXTERIOR AND INTERIOR DOORS.

  10. FOUNDATION WATER-PROOFING AND MOISTURE BARRIER TO CONSIST
- OF 6-MIL PLASTIC POLYETHYLENE. ALL LAPS SHALL BE A MINIMUM OF
- 11. FINAL LOCATION, SIZE AND PLACEMENT OF ALL PLUMBING, ELECTRICAL AND MECHANICAL COMPONENTS SHALL BE DETERMINED BY A LICENSED ELECTRICAL OR MECHANICAL CONTRACTOR IN ACCORDANCE WITH CHAPTER 471 FLORIDA STATUTES.

## STRUCTURAL NOTES

- STRUCTURAL DESIGN CRITERIA

  1. ALL WORK HAS BEEN DESIGNED FOR THE FOLLOWING LOADS AND SPECIFICATIONS APPLIED IN ACCORDANCE WITH THE LATEST EDITIONS OF THE FLORIDA BUILDING CODE AND ACI 318.
- 2. DESIGN LOADS:
  - 2.1 WIND LOAD = 120 MPH

## **CONCRETE NOTES**

- SOIL BEARING= 2500 PSF (MINIMUM).
   FILL AND COMPACTION: ALL FILL MATERIAL SHALL BE CLEAN, WELL DRAINED SAND WITH NOT MORE THAN 10% PASSING THE No. 200 STANDARD SIEVE. ALL FILL MATERIAL SHALL BE COMPACTED TO 95% OF THE MODIFIED MAXIMUM DRY DENSITY AS DETERMINED BY ASTM T-180.
- 3. CONCRETE COMPRESSIVE STRENGTH AND SLUMP:
  THE MINIMUM 28-DAY COMPRESSIVE STRENGTH AND SLUMP OF CONCRETE
- SHALL BE AS FOLLOWS: FOUNDATIONS AND FLOOR SLAB: fc'= 3000 PSI SLUMP: 2"-5"

SIDEWALKS AND CONCRETE PAVEMENT: fc'= 2500 PSI SLUMP: 3"-6" ALL CONCRETE SHALL BE MIXED IN ACCORDANCE WITH THE LATEST **EDITIONS OF ACI 315 AND ACI 318.** 

- 4. REINFORCING STEEL:
  ALL LAP SPLICES SHALL BE A MINIMUM OF 24" OR AS SPECIFIED ON THE
  PLANS. REINFORCING STEEL BARS ASTM A-615 GRADE 40
- WELDED WIRE FABRIC ASTM A-185
- 5. UNLESS OTHERWISE NOTED ON THE PLANS, ALL SLABS ON GRADE SHALL BE REINFORCED WITH ONE LAYER OF 6X6X10/10 WELDED WIRE FABRIC PLACED AT 1/3 THE THICKNESS OF THE SLAB FROM THE BOTTOM OF THE SLAB.

GENERAL NOTES CITY MINI STORAGE EXPANSION COLUMBIA COUNTY, FL

**CLEAN TREATED FILL** 

1 FOOTING SECTION
SCALE: 1/2" = 1'-0"

STEEL LINE PER METAL BUILDING MANUFACTURER'S PLANS

3,000 PSI CONC. MONO. FTG. REINF W/(2) #5 BARS CONT. ON 3" ROD CHAIRS

**②**H

STEEL LINE PER METAL BUILDING MANUFACTURER'S PLANS TOP OF SLAB SLOPE -2% MIN **CLEAN TREATED FILL** 3,000 PSI CONC. MONO. FTG. REINF W/(2) #5 BARS CONT. ON 3" ROD CHAIRS

11'-8 1/4" 1

4" CONC. SLAB (3,000 PSI MIN.) REINF. W/6"X 6" #1010 W.W.M. OVER 6 MIL. POLYETHYLENE VAPO BARYIEV, LAPPED 12" @ JOINTS & SEALE W/DUCT TAPE OVER CLEAN TREATED FILL

FOUNDATION PLAN BUILDING NOS. 700, 800, 900 & 1000 SCALE: NTS

0

0

POOTING SECTION
SCALE: 1/2" = 1'-0"

**CONTINUOUS BAR** #5 BAR BENT AROUND CORNERS W/ MIN. LAP = 40 BAR DIAMETERS (25") EDGE OF MONO. FTG. **CONTINUOUS BAR** 

REBAR CORNER LAP DETAIL (TYP.)
SCALE: 1/2" = 1'-0"

CODE DATA:

DESIGN WIND SPEED: 120 MPH RISK CATEGORY: II EXPOSURE: B

SAW CUT SLAB 1/4 SLAB THICKNESS DEEP

FLORIDA BUILDING CODE 2017 6TH EDITION

NOTE: SEE SITE PLAN FOR BUILDING LOCATION & ORIENTAION



♦ TOP OF SLAB

SLOPE 2%

FOUNDATION PLAN BLDG. NOS. 700, 800, 900 & 1000 LAKE CITY MINI STORAGE EXPANSION COLUMBIA COUNTY, FL