

**DAVID D. PARRISH LAND SURVEYING, INC.**  
**12606 NW 142<sup>nd</sup> Terrace**  
**ALACHUA, FL 32615**  
**(386) 462-5427**

June 5, 2024

Jack Cruce  
231 SW Rolling Meadows Glen  
Fort White, FL 32038

Ref: New Construction at 231 SW Rolling Meadows Glen,  
Fort White, FL 32038

Dear Jack:

The purpose of this letter is to verify that we shot the top of the finished floor for the new house being constructed on Lot 2, Sedgefield Phase 3 as recorded in Plat Book 8, Pages 60-64 of the public records of Columbia County, Florida.

The minimum finished floor for Lot 2, per plat, is 81.0'. The elevation of said top of the finished floor is 85.0', which is 4' above the minimum requirements for Lot 2. Datum was based FDOT Benchmark No. 8 as referenced on said record plat.

If you have any additional questions, please don't hesitate to call.

Sincerely,



David D. Parrish, PLS #4789  
President

DDP/sp