



STATE OF FLORIDA
DEPARTMENT OF HEALTH
ONSITE SEWAGE TREATMENT AND DISPOSAL
SYSTEM

QMA

PERMIT #: **12-SC-2244437**
APPLICATION #: **AP1632894**
DATE PAID: **2/24/21**
FEE PAID: **300.00**
RECEIPT #:
DOCUMENT #: **PR1517043**

CONSTRUCTION PERMIT FOR: OSTDS New
APPLICANT: KENNETH**21-0168 DAVIES
PROPERTY ADDRESS: 1040 SE ADAMS High Springs, FL 32643
LOT: 12 BLOCK: SUBDIVISION: Bicentennial Acres
PROPERTY ID #: 09971-007 [SECTION, TOWNSHIP, RANGE, PARCEL NUMBER]
[OR TAX ID NUMBER]

SYSTEM MUST BE CONSTRUCTED IN ACCORDANCE WITH SPECIFICATIONS AND STANDARDS OF SECTION 381.0065, F.S., AND CHAPTER 64E-6, F.A.C. DEPARTMENT APPROVAL OF SYSTEM DOES NOT GUARANTEE SATISFACTORY PERFORMANCE FOR ANY SPECIFIC PERIOD OF TIME. ANY CHANGE IN MATERIAL FACTS, WHICH SERVED AS A BASIS FOR ISSUANCE OF THIS PERMIT, REQUIRE THE APPLICANT TO MODIFY THE PERMIT APPLICATION. SUCH MODIFICATIONS MAY RESULT IN THIS PERMIT BEING MADE NULL AND VOID. ISSUANCE OF THIS PERMIT DOES NOT EXEMPT THE APPLICANT FROM COMPLIANCE WITH OTHER FEDERAL, STATE, OR LOCAL PERMITTING REQUIRED FOR DEVELOPMENT OF THIS PROPERTY.

SYSTEM DESIGN AND SPECIFICATIONS

T [900] GALLONS / GPD Septic Tank CAPACITY
A [] GALLONS / GPD N/A CAPACITY
N [] GALLONS GREASE INTERCEPTOR CAPACITY [MAXIMUM CAPACITY SINGLE TANK:1250 GALLONS]
K [] GALLONS DOSING TANK CAPACITY [] GALLONS @ [] DOSES PER 24 HRS #Pumps []

D [375] SQUARE FEET Drainfield SYSTEM
R [] SQUARE FEET N/A SYSTEM
A TYPE SYSTEM: [x] STANDARD [] FILLED [] MOUND []
I CONFIGURATION: [x] TRENCH [] BED []

N
F LOCATION OF BENCHMARK: 4" tree S. of site.

I ELEVATION OF PROPOSED SYSTEM SITE [24.00] [INCHES] FT [] [ABOVE / BELOW] BENCHMARK/REFERENCE POINT

E BOTTOM OF DRAINFIELD TO BE [54.00] [INCHES] FT [] [ABOVE / BELOW] BENCHMARK/REFERENCE POINT

L
D FILL REQUIRED: [0.00] INCHES EXCAVATION REQUIRED: [0.00] INCHES

O
T
H
E
R
The system is sized for 3 bedrooms with a maximum occupancy of 6 persons (2 per bedroom), for a total estimated flow of 300 gpd.
***** EXISTING TANK on property to be abandoned at time of new system install.*****

SPECIFICATIONS BY: WILLIAM D BISHOP TITLE: SA0890009; SM0081587

APPROVED BY: Dustin W Jones TITLE: Environmental Specialist II Columbia CHD

DATE ISSUED: 02/24/2021 EXPIRATION DATE: 08/24/2022

DH 4016, 08/09 (Obsoletes all previous editions which may not be used)

Incorporated: 64E-6.003, FAC

AYERS-

21-5168

SE ADAMS St

SWALE

345

290

305

Evapnrg
Tank
Demo

115' WELL

WEL

185

1" = 100'

3BR 1600 SQ

North

SLOPE

B WELL

EX SFR

APPROVED

Robert Ford IN 2/22/21

0 67 134 201 268 336 402 469 536 603 670 ft

Columbia County Property Appraiser Jeff Hampton | Lake City, Florida | 386-758-1083

PARCEL: 10-7S-17-09971-007 (36957) | SINGLE FAMILY (0100) | 3.97 AC
 LOT 12 BICENTENNIAL ACRES UT 1 EX 1.03 AC DESC IN ORB 1300- 1615, ORB 624-124, DC 1114- 1313, WD 1136-2354, CT 1194- 1906, WD 1200-2004, WD 1209- 266

DAVIES KENNETH SR & NANCY

Owner: 1040 SE ADAMS ST
 HIGH SPRINGS, FL 32643

Site: 1040 ADAMS ST, HIGH SPRINGS

Sales 9/3/2015 \$100 1(U)
 2/11/2011 \$41,700 1(U)
 Info 5/11/2010 \$100 1(U)

2021 Working Values

Mkt Lnd	\$30,117	Appraised	\$143,917
Ag Lnd	\$0	Assessed	\$132,666
Bldg	\$107,200	Exempt	\$50,000
XFOB	\$6,600	county:	\$82,475
Just	\$143,917	city:	\$0
		Taxable	other:\$0
		school:	\$107,666

NOTES:

Columbia County, FL

This information was derived from data which was compiled by the Columbia County Property Appraiser Office solely for the governmental purpose of property assessment. This information should not be relied upon by anyone as a determination of the ownership of property or market value. No warranties, expressed or implied, are provided for the accuracy of the data herein, its use, or its interpretation. Although it is periodically updated, this information may not reflect the data currently on file in the Property Appraiser's office. GrizzlyLogic.com