

COLUMBIA COUNTY INSPECTION SHEET

APPLICATION # 36205

DATE: 4/27/2018 TAKEN BY _____ INSPECTION DATE: 4/30/2018

BUILDING PERMIT # 000036024 CULVERT/WAIVER PERMIT # 000002505 WAIVER N

PARCEL ID: 01-5S-16-03405-251 ZONING _____

TYPE OF DEVELOPMENT Culvert

SETBACKS FRONT _____ REAR _____ SIDE _____ HEIGHT _____

FLOOD ZONE _____ SEPTIC _____ NO. EXISTING D.U. _____

SUBDIVISION SOUTHWOOD MEADOWS Lot 1 Block B Unit _____ Phase _____

OWNER LACEY DEVELOPMENTS PHONE _____

ADDRESS 213 SW ERIN GLEN
LAKE CITY FL 32024

CONTRACTOR ADAM PAPKA PHONE _____

LOCATION 47 S, L WALTER AVE, L LITTLE RD, GO TO SOUTHWOOD MEADOWS 2ND R ON ERIN GLEN, 3RD ON RIGHT

COMMENTS

INSTALL MIN. 32'X18" CORR.METAL CULVERT W/CONCRETE MITERED
ENDS W/6"X6" WELDED WIRE, REBAR, OR CULVERT BOLTS.
DAVID MCCORMICK

SPECIAL INSTRUCTIONS

PRIOR INSPECTIONS

REQUESTED INSPECTIONS

<u>Inspection</u>	<u>By</u>	<u>Date</u>	<u>Date</u>	<u>Inspection Request</u>
Driveway Opening Inspection		12/05/2017	04/30/2018	Engineering/ <u>Final Driveway</u>

INSPECTORS

APPROVED _____ NOT APROVED _____ BY _____ POWER CO _____

Phone: 3866232383 Fax: _____