



Manual S Compliance Report

Entire House

Air Ducks Heating & Air, Inc.

Job: 31
Date: Dec 07, 2020
By:

2601 NW 76th Ave, Gainesville, Fla 32653 Phone: 352-215-4624 Email: Airducksac@gmail.com Web: Airducksac.com

Project Information

For: DWC Construction
Thornwood Lot 21, Fla

Cooling Equipment

Design Conditions

| | | | | | | |
|--------------------|--------|--------------------|-------|------|-------------------|--------|
| Outdoor design DB: | 91.9°F | Sensible gain: | 28035 | Btuh | Entering coil DB: | 78.0°F |
| Outdoor design WB: | 76.2°F | Latent gain: | 4835 | Btuh | Entering coil WB: | 63.9°F |
| Indoor design DB: | 75.0°F | Total gain: | 32870 | Btuh | | |
| Indoor RH: | 50% | Estimated airflow: | 1220 | cfm | | |

Manufacturer's Performance Data at Actual Design Conditions

| | | | |
|--------------------|------------|--------|------------------------------|
| Equipment type: | Split ASHP | | |
| Manufacturer: | Trane | Model: | 4TWR4036G1+TEM3A0C36S41++TDR |
| Actual airflow: | 1220 | cfm | |
| Sensible capacity: | 29280 | Btuh | 104% of load |
| Latent capacity: | 7320 | Btuh | 151% of load |
| Total capacity: | 36600 | Btuh | 111% of load SHR: 80% |



Heating Equipment

Design Conditions

| | | | | | | |
|--------------------|--------|------------|-------|------|-------------------|--------|
| Outdoor design DB: | 33.0°F | Heat loss: | 33629 | Btuh | Entering coil DB: | 66.6°F |
| Indoor design DB: | 68.0°F | | | | | |

Manufacturer's Performance Data at Actual Design Conditions

| | | | |
|-----------------------------|------------|--------|------------------------------|
| Equipment type: | Split ASHP | | |
| Manufacturer: | Trane | Model: | 4TWR4036G1+TEM3A0C36S41++TDR |
| Actual airflow: | 1220 | cfm | |
| Output capacity: | 34200 | Btuh | 102% of load |
| Supplemental heat required: | 0 | Btuh | |
| Capacity balance: | 33 | °F | |
| Economic balance: | -99 | °F | |

| | | | |
|------------------------|------------|--------|-------------------------------|
| Backup equipment type: | Elec strip | | |
| Manufacturer: | n/a | Model: | |
| Actual airflow: | 1220 | cfm | |
| Output capacity: | 6.6 | kW | 67% of load Temp. rise: 25 °F |

Meets all requirements of ACCA Manual S.



Right-Suite® Universal 2019 19.0.21 RSU23127

...ents\Wrightsoft HVAC\DWC lot 25 thorne wood.rup Calc = MJ8 Front Door faces: N

2021-Apr-21 12:58:52

Page 1



Residential Plans Examiner Review Form for HVAC System Design (Loads, Equipment, Ducts)

Form
RPER 1
15 Mar 09

Header Information

Contractor: Air Ducks Heating & Air, Inc.
Mechanical license:
Building plan #:
Home address (Street or Lot#, Block, Subdivision): Thornwood Lot 21, Entire House

REQUIRED ATTACHMENTS
Manual J1 Form (and supporting worksheets):
or MJ1AE Form* (and supporting worksheets):
OEM performance data (heating, cooling, blower):
Manual D Friction Rate Worksheet:
Duct distribution sketch:

ATTACHED
Yes ☐ No ☐
Yes ☐ No ☐
Yes ☐ No ☐
Yes ☐ No ☐
Yes ☐ No ☐

HVAC LOAD CALCULATION (IRC M1401.3)

Design Conditions

Winter Design Conditions

Outdoor temperature: 33 °F
Indoor temperature: 68 °F
Total heat loss: 33629 Btuh

Summer Design Conditions

Outdoor temperature: 92 °F
Indoor temperature: 75 °F
Grains difference: 47 gr/lb @ 50% RH
Sensible heat gain: 28932 Btuh
Latent heat gain: 4990 Btuh
Total heat gain: 33922 Btuh

Building Construction Information


Building

Orientation: Front Door faces North
North, East, West, South, Northeast, Northwest, Southeast, Southwest

Number of bedrooms: 0
Conditioned floor area: 1843 ft²
Number of occupants: 5

Windows

Eave overhang depth: 0 ft
Internal shade: blinds
Blinds, drapes, etc.
Number of skylights: 0



HVAC EQUIPMENT SELECTION (IRC M1401.3)

Heating Equipment Data

Equipment type: Split ASHP
Furnace, Heat pump, Boiler, etc.
Model: Trane
4TWR4036G1+TEM3A0C36S41++TDR
Heating output capacity: 0 Btuh
Heat pumps - capacity at winter design outdoor conditions
Aux. heating output capacity: 22460 Btuh

Cooling Equipment Data

Equipment type: Split ASHP
Air Conditioner, Heat pump, etc.
Model: Trane
4TWR4036G1+TEM3A0C36S41++TDR
Total cooling capacity: 0 Btuh
Sensible cooling capacity: 0 Btuh
Latent cooling capacity: 0 Btuh

Blower Data

Heating cfm: 1220
Cooling cfm: 1220
Static pressure: 0.50 in H₂O
Fan's rated external static pressure for design airflow

HVAC DUCT DISTRIBUTION SYSTEM DESIGN (IRC M1601.1)

Design airflow: 1220 cfm
Equipment design ESP: 0.50 in H₂O
Total device pressure losses: 0 in H₂O
Available static pressure (ASP): 0.50 in H₂O
Longest supply duct: 418 ft
Longest return duct: 97 ft
Total effective length (TEL): 515 ft
Friction rate: 0.097 in/100ft
Duct Materials Used
Trunk duct: Fiberglass board
Branch duct: Round flex vinyl
Friction Rate = ASP ÷ (TEL × 100)

I declare the load calculation, equipment, equipment selection and duct design were rigorously performed based on the building plan listed above. I understand the claims made on these forms will be subject to review and verification.

Contractor's printed name: _____

Contractor's signature: _____ Date: _____

Reserved for County, Town Municipality or Authority having jurisdiction use.

*Home qualifies for MJ1AE Form based on Abridged Edition Checklist



Load Short Form

Entire House

Air Ducks Heating & Air, Inc.

Job:
Date: Dec 07, 2020
By:

2601 NW 76th Ave, Gainesville, Fla 32653 Phone: 352-215-4624 Email: Airducksac@gmail.com Web: Airducksac.com

Project Information

For: DWC Construction
Thornwood Lot 21, Fla

Design Information

| | Htg | Clg | Infiltration | Simplified Average |
|-----------------------------|-----|-----|----------------------|--------------------|
| Outside db (°F) | 33 | 92 | Method | |
| Inside db (°F) | 68 | 75 | Construction quality | |
| Design TD (°F) | 35 | 17 | Fireplaces | 0 |
| Daily range | - | M | | |
| Inside humidity (%) | 50 | 50 | | |
| Moisture difference (gr/lb) | 29 | 47 | | |

HEATING EQUIPMENT

Make Trane
Trade TRANE
Model 4TWR4036G1
AHRI ref 10344969

Efficiency 8.5 HSPF
Heating input
Heating output 34200 Btuh @ 47°F
Temperature rise 26 °F
Actual air flow 1220 cfm
Air flow factor 0.036 cfm/Btuh
Static pressure 0.50 in H2O
Space thermostat
Capacity balance point = 33 °F

Backup: n/a

Input = 7 kW, Output = 22460 Btuh, 100 AFUE

COOLING EQUIPMENT

Make Trane
Trade TRANE
Cond 4TWR4036G1
Coil TEM3A0C36S41++TDR
AHRI ref 10344969

Efficiency 11.5 EER, 14 SEER
Sensible cooling 29280 Btuh
Latent cooling 7320 Btuh
Total cooling 36600 Btuh
Actual air flow 1220 cfm
Air flow factor 0.044 cfm/Btuh
Static pressure 0.50 in H2O
Load sensible heat ratio 0.85

| ROOM NAME | Area (ft²) | Htg load (Btuh) | Clg load (Btuh) | Htg AVF (cfm) | Clg AVF (cfm) |
|----------------|------------|-----------------|-----------------|---------------|---------------|
| Master | 316 | 7873 | 6299 | 286 | 274 |
| Wic 1 | 48 | 927 | 415 | 34 | 18 |
| wc | 40 | 58 | 100 | 2 | 4 |
| Master bath | 215 | 4005 | 2036 | 145 | 89 |
| living | 449 | 7161 | 8031 | 260 | 349 |
| kitchen/dining | 243 | 2168 | 3508 | 79 | 153 |
| bed 2 | 156 | 4573 | 2161 | 166 | 94 |
| bath | 54 | 1346 | 1682 | 49 | 73 |
| bed 3 | 168 | 2149 | 937 | 78 | 41 |
| hall | 18 | 0 | 0 | 0 | 0 |
| wic | 42 | 1751 | 1689 | 64 | 74 |
| Pantry | 42 | 0 | 0 | 0 | 0 |
| laundry | 70 | 1617 | 1176 | 59 | 51 |

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Right-Suite® Universal 2019 19.0.21 RSU23127

2021-Apr-21 12:58:53

Page 1

...ents\Wrightsoft HVAC\DWC lot 25 thorne wood.rup Calc = MJ8 Front Door faces: N

| | | | | | | |
|-------------------|---|------|-------|-------|------|------|
| Entire House | d | 1861 | 33629 | 28035 | 1220 | 1220 |
| Other equip loads | | | 0 | 0 | | |
| Equip. @ 0.97 RSM | | | | 27166 | | |
| Latent cooling | | | | 4835 | | |
| TOTALS | | 1861 | 33629 | 32001 | 1220 | 1220 |

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Right-Suite® Universal 2019 19.0.21 RSU23127

2021-Apr-21 12:58:53

Page 2

...ents\Wrightsoft HVAC\DWG lot 25 thorne wood.rup Calc = MJ8 Front Door faces: N

Project Information

For: DWC Construction
 Thornwood Lot 21, Fla

Notes:

Design Information

Weather: Gainesville Rgnl, FL, US

Winter Design Conditions

Outside db 33 °F
 Inside db 68 °F
 Design TD 35 °F

Summer Design Conditions

Outside db 92 °F
 Inside db 75 °F
 Design TD 17 °F
 Daily range M
 Relative humidity 50 %
 Moisture difference 47 gr/lb

Heating Summary

Structure 25863 Btuh
 Ducts 7766 Btuh
 Central vent (0 cfm)
 (none) 0 Btuh
 Humidification 0 Btuh
 Piping 0 Btuh
 Equipment load 33629 Btuh

Sensible Cooling Equipment Load Sizing

Structure 17962 Btuh
 Ducts 10073 Btuh
 Central vent (0 cfm)
 (none) 0 Btuh
 Blower 0 Btuh
 Use manufacturer's data n
 Rate/swing multiplier 0.97
 Equipment sensible load 27166 Btuh

Infiltration

Method Simplified
 Construction quality Average
 Fireplaces 0

Latent Cooling Equipment Load Sizing

Structure 2713 Btuh
 Ducts 2122 Btuh
 Central vent (0 cfm)
 (none) 0 Btuh
 Equipment latent load 4835 Btuh

| | Heating | Cooling |
|------------------|---------|---------|
| Area (ft²) | 1843 | 1843 |
| Volume (ft³) | 16207 | 16207 |
| Air changes/hour | 0.38 | 0.20 |
| Equiv. AVF (cfm) | 103 | 54 |

Equipment Total Load (Sen+Lat) 32001 Btuh
 Req. total capacity at 0.80 SHR 2.8 ton

Heating Equipment Summary

Make Trane
 Trade TRANE
 Model 4TWR4036G1
 AHRI ref 10344969
 Efficiency 8.5 HSPF
 Heating input 34200 Btuh @ 47°F
 Heating output 26 °F
 Temperature rise 1220 cfm
 Actual air flow 0.036 cfm/Btuh
 Air flow factor 0.50 in H2O
 Static pressure
 Space thermostat
 Capacity balance point = 33 °F
 Backup: n/a
 Input = 7 kW, Output = 22460 Btuh, 100 AFUE


Cooling Equipment Summary

Make Trane
 Trade TRANE
 Cond 4TWR4036G1
 Coil TEM3A0C36S41++TDR
 AHRI ref 10344969
 Efficiency 11.5 EER, 14 SEER
 Sensible cooling 29280 Btuh
 Latent cooling 7320 Btuh
 Total cooling 36600 Btuh
 Actual air flow 1220 cfm
 Air flow factor 0.044 cfm/Btuh
 Static pressure 0.50 in H2O
 Load sensible heat ratio 0.85

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Level 1



Job #:
Performed for:
DWC Construction
Thornwood Lot 21
Fla

Air Ducks Heating & Air, Inc.

2601 NW 76th Ave
Gainesville, Fla 32653
Phone: 352-215-4624
Airducksac.com Airducksac@gmail.com

Scale: 1 : 96

Page 1
Right-Suite® Universal 2019
19.0.21 RSU23127
2021-Apr-21 12:59:44
... HVAC\DWC lot 25 thorne wood.ru

wrightsoft **Duct System Summary**
Entire House
Air Ducks Heating & Air, Inc.

Job:
 Date: Dec 07, 2020
 By:

2601 NW 76th Ave, Gainesville, Fla 32653 Phone: 352-215-4624 Email: Airducksac@gmail.com Web: Airducksac.com

Project Information

For: DWC Construction
 Thornwood Lot 21, Fla

| | Heating | Cooling |
|------------------------------------|----------------------|----------------------|
| External static pressure | 0.50 in H2O | 0.50 in H2O |
| Pressure losses | 0 in H2O | 0 in H2O |
| Available static pressure | 0.50 in H2O | 0.50 in H2O |
| Supply / return available pressure | 0.406 / 0.094 in H2O | 0.406 / 0.094 in H2O |
| Lowest friction rate | 0.097 in/100ft | 0.097 in/100ft |
| Actual air flow | 1220 cfm | 1220 cfm |
| Total effective length (TEL) | 515 ft | |

Supply Branch Detail Table

| Name | Design (Btuh) | Htg (cfm) | Clg (cfm) | Design FR | Diam (in) | H x W (in) | Duct Matl | Actual Ln (ft) | Ftg.Eqv Ln (ft) | Trunk |
|----------------|---------------|-----------|-----------|-----------|-----------|------------|-----------|----------------|-----------------|-------|
| Master | h 3937 | 143 | 137 | 0.099 | 7.0 | 0x0 | VIFx | 45.2 | 365.0 | st3 |
| Master bath | h 4005 | 145 | 89 | 0.097 | 6.0 | 0x0 | VIFx | 48.4 | 370.0 | st3 |
| Master-A | h 3937 | 143 | 137 | 0.099 | 7.0 | 0x0 | VIFx | 54.9 | 355.0 | st3 |
| Wic 1 | h 927 | 34 | 18 | 0.105 | 4.0 | 0x0 | VIFx | 51.0 | 335.0 | st3 |
| bath | c 1682 | 49 | 73 | 0.154 | 6.0 | 0x0 | VIFx | 28.0 | 235.0 | st2 |
| bed 2 | h 4573 | 166 | 94 | 0.201 | 7.0 | 0x0 | VIFx | 31.8 | 170.0 | st2 |
| bed 3 | h 2149 | 78 | 41 | 0.148 | 6.0 | 0x0 | VIFx | 19.0 | 255.0 | st2 |
| kitchen/dining | c 3508 | 79 | 153 | 0.153 | 8.0 | 0x0 | VIFx | 21.0 | 245.0 | st2 |
| laundry | h 1617 | 59 | 51 | 0.191 | 6.0 | 0x0 | VIFx | 8.0 | 205.0 | st1 |
| living | c 4015 | 130 | 175 | 0.135 | 7.0 | 0x0 | VIFx | 31.0 | 270.0 | st3 |
| living-A | c 4015 | 130 | 175 | 0.132 | 7.0 | 0x0 | VIFx | 37.0 | 270.0 | st3 |
| wc | c 100 | 2 | 4 | 0.104 | 4.0 | 0x0 | VIFx | 44.3 | 345.0 | st3 |
| wic | c 1689 | 64 | 74 | 0.184 | 4.0 | 0x0 | VIFx | 15.0 | 205.0 | st1 |

Supply Trunk Detail Table

| Name | Trunk Type | Htg (cfm) | Clg (cfm) | Design FR | Veloc (fpm) | Diam (in) | H x W (in) | Duct Material | Trunk |
|------|------------|-----------|-----------|-----------|-------------|-----------|------------|---------------|-------|
| st1 | Peak AVF | 1220 | 1220 | 0.097 | 732 | 15.7 | 8 x 30 | RectFbg | |
| st3 | Peak AVF | 726 | 735 | 0.097 | 661 | 13.0 | 8 x 20 | RectFbg | st1 |
| st2 | Peak AVF | 371 | 361 | 0.148 | 668 | 9.3 | 8 x 10 | RectFbg | st1 |

Return Branch Detail Table

| Name | Grille Size (in) | Htg (cfm) | Clg (cfm) | TEL (ft) | Design FR | Veloc (fpm) | Diam (in) | H x W (in) | Stud/Joist Opening (in) | Duct Matl | Trunk |
|------|---------------------|--------------|--------------|-------------|--------------|----------------|--------------|---------------|----------------------------|--------------|-------|
| rb3 | 0x 0 | 200 | 165 | 70.2 | 0.134 | 573 | 8.0 | 0x 0 | | VIFx | |
| rb4 | 0x 0 | 313 | 187 | 90.0 | 0.105 | 898 | 8.0 | 0x 0 | | VIFx | |
| rb2 | 0x 0 | 257 | 401 | 74.8 | 0.126 | 287 | 16.0 | 0x 0 | | VIFx | |
| rb1 | 0x 0 | 449 | 467 | 97.0 | 0.097 | 595 | 12.0 | 0x 0 | | VIFx | |

Certificate of Product Ratings

AHRI Certified Reference Number : 201763659

Date : 12-07-2020

Model Status : Active

AHRI Type : HRCU-A-CB (Split System: Heat Pump with Remote Outdoor Unit-Air-Source)

Series : XR14

Outdoor Unit Brand Name : TRANE

Outdoor Unit Model Number (Condenser or Single Package) : 4TWR4036G1

Indoor Unit Model Number (Evaporator and/or Air Handler) : TEM4A0B36S31+TDR

The manufacturer of this TRANE product is responsible for the rating of this system combination.

Rated as follows in accordance with the latest edition of AHRI 210/240 with Addendum 1, Performance Rating of Unitary Air-Conditioning & Air-Source Heat Pump Equipment and subject to rating accuracy by AHRI-sponsored, independent, third party testing:

Cooling Capacity (A2) - Single or High Stage (95F), btuh : 35000

SEER : 14.00

EER (A2) - Single or High Stage (95F) : 11.50

Heating Capacity (H12) - Single or High Stage (47F) : 34400

HSPF (Region IV) : 8.20

†"Active" Model Status are those that an AHRI Certification Program Participant is currently producing AND selling or offering for sale; OR new models that are being marketed but are not yet being produced. "Production Stopped" Model Status are those that an AHRI Certification Program Participant is no longer producing BUT is still selling or offering for sale.

Ratings that are accompanied by WAS indicate an involuntary re-rate. The new published rating is shown along with the previous (i.e. WAS) rating.

DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2020 Air-Conditioning, Heating, and Refrigeration Institute



we make life better™

CERTIFICATE NO.:

132518520519674749



Manual S Compliance Report

Entire House

Air Ducks Heating & Air, Inc.

Job:
Date: Dec 07, 2020
By:

2601 NW 76th Ave, Gainesville, Fla 32653 Phone: 352-215-4624 Email: Airducksac@gmail.com Web: Airducksac.com

Project Information

For: DWC Construction
Thornwood Lot 21, Fla

Cooling Equipment

Design Conditions

| | | | | | | |
|--------------------|--------|--------------------|-------|------|-------------------|--------|
| Outdoor design DB: | 91.9°F | Sensible gain: | 28035 | Btuh | Entering coil DB: | 78.0°F |
| Outdoor design WB: | 76.2°F | Latent gain: | 4835 | Btuh | Entering coil WB: | 63.9°F |
| Indoor design DB: | 75.0°F | Total gain: | 32870 | Btuh | | |
| Indoor RH: | 50% | Estimated airflow: | 1220 | cfm | | |

Manufacturer's Performance Data at Actual Design Conditions

| | | | |
|--------------------|------------|--------|------------------------------|
| Equipment type: | Split ASHP | | |
| Manufacturer: | Trane | Model: | 4TWR4036G1+TEM3A0C36S41++TDR |
| Actual airflow: | 1220 | cfm | |
| Sensible capacity: | 29280 | Btuh | 104% of load |
| Latent capacity: | 7320 | Btuh | 151% of load |
| Total capacity: | 36600 | Btuh | 111% of load SHR: 80% |

Heating Equipment

Design Conditions

| | | | | | | |
|--------------------|--------|------------|-------|------|-------------------|--------|
| Outdoor design DB: | 33.0°F | Heat loss: | 33629 | Btuh | Entering coil DB: | 66.6°F |
| Indoor design DB: | 68.0°F | | | | | |

Manufacturer's Performance Data at Actual Design Conditions

| | | | |
|-----------------------------|------------|--------|------------------------------|
| Equipment type: | Split ASHP | | |
| Manufacturer: | Trane | Model: | 4TWR4036G1+TEM3A0C36S41++TDR |
| Actual airflow: | 1220 | cfm | |
| Output capacity: | 34200 | Btuh | 102% of load |
| Supplemental heat required: | 0 | Btuh | |
| | | | Capacity balance: 33 °F |
| | | | Economic balance: -99 °F |

| | | | |
|------------------------|------------|--------|-------------------------------|
| Backup equipment type: | Elec strip | | |
| Manufacturer: | n/a | Model: | |
| Actual airflow: | 1220 | cfm | |
| Output capacity: | 6.6 | kW | 67% of load Temp. rise: 25 °F |

Meets all requirements of ACCA Manual S.



Wrightsoft

Right-Suite® Universal 2019 19.0.21 RSU23127

...ents\Wrightsoft HVAC\DWC lot 25 thorne wood.rup Calc = MJ8 Front Door faces: N

2021-Apr-21 12:58:52

Page 1



Residential Plans Examiner Review Form for HVAC System Design (Loads, Equipment, Ducts)

Form
RPER 1
15 Mar 09

Header Information

Contractor: Air Ducks Heating & Air, Inc.

Mechanical license:

Building plan #:

Home address (Street or Lot#, Block, Subdivision): Thornwood Lot 21, Entire House

REQUIRED ATTACHMENTS

Manual J1 Form (and supporting worksheets):
or MJ1AE Form* (and supporting worksheets):
OEM performance data (heating, cooling, blower):
Manual D Friction Rate Worksheet:
Duct distribution sketch:

ATTACHED

Yes ☐ No ☐
Yes ☐ No ☐
Yes ☐ No ☐
Yes ☐ No ☐
Yes ☐ No ☐

HVAC LOAD CALCULATION (IRC M1401.3)

Design Conditions

Winter Design Conditions

Outdoor temperature: 33 °F
Indoor temperature: 68 °F
Total heat loss: 33629 Btuh

Summer Design Conditions

Outdoor temperature: 92 °F
Indoor temperature: 75 °F
Grains difference: 47 gr/lb @ 50% RH
Sensible heat gain: 28932 Btuh
Latent heat gain: 4990 Btuh
Total heat gain: 33922 Btuh

Building Construction Information


Building

Orientation: Front Door faces North
North, East, West, South, Northeast, Northwest, Southeast, Southwest

Number of bedrooms: 0
Conditioned floor area: 1843 ft²
Number of occupants: 5

Windows

Eave overhang depth: 0 ft
Internal shade: blinds
Blinds, drapes, etc.
Number of skylights: 0



HVAC EQUIPMENT SELECTION (IRC M1401.3)

Heating Equipment Data

Equipment type: Split ASHP
Furnace, Heat pump, Boiler, etc.
Model: Trane
4TWR4036G1+TEM3A0C36S41++TDR
Heating output capacity: 0 Btuh
Heat pumps - capacity at winter design outdoor conditions
Aux. heating output capacity: 22460 Btuh

Cooling Equipment Data

Equipment type: Split ASHP
Air Conditioner, Heat pump, etc.
Model: Trane
4TWR4036G1+TEM3A0C36S41++TDR
Total cooling capacity: 0 Btuh
Sensible cooling capacity: 0 Btuh
Latent cooling capacity: 0 Btuh

Blower Data

Heating cfm: 1220
Cooling cfm: 1220
Static pressure: 0.50 in H2O
Fan's rated external static pressure for design airflow

HVAC DUCT DISTRIBUTION SYSTEM DESIGN (IRC M1601.1)

Design airflow: 1220 cfm
Equipment design ESP: 0.50 in H2O
Total device pressure losses: 0 in H2O
Available static pressure (ASP): 0.50 in H2O
Longest supply duct: 418 ft
Longest return duct: 97 ft
Total effective length (TEL): 515 ft
Friction rate: 0.097 in/100ft
Friction Rate = ASP ÷ (TEL × 100)
Duct Materials Used
Trunk duct: Fiberglass board
Branch duct: Round flex vinyl

I declare the load calculation, equipment, equipment selection and duct design were rigorously performed based on the building plan listed above. I understand the claims made on these forms will be subject to review and verification.

Contractor's printed name: _____

Contractor's signature: _____

Date: _____

Reserved for County, Town Municipality or Authority having jurisdiction use.

*Home qualifies for MJ1AE Form based on Abridged Edition Checklist



Load Short Form

Entire House

Air Ducks Heating & Air, Inc.

Job:
Date: Dec 07, 2020
By:

2601 NW 76th Ave, Gainesville, Fla 32653 Phone: 352-215-4624 Email: Airducksac@gmail.com Web: Airducksac.com

Project Information

For: DWC Construction
Thornwood Lot 21, Fla

Design Information

| | Htg | Clg | Infiltration | Simplified Average |
|-----------------------------|-----|-----|----------------------|--------------------|
| Outside db (°F) | 33 | 92 | Method | 0 |
| Inside db (°F) | 68 | 75 | Construction quality | |
| Design TD (°F) | 35 | 17 | Fireplaces | |
| Daily range | - | M | | |
| Inside humidity (%) | 50 | 50 | | |
| Moisture difference (gr/lb) | 29 | 47 | | |

HEATING EQUIPMENT

Make Trane
Trade TRANE
Model 4TWR4036G1
AHRI ref 10344969

Efficiency 8.5 HSPF
Heating input
Heating output 34200 Btuh @ 47°F
Temperature rise 26 °F
Actual air flow 1220 cfm
Air flow factor 0.036 cfm/Btuh
Static pressure 0.50 in H2O
Space thermostat
Capacity balance point = 33 °F

Backup: n/a

Input = 7 kW, Output = 22460 Btuh, 100 AFUE

COOLING EQUIPMENT

Make Trane
Trade TRANE
Cond 4TWR4036G1
Coil TEM3A0C36S41++TDR
AHRI ref 10344969

Efficiency 11.5 EER, 14 SEER
Sensible cooling 29280 Btuh
Latent cooling 7320 Btuh
Total cooling 36600 Btuh
Actual air flow 1220 cfm
Air flow factor 0.044 cfm/Btuh
Static pressure 0.50 in H2O
Load sensible heat ratio 0.85

| ROOM NAME | Area (ft²) | Htg load (Btuh) | Clg load (Btuh) | Htg AVF (cfm) | Clg AVF (cfm) |
|----------------|------------|-----------------|-----------------|---------------|---------------|
| Master | 316 | 7873 | 6299 | 286 | 274 |
| Wic 1 | 48 | 927 | 415 | 34 | 18 |
| wc | 40 | 58 | 100 | 2 | 4 |
| Master bath | 215 | 4005 | 2036 | 145 | 89 |
| living | 449 | 7161 | 8031 | 260 | 349 |
| kitchen/dining | 243 | 2168 | 3508 | 79 | 153 |
| bed 2 | 156 | 4573 | 2161 | 166 | 94 |
| bath | 54 | 1346 | 1682 | 49 | 73 |
| bed 3 | 168 | 2149 | 937 | 78 | 41 |
| hall | 18 | 0 | 0 | 0 | 0 |
| wic | 42 | 1751 | 1689 | 64 | 74 |
| Pantry | 42 | 0 | 0 | 0 | 0 |
| laundry | 70 | 1617 | 1176 | 59 | 51 |

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Right-Suite® Universal 2019 19.0.21 RSU23127

2021-Apr-21 12:58:53

Page 1

...ents\Wrightsoft HVAC\DWC lot 25 thorne wood.rup Calc = MJ8 Front Door faces: N

| | | | | | | |
|-------------------|---|------|-------|-------|------|------|
| Entire House | d | 1861 | 33629 | 28035 | 1220 | 1220 |
| Other equip loads | | | 0 | 0 | | |
| Equip. @ 0.97 RSM | | | | 27166 | | |
| Latent cooling | | | | 4835 | | |
| TOTALS | | 1861 | 33629 | 32001 | 1220 | 1220 |

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Right-Suite® Universal 2019 19.0.21 RSU23127

2021-Apr-21 12:58:53

Page 2

...ents\Wrightsoft HVAC\DWI lot 25 thorne wood.rup Calc = MJ8 Front Door faces: N

Project Information

For: DWC Construction
 Thornwood Lot 21, Fla

Notes:

Design Information

Weather: Gainesville Rgnl, FL, US

Winter Design Conditions

| | |
|------------|-------|
| Outside db | 33 °F |
| Inside db | 68 °F |
| Design TD | 35 °F |

Summer Design Conditions

| | |
|---------------------|----------|
| Outside db | 92 °F |
| Inside db | 75 °F |
| Design TD | 17 °F |
| Daily range | M |
| Relative humidity | 50 % |
| Moisture difference | 47 gr/lb |

Heating Summary

| | |
|--------------------------------|------------|
| Structure | 25863 Btuh |
| Ducts | 7766 Btuh |
| Central vent (0 cfm) (none) | 0 Btuh |
| Humidification | 0 Btuh |
| Piping | 0 Btuh |
| Equipment load | 33629 Btuh |

Sensible Cooling Equipment Load Sizing

| | |
|--------------------------------|------------|
| Structure | 17962 Btuh |
| Ducts | 10073 Btuh |
| Central vent (0 cfm) (none) | 0 Btuh |
| Blower | 0 Btuh |
| Use manufacturer's data | n |
| Rate/swing multiplier | 0.97 |
| Equipment sensible load | 27166 Btuh |

Infiltration

| | |
|----------------------|------------|
| Method | Simplified |
| Construction quality | Average |
| Fireplaces | 0 |

Latent Cooling Equipment Load Sizing

| | |
|--------------------------------|-----------|
| Structure | 2713 Btuh |
| Ducts | 2122 Btuh |
| Central vent (0 cfm) (none) | 0 Btuh |
| Equipment latent load | 4835 Btuh |

| | Heating | Cooling |
|------------------|---------|---------|
| Area (ft²) | 1843 | 1843 |
| Volume (ft³) | 16207 | 16207 |
| Air changes/hour | 0.38 | 0.20 |
| Equiv. AVF (cfm) | 103 | 54 |

| | |
|---------------------------------------|------------|
| Equipment Total Load (Sen+Lat) | 32001 Btuh |
| Req. total capacity at 0.80 SHR | 2.8 ton |

Heating Equipment Summary

| | |
|---|-------------------|
| Make | Trane |
| Trade | TRANE |
| Model | 4TWR4036G1 |
| AHRI ref | 10344969 |
| Efficiency | 8.5 HSPF |
| Heating input | |
| Heating output | 34200 Btuh @ 47°F |
| Temperature rise | 26 °F |
| Actual air flow | 1220 cfm |
| Air flow factor | 0.036 cfm/Btuh |
| Static pressure | 0.50 in H2O |
| Space thermostat | |
| Capacity balance point = 33 °F | |
| Backup: n/a | |
| Input = 7 kW, Output = 22460 Btuh, 100 AFUE | |

Cooling Equipment Summary

| | |
|--------------------------|-------------------|
| Make | Trane |
| Trade | TRANE |
| Cond | 4TWR4036G1 |
| Coil | TEM3A0C36S41++TDR |
| AHRI ref | 10344969 |
| Efficiency | 11.5 EER, 14 SEER |
| Sensible cooling | 29280 Btuh |
| Latent cooling | 7320 Btuh |
| Total cooling | 36600 Btuh |
| Actual air flow | 1220 cfm |
| Air flow factor | 0.044 cfm/Btuh |
| Static pressure | 0.50 in H2O |
| Load sensible heat ratio | 0.85 |

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Duct System Summary

Entire House

Air Ducks Heating & Air, Inc.

Job:
Date: Dec 07, 2020
By:

2601 NW 76th Ave, Gainesville, Fla 32653 Phone: 352-215-4624 Email: Airducksac@gmail.com Web: Airducksac.com

Project Information

For: DWC Construction
Thornwood Lot 21, Fla

| | | |
|------------------------------------|-----------------------------------|-----------------------------------|
| | Heating | Cooling |
| External static pressure | 0.50 in H ₂ O | 0.50 in H ₂ O |
| Pressure losses | 0 in H ₂ O | 0 in H ₂ O |
| Available static pressure | 0.50 in H ₂ O | 0.50 in H ₂ O |
| Supply / return available pressure | 0.406 / 0.094 in H ₂ O | 0.406 / 0.094 in H ₂ O |
| Lowest friction rate | 0.097 in/100ft | 0.097 in/100ft |
| Actual air flow | 1220 cfm | 1220 cfm |
| Total effective length (TEL) | 515 ft | |

Supply Branch Detail Table

| Name | Design (Btuh) | Htg (cfm) | Clg (cfm) | Design FR | Diam (in) | H x W (in) | Duct Matl | Actual Ln (ft) | Ftg.Eqv Ln (ft) | Trunk |
|----------------|---------------|-----------|-----------|-----------|-----------|------------|-----------|----------------|-----------------|-------|
| Master | h 3937 | 143 | 137 | 0.099 | 7.0 | 0x0 | VIFx | 45.2 | 365.0 | st3 |
| Master bath | h 4005 | 145 | 89 | 0.097 | 6.0 | 0x0 | VIFx | 48.4 | 370.0 | st3 |
| Master-A | h 3937 | 143 | 137 | 0.099 | 7.0 | 0x0 | VIFx | 54.9 | 355.0 | st3 |
| Wic 1 | h 927 | 34 | 18 | 0.105 | 4.0 | 0x0 | VIFx | 51.0 | 335.0 | st3 |
| bath | c 1682 | 49 | 73 | 0.154 | 6.0 | 0x0 | VIFx | 28.0 | 235.0 | st2 |
| bed 2 | h 4573 | 166 | 94 | 0.201 | 7.0 | 0x0 | VIFx | 31.8 | 170.0 | st2 |
| bed 3 | h 2149 | 78 | 41 | 0.148 | 6.0 | 0x0 | VIFx | 19.0 | 255.0 | st2 |
| kitchen/dining | c 3508 | 79 | 153 | 0.153 | 8.0 | 0x0 | VIFx | 21.0 | 245.0 | st2 |
| laundry | h 1617 | 59 | 51 | 0.191 | 6.0 | 0x0 | VIFx | 8.0 | 205.0 | st1 |
| living | c 4015 | 130 | 175 | 0.135 | 7.0 | 0x0 | VIFx | 31.0 | 270.0 | st3 |
| living-A | c 4015 | 130 | 175 | 0.132 | 7.0 | 0x0 | VIFx | 37.0 | 270.0 | st3 |
| wc | c 100 | 2 | 4 | 0.104 | 4.0 | 0x0 | VIFx | 44.3 | 345.0 | st3 |
| wic | c 1689 | 64 | 74 | 0.184 | 4.0 | 0x0 | VIFx | 15.0 | 205.0 | st1 |

Supply Trunk Detail Table

| Name | Trunk Type | Htg (cfm) | Clg (cfm) | Design FR | Veloc (fpm) | Diam (in) | H x W (in) | Duct Material | Trunk |
|------|------------|-----------|-----------|-----------|-------------|-----------|------------|---------------|-------|
| st1 | Peak AVF | 1220 | 1220 | 0.097 | 732 | 15.7 | 8 x 30 | RectFbg | st1 |
| st3 | Peak AVF | 726 | 735 | 0.097 | 661 | 13.0 | 8 x 20 | RectFbg | |
| st2 | Peak AVF | 371 | 361 | 0.148 | 668 | 9.3 | 8 x 10 | RectFbg | |



Wrightsoft

Right-Suite® Universal 2019 19.0.21 RSU23127

...ents\Wrightsoft HVAC\DWC lot 25 thorne wood.rup Calc = MJ8 Front Door faces: N

2021-Apr-21 12:58:53

Page 1

Return Branch Detail Table

| Name | Grille Size (in) | Htg (cfm) | Clg (cfm) | TEL (ft) | Design FR | Veloc (fpm) | Diam (in) | H x W (in) | Stud/Joist Opening (in) | Duct Matl | Trunk |
|------|------------------|-----------|-----------|----------|-----------|-------------|-----------|------------|-------------------------|-----------|-------|
| rb3 | 0x 0 | 200 | 165 | 70.2 | 0.134 | 573 | 8.0 | 0x 0 | | VIFx | |
| rb4 | 0x 0 | 313 | 187 | 90.0 | 0.105 | 898 | 8.0 | 0x 0 | | VIFx | |
| rb2 | 0x 0 | 257 | 401 | 74.8 | 0.126 | 287 | 16.0 | 0x 0 | | VIFx | |
| rb1 | 0x 0 | 449 | 467 | 97.0 | 0.097 | 595 | 12.0 | 0x 0 | | VIFx | |

Certificate of Product Ratings

AHRI Certified Reference Number : 201763659

Date : 12-07-2020

Model Status : Active

AHRI Type : HRCU-A-CB (Split System: Heat Pump with Remote Outdoor Unit-Air-Source)

Series : XR14

Outdoor Unit Brand Name : TRANE

Outdoor Unit Model Number (Condenser or Single Package) : 4TWR4036G1

Indoor Unit Model Number (Evaporator and/or Air Handler) : TEM4A0B36S31+TDR

The manufacturer of this TRANE product is responsible for the rating of this system combination.

Rated as follows in accordance with the latest edition of AHRI 210/240 with Addendum 1, Performance Rating of Unitary Air-Conditioning & Air-Source Heat Pump Equipment and subject to rating accuracy by AHRI-sponsored, independent, third party testing:

Cooling Capacity (A2) - Single or High Stage (95F), btuh : 35000

SEER : 14.00

EER (A2) - Single or High Stage (95F) : 11.50

Heating Capacity (H12) - Single or High Stage (47F) : 34400

HSPF (Region IV) : 8.20

†"Active" Model Status are those that an AHRI Certification Program Participant is currently producing AND selling or offering for sale; OR new models that are being marketed but are not yet being produced. "Production Stopped" Model Status are those that an AHRI Certification Program Participant is no longer producing BUT is still selling or offering for sale.

Ratings that are accompanied by WAS indicate an involuntary re-rate. The new published rating is shown along with the previous (i.e. WAS) rating.

DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2020 Air-Conditioning, Heating, and Refrigeration Institute



we make life better™

CERTIFICATE NO.:

132518520519674749