

1011 N Causeway Blvd, Suite 19 ◆Mandeville, Louisiana 70471◆ Phone: 985.624.5001◆ Fax: 985.624.5303

Monday, April 3, 2023

Property Owner: Phillip Noegel

Property Address: 345 SW Seminole Terrace, Lake City, FL 32024

#### **RE:** Goundmount Installation

I have reviewed the address referenced above to determine the adequacy of the existing area supports the proposed installation of an array of solar panels in the ground.

The photovoltaic ground mount structure offered by Unirac is found to be of sufficient capacity for the design loads when installed in accordance with the drawings and calculations attached, and manufacturer's instructions. The foundation shall be installed as marked on the drawings to the depth specified in the drawing table. To the best of my professional knowledge and belief, the product and system installation will be in compliance with all state and local building codes and guidelines at the time of our review.

#### **Evaluation Criteria:**

Wind Speed: 108 mph

Applied Codes: ASCE 7-16 FBC 2020 NEC 2017

Risk Category: I

Wind Exposure Category: B Ground Snow Load: 0 psf Footing Depth: 5.25 ft

N-S Leg Spacing: 81.29" E-W Leg Spacing: 92.47"

#### **Connection of Array to Ground:**

Manufacturer: UNIRAC

Model: ULA (Unirac Large Array)

Foundation Type: Drilled Cast-In-Hole Concrete Pile

#### **Limitations:**

Unirac's ground mount system is to be installed per manufacturer's specifications and in accordance with accepted industry-wide safety standards. Electrical engineering is beyond our scope of the installation.

PRINCIPAL ENGINEERING, INC. 1011 N. CAUSEWAY BLVD. STE 19 MANDEVILLE, LA 70471 985.624.5001 INFO@PI-AEC.COM FLORIDA FIRM NO. 30649

This item has been digitally signed and sealed by

Henry I. DiFranco, Jr., P.E.

document are not considered

signed and sealed and the signature must be verified

on any electronic copies.

on April 3, 2023

Printed copies of this

PRINCIPAL Infrastructure<sup>TM</sup>

Architecture • Engineering • Construction

# NEW PHOTOVOLTAIC SYSTEM 11.06 KW DC 345 SW SEMINOLE TER, LAKE CITY, FL 32024





# CONTRACTOR



22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490 PROJECT NAME & ADDRESS

PHILLIP NOEGEL

# 345 SW SEMINOLE TER. LAKE CITY. FL 32024

**COUNTY:-COLUMBIA COUNTY** 

#### SYSTEM SIZE

DC SIZE: 11.060 KW DC-(STC) AC SIZE: 8.120 KW AC



This item has been digitally signed and sealed by Henry I. DiFranco, Jr., P.E. on April 3, 2023 Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

PRINCIPAL ENGINEERING, INC. 1011 N. CAUSEWAY BLVD. STE 19 MANDEVILLE, LA 70471 985.624.5001 INFO@PI-AEC.COM FLORIDA FIRM NO. 30649

SHEET TITLE

# **COVER PAGE**

DRAWN DATE	3/31/2023
DRAWN BY	TSP

SHEET NUMBER

G-001

# **GENERAL NOTES**

#### 1.1.1 PROJECT NOTES:

1.1.2 THIS PHOTOVOLTAIC (PV) SYSTEM SHALL COMPLY WITH THE NATIONAL ELECTRIC CODE (NEC) ARTICLE 690, ALL MANUFACTURERS'S LISTING AND INSTALLATION INSTRUCTIONS, AND THE RELEVANT CODES AS SPECIFIED BY THE AUTHORITY HAVING JURISDICTION'S (AHJ) APPLICABLE CODES. 1.1.3 THE UTILITY INTERCONNECTION APPLICATION MUST BE APPROVED AND PV SYSTEM INSPECTED PRIOR TO PARALLEL OPERATION 1.1.4 GROUND FAULT DETECTION AND INTERRUPTION (GFDI) DEVICE IS INTEGRATED WITH THE MICRO-INVERTER IN ACCORDANCE WITH NEC 690.41(B) 1.1.5 ALL PV SYSTEM COMPONENTS; MODULES, UTILITY-INTERACTIVE INVERTERS, AND SOURCE CIRCUIT COMBINER BOXES ARE IDENTIFIED AND LISTED FOR USE IN PHOTOVOLTAIC SYSTEMS AS REQUIRED BY NEC 690.4: PV MODULES: UL1703. IEC61730. AND IEC61215. AND NFPA 70 CLASS C FIRE INVERTERS: UL 1741 CERTIFIED, IEEE 1547, 929, 519 COMBINER BOX(ES): UL 1703 OR UL 1741 ACCESSORY

1.1.6 MAX DC VOLTAGE CALCULATED USING MANUFACTURER PROVIDED TEMP COEFFICIENT FOR VOC. IF UNAVAILABLE, MAX DC VOLTAGE CALCULATED ACCORDING TO NEC 690.7.

1.1.7 ALL INVERTERS, PHOTOVOLTAIC MODULES, PHOTOVOLTAIC PANELS, AND SOURCE CIRCUIT COMBINERS INTENDED FOR USE IN A PHOTOVOLTAIC POWER SYSTEM WILL BE IDENTIFIED AND LISTED FOR THE APPLICATION PER 690.4. SHALL BE INSTALLED ACCORDING TO ANY INSTRUCTIONS FROM LISTING OR LABELING [NEC 110.3].

1.1.8 ALL SIGNAGE TO BE PLACED IN ACCORDANCE WITH LOCAL BUILDING CODE. IF EXPOSED TO SUNLIGHT. IT SHALL BE UV RESISTANT. ALL PLAQUES AND SIGNAGE WILL BE INSTALLED AS REQUIRED BY THE NEC AND AHJ.

#### 1.2.1 SCOPE OF WORK:

1.2.2 PRIME CONTRACTOR IS RESPONSIBLE FOR THE DESIGN AND SPECIFICATIONS OF THE GRID-TIED PHOTOVOLTAIC SYSTEM RETROFIT. PRIME CONTRACTOR WILL BE RESPONSIBLE FOR COLLECTING EXISTING ONSITE REQUIREMENTS TO DESIGN, SPECIFY, AND INSTALL THE EXTERIOR ULA GROUND-MOUNTED PORTION OF THE PHOTOVOLTAIC SYSTEMS DETAILED IN THIS **DOCUMENT** 

#### 1.3.1 WORK INCLUDES:

1.3.2 PV RACKING SYSTEM INSTALLATION - UNIRAC SOLAR

1.3.3 PV MODULE AND INVERTER INSTALLATION - CANADIAN SOLAR CS3N-395MS / ENPHASE IQ8PLUS-72-2-US INVERTER

1.3.4 PV EQUIPMENT ULA GROUND MOUNT

1.3.5 PV SYSTEM WIRING TO A GROUND-MOUNTED JUNCTION BOX

1.3.6 PV LOAD CENTERS (IF INCLUDED)

1.3.7 PV METERING/MONITORING (IF INCLUDED)

1.3.8 PV DISCONNECTS

1.3.9 PV GROUNDING ELECTRODE & BONDING TO (E) GEC

1.3.10 PV FINAL COMMISSIONING

1.3.11 (E) ELECTRICAL EQUIPMENT RETROFIT FOR PV

1.3.12 SIGNAGE PLACED IN ACCORDANCE WITH LOCAL BUILDING CODE

#### PROJECT INFORMATION

NAME: PHILLIP NOEGEL

#### **CONTRACTOR NAME**

ADT SOLAR LLC PHONE: 5052180838

#### SCOPE OF WORK

PTC: 28 x 372.75W = 10.44 kW DC

ATTACHMENT TYPE: ULA GROUND MOUNT

UTILITY METER UPGRADE: NO

#### **AUTHORITIES HAVING JURISDICTION**

**BUILDING: COLUMBIA COUNTY** 

CONSTRUCTION: SINGLE-FAMILY **ZONING:** RESIDENTIAL

**OWNER** 

# SYSTEM SIZE: STC:28 X 395W= 11.06 kW DC

(28) CANADIAN SOLAR CS3N-395MS (28) ENPHASE IQ8PLUS-72-2-US

MSP UPGRADE: YES

**ZONING: COLUMBIA COUNTY** 

UTILITY: FLORIDA POWER & LIGHT CO. - FPL (FL)

METER NO: ACD2110

#### **DESIGN SPECIFICATION**

OCCUPANCY:

GROUND SNOW LOAD: REFER STRUCTURAL LETTER

WIND EXPOSURE: REFER STRUCTURAL WIND SPEED: LETTER 108 MPH

#### APPLICABLE CODES & STANDARDS

IBC 2018, IRC 2018, FBC 2020 (7TH EDITION) **BUILDING:** 

**ELECTRICAL: NEC 2017** IFC 2020 FIRE:

# SATELLITE VIEW

**VICINITY MAP** 

# SHEET INDEX

G-001

0 001	OUVERTINGE	
G-002	NOTES	
A-101	SITE PLAN	
A-102	ELECTRICAL PLAN	
A-103	ATTACHMENT PLAN	
E-601	LINE DIAGRAM	
E-602	ELECTRICAL CALCULATIONS	
E-603	PLACARD	
R-001	RESOURCE DOCUMENT	
R-002	RESOURCE DOCUMENT	
R-003	RESOURCE DOCUMENT	
R-004	RESOURCE DOCUMENT	
R-005	RESOURCE DOCUMENT	
R-006	RESOURCE DOCUMENT	
R-007	RESOURCE DOCUMENT	
R-008 - R-012	RESOURCE DOCUMENT	

#### 2.1.1 SITE NOTES:

- 2.1.2 A LADDER WILL BE IN PLACE FOR INSPECTION IN COMPLIANCE WITH OSHA REGULATIONS.
- 2.1.3 THE PV MODULESARECONSIDERED NON-COMBUSTIBLE AND THIS SYSTEM IS A UTILITY INTERACTIVE SYSTEM WITH NO STORAGE BATTERIES.
- 2.1.4 THE SOLAR PV INSTALLATION WILL NOT OBSTRUCT ANY PLUMBING, MECHANICAL, OR BUILDING ROOF VENTS.
- 2.1.5 PROPERACCESS AND WORKING CLEARANCE AROUND EXISTING AND PROPOSED ELECTRICAL EQUIPMENT WILL BE PROVIDED AS PERSECTION NEC 110.26.
- 2.1.6 ROOF COVERINGS SHALL BE DESIGNED, INSTALLED, AND MAINTAINED IN ACCORDANCE WITH THIS CODE AND THE APPROVED MANUFACTURER'S INSTRUCTIONS SUCH THAT THE ROOF COVERING SERVES TO PROTECT THE BUILDING OR STRUCTURE.
- 2.2.1 EQUIPMENT LOCATIONS:
- 2.2.2 ALL EQUIPMENT SHALL MEET MINIMUM SETBACKS AS REQUIRED BY 2.5.5 EQUIPMENT GROUNDING CONDUCTORS SHALLBE SIZED NEC 110.26.
- 2.2.3 WIRING SYSTEMS INSTALLED IN DIRECT SUNLIGHT MUST BE RATED MANUFACTORERS' INSTRUCTIONS. FOR EXPECTED OPERATING TEMPERATURE AS SPECIFIED BY NEC 690.31 2.5.6 EACH MODULE WILL BE GROUNDED USING WEEB (A),(C) AND NEC TABLES 310.15 (B)(2)(A) AND 310.15 (B)(3)(C).
- 2.2.4 JUNCTION AND PULL BOXES PERMITTED INSTALLED UNDER PV MODULES ACCORDING TO NEC 690.34.
- 2.2.5 ADDITIONAL AC DISCONNECT(S) SHALL BE PROVIDED WHERE THE INVERTER IS NOT WITHIN SIGHT OF THE AC SERVICING DISCONNECT. 2.2.6 ALL EQUIPMENT SHALL BE INSTALLED ACCESSIBLE TO QUALIFIED PERSONNEL ACCORDING TO NEC APPLICABLE CODES.
- 2.2.7 ALL COMPONENTS ARE LISTED FOR THEIR PURPOSE AND RATED FOR OUTDOOR USAGE WHEN APPROPRIATE.

#### 2.3.1 STRUCTURAL NOTES:

- 2.3.2 RACKING SYSTEM & PV ARRAY WILL BE INSTALLED ACCORDING TO CODE-COMPLIANT INSTALLATION MANUAL. TOP CLAMPS REQUIRE A DESIGNATED SPACE BETWEEN MODULES, AND RAILS MUSTALSO EXTEND A MINIMUM DISTANCE BEYOND EITHER EDGE OF THE ARRAY/SUBARRAY, ACCORDING TO RAI MANUFACTURER'S INSTRUCTIONS.
- 2.3.3 JUNCTION BOX WILL BE INSTALLED PER MANUFACTURERS' SPECIFICATIONS. IF ROOF-PENETRATING TYPE, IT SHALL BE FLASHED & SEALED PER LOCAL REQUIREMENTS.
- 2.3.4 ROOFTOP PENETRATIONS FOR PV RACEWAY WILLBE COMPLETED AND SEALED W/ APPROVED CHEMICAL SEALANT PER CODE BY A LICENSED CONTRACTOR.
- 2.3.5 ALL PV RELATED ROOF ATTACHMENTS TO BE SPACED NO GREATER THAN THE SPAN DISTANCE SPECIFIED BY THE RACKING MANUFACTURER.
- 2.3.6 WHEN POSSIBLE, ALL PV RELATED RACKING ATTACHMENTS WILL BE STAGGERED AMONGST THE ROOF FRAMING MEMBERS.

#### 2.4.1 WIRING & CONDUIT NOTES:

- 2.4.2 ALL CONDUIT AND WIRE WILL BE LISTED AND APPROVED FOR THEIR PURPOSE. CONDUIT AND WIRE SPECIFICATIONS AREBASED ON MINIMUM CODE REQUIREMENTS AND ARE NOT MEANT TO LIMIT UP-SIZING.
- 2.4.3 CONDUCTORS SIZED ACCORDING TO NEC 690.8, NEC 690.7.
- 2.4.4 VOLTAGE DROP LIMITED TO 1.5%.
- 2.4.5 DC WIRING LIMITED TO MODULE FOOTPRINT. MICROINVERTER WIRING SYSTEMS SHALL BE LOCATED AND SECURED UNDER THE ARRAY W/ SUITABLE WIRING CLIPS.

2.4.6 AC CONDUCTORS COLORED OR MARKED AS FOLLOWS: PHASE A OR L1- BLACK PHASE B OR L2- RED. OR OTHER CONVENTION IF THREE PHASE PHASE C OR L3- BLUE. YELLOW, ORANGE\*\*, OR OTHER CONVENTION NEUTRAL-WHITE OR GREY IN 4-WIRE DELTA CONNECTED SYSTEMS THE PHASE WITH HIGHER VOLTAGE TO BE MARKED ORANGE [NEC 110.15].

#### 2.5.1 GROUNDING NOTES:

2.5.2 GROUNDING SYSTEM COMPONENTS SHALL BE LISTED FOR THEIR PURPOSE, AND GROUNDING DEVISES EXPOSED TO THE ELEMENTS SHALL BE RATED FOR SUCH USE.

2.5.3 PV EQUIPMENT SHALL BE GROUNDED ACCORDING TO NEC 690.43 AND MINIMUM NEC TABLE 250.122.

2.5.4 METAL PARTS OF MODULE FRAMES, MODULE RACKING, AND ENCLOSURES CONSIDERED GROUNDED IN ACCORD WITH 250.134 AND 250.136(A).

ACCORDING TO NEC 690.45 AND MICROINVERTER

**GROUNDING CLIPS AS SHOWN IN** 

MANUFACTURERDOCUMENTATION AND APPROVED BY THE AHJ. IF WEEBS ARE NOT USED, MODULE GROUNDING LUGS MUST BE INSTALLED AT THE SPECIFIED GROUNDING LUG HOLES PER THE MANUFACTURERS' INSTALLATION REQUIREMENTS.

2.5.7 THE GROUNDING CONNECTION TO A MODULE SHALL BE ARRANGED SUCH THAT THE REMOVAL OFA MODULE DOES NOT INTERRUPT A GROUNDING CONDUCTOR TO ANOTHER MODULE. 2.5.8 GROUNDING AND BONDING CONDUCTORS, IF INSULATED, SHALL BE COLORED GREEN OR MARKED GREEN IF #4 AWG OR LARGER [NEC 250.119]

2.5.9 THE GROUNDING ELECTRODE SYSTEM COMPLIES WITH NEC 690.47 AND NEC 250.50 THROUGH 250.106. IF EXISTING SYSTEM IS INACCESSIBLE. OR INADEQUATE. A GROUNDING ELECTRODE SYSTEM PROVIDED ACCORDING TO NEC 250, NEC 690,47 AND

2.5.10 GROUND-FAULT DETECTION SHALL COMPLY WITH NEC 690.41(B)(1) AND (2) TO REDUCE FIRE HAZARDS

#### 2.6.1 DISCONNECTION AND OVER-CURRENT PROTECTION NOTES:

2.6.2 DISCONNECTING SWITCHES SHALL BE WIRED SUCH THAT WHENTHE SWITCH IS OPENED THE CONDUCTORS REMAINING ENERGIZED ARECONNECTED TO THE TERMINALS MARKED "LINE SIDE" (TYPICALLY THE UPPER TERMINALS). 2.6.3 DISCONNECTS TO BE ACCESSIBLE TO QUALIFIED UTILITY PERSONNEL, BE LOCKABLE, AND BE A VISIBLE-BREAK SWITCH 2.6.4 PV SYSTEM CIRCUITS INSTALLED ON OR IN BUILDINGS SHALL INCLUDE A RAPID SHUTDOWN FUNCTION TO REDUCE SHOCK HAZARD FOR EMERGENCY RESPONDERS IN ACCORDANCE WITH 690.12(A) THROUGH (D). 2.6.5 ALL OCPD RATINGS AND TYPES SPECIFIED ACCORDING TO NEC 690.8, 690.9, AND 240.

2.6.6 MICROINVERTER BRANCHES CONNECTED TO A SINGLE BREAKER OR GROUPED FUSES IN ACCORDANCE WITH NEC 110.3(B).

2.6.7 IF REQUIRED BY AHJ. SYSTEM WILL INCLUDE ARC-FAULT CIRCUIT PROTECTION ACCORDING TO NEC 690.11 AND UL1699B.

#### 2.7.1 INTERCONNECTION NOTES:

2.7.2 LOAD-SIDE INTERCONNECTION SHALL BE IN ACCORDANCE WITH [NEC 705.12 (B)] 2.7.3 THE SUM OF THE UTILITY OCPD AND INVERTER CONTINUOUS OUTPUT MAY NOT EXCEED 120% OF BUSBAR RATING [NEC 705.12(B)(2)(3)(b)]. 2.7.4 THE SUM OF 125 PERCENT OF THE POWER SOURCE(S) OUTPUT CIRCUIT CURRENT AND THE RATING OF THE OVERCURRENT DEVICE PROTECTING THE BUSBAR SHALL NOT EXCEED 120 PERCENT OF THE AMPACITY OF THE BUSBAR, PV DEDICATED BACKFEED BREAKERS MUST BE LOCATED OPPOSITE END OF THE BUS FROM THE UTILITY SOURCE OCPD [NEC 705.12(B)(2)(3)].

2.7.5 AT MULTIPLE ELECTRIC POWER SOURCES OUTPUT COMBINER PANEL. TOTAL RATING OF ALL OVERCURRENT DEVICES SHALL NOT EXCEED AMPACITY OF BUSBAR, HOWEVER, THE COMBINED OVERCURRENT DEVICE MAY BE EXCLUDED ACCORDING TO NEC 705.12 (B)(2)(3)(C). 2.7.6 FEEDER TAP INTERCONECTION (LOADSIDE) ACCORDING TO NEC 705.12 (B)(2)(1) 2.7.7 SUPPLY SIDE TAP INTERCONNECTION ACCORDING TO NEC 705.12 (A) WITH SERVICE ENTRANCE CONDUCTORS IN ACCORDANCE WITH NEC 230.42 2.7.8BACKFEEDING BREAKER FOR ELECTRIC POWER SOURCES OUTPUT IS EXEMPT FROM ADDITIONAL FASTENING [NEC 705.12 (B)(5)].

#### CONTRACTOR



22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

PROJECT NAME & ADDRESS


PHILLIP NOEGEL

## 345 SW SEMINOLE TER. LAKE CITY. FL 32024

**COUNTY:-COLUMBIA COUNTY** 

#### SYSTEM SIZE

DC SIZE: 11.060 KW DC-(STC) AC SIZE: 8.120 KW AC



This item has been digitally signed and sealed by Henry I. DiFranco, Jr., P.E. on April 3, 2023 Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

PRINCIPAL ENGINEERING, INC. 1011 N. CAUSEWAY BLVD. STE 19 MANDEVILLE, LA 70471 985.624.5001 INFO@PI-AEC.COM FLORIDA FIRM NO. 30649


SHEET TITLE

# NOTES

DRAWN DATE	3/31/2023
DRAWN BY	TSP

SHEET NUMBER

G-002



CONTRACTOR



22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

PROJECT NAME & ADDRESS


PHILLIP NOEGEL

345 SW SEMINOLE TER, LAKE CITY, FL 32024

**COUNTY:-COLUMBIA COUNTY** 

SYSTEM SIZE

DC SIZE: 11.060 KW DC-(STC) AC SIZE: 8.120 KW AC



This item has been digitally signed and sealed by Henry I. DiFranco, Jr., P.E. on April 3, 2023 Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

PRINCIPAL ENGINEERING, INC. 1011 N. CAUSEWAY BLVD. STE 19 MANDEVILLE, LA 70471 985.624.5001 INFO@PI-AEC.COM FLORIDA FIRM NO. 30649


SHEET TITLE

# SITE PLAN

DRAWN DATE	3/31/2023
DRAWN BY	TSP

SHEET NUMBER

A-101



- CLAMP FOOTING DEPTH - 5.25 FT - SM HD RAIL FOOTING DIAMETER - 24.00" - SQUARE BRACE - PIPE-1,2 (2" SCH 40 GAL PIPE) - PIPE 3 (2" SCH 40 GAL PIPE) PIPE-1 2'-8"-7'-8" ..6-.9 44'-8" PIPE-2 -PIPE-3 ARRAY 1 TILT- 30 DEG AZIMUTH - 180 DEG 1 ATTACHMENT PLAN

**SCALE:**1/4"=1'-0"

CONTRACTOR



22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

PROJECT NAME & ADDRESS

PHILLIP NOEGEL

# 345 SW SEMINOLE TER, LAKE CITY, FL 32024

**COUNTY:-COLUMBIA COUNTY** 

#### SYSTEM SIZE

DC SIZE: 11.060 KW DC-(STC) AC SIZE: 8.120 KW AC



This item has been digitally signed and sealed by Henry I. DiFranco, Jr., P.E. on April 3, 2023 Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

PRINCIPAL ENGINEERING, INC. 1011 N. CAUSEWAY BLVD. STE 19 MANDEVILLE, LA 70471 985.624.5001 INFO@PI-AEC.COM FLORIDA FIRM NO. 30649

SHEET TITLE

# ATTACHMENT PLAN

DRAWN DATE	3/31/2023
DRAWN BY	TSP

SHEET NUMBER


A-103

$\checkmark \checkmark \checkmark \lor \lor \lor \lor \lor \checkmark$	V V V V V V V V V V V V V V V V V V V	
SOLAR MODULE SPECIFICATIONS		
MANUFACTURER / MODEL #	CANADIAN SOLAR CS3N-395MS	
VMP	37.0V	
IMP	10.68A	
VOC	44.3V	
ISC	11.44A	
TEMP. COEFF. VOC	-0.26%/°C	
MODULE DIMENSION	76.4"L x 41.3"W x 1.38"D (In Inch)	

<u>INVERTER SPECIFICATIONS</u>		
MANUFACTURER / MODEL #	ENPHASE IQ8PLUS-72-2-US MICROINVERTER	
MIN/MAX DC VOLT RATING	30V MIN/ 58V MAX	
MAX INPUT POWER	235W-440W	
NOMINAL AC VOLTAGE RATING	240V/ 211-264V	
MAX AC CURRENT	1.21A	
MAX MODULES PER STRING	13 (SINGLE PHASE)	
MAX OUTPUT POWER	290 VA	

WIRE /CONDUIT SCHEDULE		
TAG	DESCRIPTION	
1	(6)#10 THWN-2 ON EXTERIOR & (1)#10 THWN-2 GROUND / (GN)	
2	(3)#6 THWN-2 & (1)#10 THWN-2 GROUND /(GN) (IN TRENCH 18" DEEP, 60 FEET APPROX. CONDUIT) (3)#4 USE-2 AL & (1)#10 USE-2 AL DIRECT BURIAL (IN TRENCH 24" DEEP, 60 FEET APPROX. CONDUIT)	
3	(3)#6 THWN-2 & (1)#10 THWN-2 GROUND / (GN)	
4	(1)#6 BARE GROUND	
5	(3)#1/0 THWN-2 & (1)#10 THWN-2 GROUND / (GN)	
6	(3)#1/0 THWN-2 / (GN)	

DC SIZE 28 X 395W = 11.060 kW DC-STC AC SIZE 28X 290W = 8.120 kW AC



(GN) GENERAL CONDUIT NOTE:

CONDUIT TO BE UL LISTED FOR WET LOCATIONS AND UV PROTECTED (EX. -EMT,SCH 80 PVC OR RMC)\*FMC MAYBE USED IN INDOOR APPLICATIONS WHERE PERMITTED BY NEC ART .348

PANEL UPGRADE INSTALL NEW 225A RATED 150A MAIN BREAKER PANEL

AC DISCONNECT MUST BE WITHIN 10FEET OF UTILITY METER

#### CONTRACTOR



22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

PROJECT NAME & ADDRESS


PHILLIP NOEGEL

# 345 SW SEMINOLE TER, LAKE CITY, FL 32024

**COUNTY:-COLUMBIA COUNTY** 

#### SYSTEM SIZE

DC SIZE: 11.060 KW DC-(STC) AC SIZE: 8.120 KW AC



This item has been digitally signed and sealed by Nestor J. Houghton, P.E. on April 3, 2023 Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

PRINCIPAL ENGINEERING, INC.

1011 N. CAUSEWAY BLVD. STE 19

MANDEVILLE, LA 70471

985.624.5001

INFO@PI-AEC.COM

FLORIDA FIRM NO. 30649

SHEET TITLE

# LINE DIAGRAM

$\rfloor \mid$	DRAWN DATE	3/31/2023
	DRAWN BY	TSP

SHEET NUMBER

E-601

AMBIENT TEMPERATURE SPECS	
<u>/                                    </u>	
RECORD LOW TEMP	-5°
AMBIENT TEMP (HIGH TEMP 2%)	34°
CONDUIT HEIGHT	0.5"
CONDUCTOR TEMPERATURE RATE	90°

PERCENT OF VALUES	NUMBER OF CURRENT CARRYING CONDUCTORS
.80	4-6
.70	7-9
.50	10-20

# **CALCULATIONS:**

# 1. CURRENT CARRYING CONDUCTOR

(A) <u>BEFORE PV DEDICATED SUB PANEL</u>
AMBIENT TEMPERATURE - (34)°C ...NEC 310.15(B)(3)(c)
TEMPERATURE DERATE FACTOR - 0.96 ...NEC 310.15(B)(2)(a)
GROUPING FACTOR - 0.80...NEC 310.15(B)(3)(a)

# **CONDUCTOR AMPACITY**

- $= (INV O/P CURRENT) \times 1.25 / A.T.F / G.F ...NEC 690.8(B)$
- $= [(10 \times 1.21) \times 1.25] / [0.96 \times 0.80]$
- = 19.69A

SELECTED CONDUCTOR - #10 THWN-2 ...NEC 310.15(B)(16)

(B) AFTER PV DEDICATED SUB PANEL TEMPERATURE DERATE FACTOR - 0.96 GROUPING FACTOR - 1

# **CONDUCTOR AMPACITY**

- $= (TOTAL INV O/P CURRENT) \times 1.25 / 0.96 / 1 ... NEC 690.8(B)$
- $= [(28 \times 1.21) \times 1.25] / [0.96 \times 1]$
- = 44.11 A SELECTED CONDUCTOR - #6 THWN-2 OR #4 USE-2 AL ...NEC 310.15(B)(16)

(B) AFTER IQ COMBINER PANEL
TEMPERATURE DERATE FACTOR - 0.96
GROUPING FACTOR - 1

# **CONDUCTOR AMPACITY**

- $= (TOTAL INV O/P CURRENT) \times 1.25 / 0.96 / 1 ... NEC 690.8(B)$
- $= [(28 \times 1.21) \times 1.25] / [0.96 \times 1]$
- = 44.11 A SELECTED CONDUCTOR - #6 THWN-2 ...NEC 310.15(B)(16)
  - 2. PV OVER CURRENT PROTECTION ...NEC 690.9(B)
- **= TOTAL INVERTER O/P CURRENT x 1.25**
- $= (28 \times 1.21) \times 1.25 = 42.35 \text{ A}$

∕B\-

SELECTED OCPD = 50A ...NEC 240.6

3. <u>120% RULE FOR BACKFEED BREAKER</u> ...NEC 705.12(B)(2)(3)(b)

MCB + PV BREAKER <= (1.2 x BUS BAR RATING RATING)

(150 + 50) <= 1.2 x 225A

200.00 <= 270.00 HENCE OK

4. VOLTAGE DROP CALCULATION
VOLTAGE DROP= (0.2 x LENGTH OF CONDUCTOR x
CURRENT x RESISTANCE IN CONDUCTOR) / 240
= (0.2 x 60 x 33.88 x 0.49 ( FOR #6 AWG WIRE) ) / 240
= 0.83%

VOLTAGE DROP IS WITHIN PERMISSIBLE LIMIT OF 2%.HENCE OK

#### CONTRACTOR



22171 MCH RD MANDEVILLE, LA 70471

PROJECT NAME & ADDRESS

PHONE: 9152011490


PHILLIP NOEGEL

# 345 SW SEMINOLE TER, LAKE CITY, FL 32024

COUNTY:-COLUMBIA COUNTY

#### SYSTEM SIZE

DC SIZE: 11.060 KW DC-(STC) AC SIZE: 8.120 KW AC



This item has been digitally signed and sealed by Nestor J. Houghton, P.E. on April 3, 2023
Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

PRINCIPAL ENGINEERING, INC. 1011 N. CAUSEWAY BLVD. STE 19 MANDEVILLE, LA 70471 985.624.5001 INFO@PI-AEC.COM FLORIDA FIRM NO. 30649

# SHEET TITLE ELECTRICAL CALCULATIONS

DRAWN DATE	3/31/2023
DRAWN BY	TSP


SHEET NUMBER

E-602

# WARNING: PHOTOVOLTAIC **POWER SOURCE**

# SOLAR PV SYSTEM EQUIPPED WITH RAPID SHUTDOWN

TURN RAPID SHUTDOWN SWITCH TO THE 'OFF' POSITION TO SHUT DOWN PV SYSTEM AND REDUCE SHOCK HAZARD IN THE ARRAY



# **AC DISCONNECT**



DO NOT TOUCH TERMINALS. TERMINALS ON BOTH LINE AND LOAD SIDES MAY BE ENERGIZED IN THE **OPEN POSITION** 

PHOTOVOLTAIC SYSTEM **AC DISCONNECT** 

**OPERATING VOLTAGE: 240 VOLTS OPERATING CURRENT: 33.88 AMPS** 





**PHOTOVOLTAIC MICROINVERTERS LOCATED UNDER EACH PV MODULE IN ROOFTOP ARRAY** 

PHOTOVOLTAIC SYSTEM **EQUIPPED WITH** RAPID SHUTDOWN

RATED AC OUTPUT CURRENT: NOM. OPERATING VOLTAGE:



SOURCES: UTILITY GRID AND PV **SOLAR ELECTRIC SYSTEM** 

KW SOLAR **DISCONNECT LOCATED** 




**AC COMBINER BOX** 

**⚠ WARNING ⚠** INVERTER OUTPUT CONNECTION DO NOT RELOCATE THIS **OVERCURRENT DEVICE** 

# **EMERGENCY RESPONDER** THIS SOLAR PV SYSTEM EQUIPPED WITH RAPID SHUTDOWN


TURN RAPID SHUTDOWN SWITCH TO THE 'OFF' POSITION TO SHUTDOWN ENTIRE PV SYSTEM.



THE LABEL SHALL BE REFLECTIVE, WITH ALL LETTERS CAPITALIZED AND HAVING A MINIMUM HEIGHT OF 3/8 IN. (9.5 MM), IN WHITE ON A RED BACKGROUND.

# CAUTION

POWER TO THIS BUILDING IS ALSO SUPPLIED FROM THE FOLLOWING SOURCES WITH **DISCONNECTS LOCATED AS SHOWN:** 



#### CONTRACTOR



22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

PROJECT NAME & ADDRESS

PHILLIP NOEGEL

# 345 SW SEMINOLE TER. LAKE CITY. FL 32024

**COUNTY:-COLUMBIA COUNTY** 

#### SYSTEM SIZE

DC SIZE: 11.060 KW DC-(STC) AC SIZE: 8.120 KW AC



This item has been digitally signed and sealed by Nestor J. Houghton, P.E. on April 3, 2023 Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

PRINCIPAL ENGINEERING, INC. 1011 N. CAUSEWAY BLVD. STE 19 MANDEVILLE, LA 70471 985.624.5001 INFO@PI-AEC.COM FLORIDA FIRM NO. 30649

SHEET TITLE

# **PLACARD**

DRAWN DATE	3/31/2023
DRAWN BY	TSP

SHEET NUMBER

E-603



**SOLAR BREAKER** 







# **HiKuBlack Mono PERC BLACK FRAME ON BLACK BACKSHEET** F23 Frame 380 W ~ 405 W CS3N-380 | 385 | 390 | 395 | 400 | 405MS

#### MORE POWER



Module power up to 405 W Module efficiency up to 19.9 %



Lower LCOE & BOS cost



Comprehensive LID / LeTID mitigation technology, up to 50% lower degradation



Better shading tolerance

#### MORE RELIABLE



Minimizes micro-crack impacts



Heavy snow load up to 8100 Pa, enhanced wind load up to 6000 Pa\*



**Industry Leading Product Warranty on Materials** 



Linear Power Performance Warranty\*

#### 1st year power degradation no more than 2%

#### Subsequent annual power degradation no more than 0.55%

\*Subject to the terms and conditions contained in the applicable Canadian Solar Limited Warranty Statement. Also this 25-year limited product warranty is available only for products installed and operating on residential rooftops in certain regions.

#### MANAGEMENT SYSTEM CERTIFICATES\*

ISO 9001: 2015 / Quality management system ISO 14001: 2015 / Standards for environmental management system

ISO 45001: 2018 / International standards for occupational health & safety

#### **PRODUCT CERTIFICATES\***

IEC 61215 / IEC 61730 / CE FSEC (US Florida) / UL 61730 / IEC 61701 / IEC 62716






\* The specific certificates applicable to different module types and markets will vary, and therefore not all of the certifications listed herein will simultaneously apply to the products you order or use. Please contact your local Canadian Solar sales representative to confirm the specific certificates available for your Product and applicable in the regions

CSI SOLAR (USA) CO., LTD. is committed to providing high quality solar photovoltaic modules, solar energy and battery storage solutions to customers. The company was recognized as the No. 1 module supplier for quality and performance/price ratio in the IHS Module Customer Insight Survey. Over the past 20 years, it has successfully delivered over 63 GW of premium-quality solar modules across the world.

1350 Treat Blvd. Suite 500, Walnut Creek, CA 94598, USA | www.csisolar.com/na | service.ca@csisolar.com

#### **ENGINEERING DRAWING (mm)**



#### **ELECTRICAL DATA | STC\***

THE RESERVE OF THE PARTY OF THE						
CS3N	380MS	385MS	390MS	395MS	400MS	405MS
Nominal Max. Power (Pmax)	380 W	385 W	390 W	395 W	400 W	405 W
Opt. Operating Voltage (Vmp)	36.4 V	36.6 V	36.8 V	37.0 V	37.2 V	37.4 V
Opt. Operating Current (Imp)	10.44 A	10.52 A	10.60 A	10.68 A	10.76 A	10.83 A
Open Circuit Voltage (Voc)	43.7 V	43.9 V	44.1 V	44.3 V	44.5 V	44.7 V
Short Circuit Current (Isc)	11.26 A	11.32 A	11.38 A	11.44 A	11.50 A	11.56 A
Module Efficiency	18.7%	18.9%	19.2%	19.4%	19.7%	19.9%
Operating Temperature	-40°C ~	+85°C				
Max. System Voltage	1000V (	UL)				
Module Fire Performance	TYPE 2	(UL 617	30 1000	V)		
Max. Series Fuse Rating	20 A					
Application Classification	Class A					
Power Tolerance	0~+10	W				
* Under Standard Test Conditions (STC)	of irradiar	ce of 100	0 W/m <sup>2</sup> , sp	ectrum A	M 1.5 and	cell temperature

#### **ELECTRICAL DATA | NMOT\***

					I	
CS3N	380MS	385MS	390MS	395MS	400MS	405MS
Nominal Max. Power (Pmax)	284 W	288 W	291 W	295 W	299 W	303 W
Opt. Operating Voltage (Vmp)	34.0 V	34.2 V	34.4 V	34.6 V	34.7 V	34.9 V
Opt. Operating Current (Imp)	8.35 A	8.42 A	8.48 A	8.54 A	8.60 A	8.66 A
Open Circuit Voltage (Voc)	41.2 V	41.4 V	41.6 V	41.8 V	41.9 V	42.1 V
Short Circuit Current (Isc)	9.08 A	9.13 A	9.18 A	9.23 A	9.28 A	9.33 A
			44	£000 1111	4	

<sup>\*</sup> Under Nominal Module Operating Temperature (NMOT), irradiance of 800 W/m² spectrum AM 1.5, ambient temperature 20°C, wind speed 1 m/s.

\* The specifications and key features contained in this datasheet may deviate slightly from our actual

products due to the on-going innovation and product enhancement. CSI Solar Co., Ltd. reserves the right to make necessary adjustment to the information described herein at any time without further notice.


Please be kindly advised that PV modules should be handled and installed by qualified people who have

professional skills and please carefully read the safety and installation instructions before using our PV

# CSI SOLAR (USA) CO., LTD.

#### Jan. 2022 | All rights reserved | PV Module Product Datasheet v2.9C25\_F23\_J3\_NA

#### CS3N-400MS / I-V CURVES



#### MECHANICAL DATA

Specification	Data
Cell Type	Mono-crystalline
Cell Arrangement	132 [2 X (11 X 6) ]
Dimensions	1940 X 1048 X 35 mm
Dimensions	(76.4 X 41.3 X 1.38 in)
Weight	23.4 kg (51.6 lbs)
Front Cover	3.2 mm tempered glass
Frame	Anodized aluminium alloy
J-Box	IP68, 3 bypass diodes
Cable	12 AWG (UL)
Cable Length (Including Connector)	Portrait: 400 mm (15.7 in) (+) / 280 mm (11.0 in) (-) (supply additional cable jumper: 2 lines/pallet); land- scape: 1250 mm (49.2 in)*
Connector	T4 or MC4 series
Per Pallet	30 pieces
Per Container (40' HQ)	720 pieces
* For detailed information, ple	ease contact your local Canadian Solar sales an

#### TEMPERATURE CHARACTERISTICS

	Specification	Data
-	Temperature Coefficient (Pmax)	-0.34 % / °C
	Temperature Coefficient (Voc)	-0.26 % / °C
-	Temperature Coefficient (Isc)	0.05 % / °C
	Nominal Module Operating Temperature	42 ± 3°C

#### PARTNER SECTION

technical representatives

## SHEET TITLE **RESOURCE DOCUMENT**

CONTRACTOR

22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

PROJECT NAME & ADDRESS

PHILLIP NOEGEL

345 SW SEMINOLE TER. LAKE CITY, FL 32024

**COUNTY:-COLUMBIA COUNTY** 

SYSTEM SIZE

DC SIZE: 11.060 KW DC-(STC)

AC SIZE: 8.120 KW AC

Solar

DRAWN DATE	3/31/2023
DRAWN BY	TSP

SHEET NUMBER

<sup>\*</sup> For detailed information, please refer to Installation Manual.







# IQ8 and IQ8+ Microinverters

Our newest IQ8 Microinverters are the industry's first microgrid-forming, software-defined microinverters with split-phase power conversion capability to convert DC power to AC power efficiently. The brain of the semiconductor-based microinverter is our proprietary application-specific integrated circuit (ASIC) which enables the microinverter to operate in grid-tied or off-grid modes. This chip is built in advanced 55nm technology with high speed digital logic and has super-fast response times to changing loads and grid events, alleviating constraints on battery sizing for home energy systems.



Part of the Enphase Energy System, IQ8 Series Microinverters integrate with the Enphase IQ Battery, Enphase IQ Gateway, and the Enphase App monitoring and analysis software.



Connect PV modules quickly and easily to IQ8 Series Microinverters using the included Q-DCC-2 adapter cable with plug-n-play MC4 connectors.

IQ8 Series Microinverters are UL Listed as PV Rapid Shut Down Equipment and conform with various regulations, when installed according to manufacturer's instructions.

IQ8 Series Microinverters redefine reliability

enabling an industry-leading limited warranty

standards with more than one million

cumulative hours of power-on testing,

 $\ \odot$  2021 Enphase Energy. All rights reserved. Enphase, the Enphase logo, IQ8 microinverters, and other names are trademarks of Enphase Energy, Inc. Data subject to change.

IQ8SP-DS-0002-01-EN-US-2021-10-19

#### Easy to install

- Lightweight and compact with plug-n-play connectors
- Power Line Communication (PLC) between components
- Faster installation with simple two-wire cabling

#### High productivity and reliability

- Produce power even when the grid is down
- More than one million cumulative hours of testing
- Class II double-insulated enclosure
- Optimized for the latest highpowered PV modules

#### Microgrid-forming

- Complies with the latest advanced grid support
- Remote automatic updates for the latest grid requirements
- Configurable to support a wide range of grid profiles
- Meets CA Rule 21 (UL 1741-SA) requirements

# IQ8 and IQ8+ Microinverters

(1) No enforced DC/AC ratio. See the compatibility calculator at https://link.enphase.com/

module-compatibility (2) Maximum continuous input DC current is 10.6A (3) Nominal voltage range can be extended beyond nominal if required by the utility. (4) Limits may vary. Refer to

local requirements to define the number of microinverters per branch in your area.

INPUT DATA (DC)		108-60-2-US	IQ8PLUS-72-2-US
Commonly used module pairings <sup>1</sup>	W	235 - 350	235 – 440
Module compatibility		60-cell/120 half-cell	60-cell/120 half-cell and 72-cell/144 half-cell
MPPT voltage range	٧	27 - 37	29 - 45
Operating range	٧	25 - 48	25 - 58
Min/max start voltage	٧	30 / 48	30 / 58
Max input DC voltage	٧	50	60
Max DC current <sup>2</sup> [module lsc]	A		15
Overvoltage class DC port			1
DC port backfeed current	mA		0
PV array configuration		1x1 Ungrounded array; No additional DC side pro	tection required; AC side protection requires max 20A per branch circu
OUTPUT DATA (AC)		108-60-2-US	IQ8PLUS-72-2-US
Peak output power	VA	245	300
Max continuous output power	VA	240	290
Nominal (L-L) voltage/range <sup>3</sup>	٧		240 / 211 - 264
Max continuous output current	A	1.0	1.21
Nominal frequency	Hz		60
Extended frequency range	Hz		50 - 68
Max units per 20 A (L-L) branch circuit	4	16	13
Total harmonic distortion			<5%
Overvoltage class AC port			III
AC port backfeed current	mA		30
Power factor setting			10
Grid-tied power factor (adjustable)		d	85 leading - 0.85 lagging
Peak efficiency	%	97.5	97.6
CEC weighted efficiency	%	97	97
Night-time power consumption	mW		60
MECHANICAL DATA			
Ambient temperature range		-40%	C to +60°C (-40°F to +140°F)
Relative humidity range		.4	% to 100% (condensing)
DC Connector type			MC4
Dimensions (HxWxD)		. 212 mm (8.	3") x 175 mm (6.9") x 30.2 mm (1.2")
Weight			1.08 kg (2.38 lbs)
Cooling		Na	tural convection - no fans
Approved for wet locations			Yes
Acoustic noise at 1m			<60 dBA
Pollution degree			PD3
Enclosure		Class II double-insula	ited, corrosion resistant polymeric enclosure
Environ. category / UV exposure rating			NEMA Type 6 / outdoor
COMPLIANCE			
	(	CA Rule 21 (UL 1741-SA), UL 62109-1, UL1741/IEEE154	7, FCC Part 15 Class B, ICES-0003 Class B, CAN/CSA-C22.2 NO. 107.1-
Certifications			uipment and conforms with NEC 2014, NEC 2017, and NEC 2020 section of PV Systems, for AC and DC conductors, when installed according to

IQ8SP-DS-0002-01-EN-US-2021-10-19

#### CONTRACTOR



22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

PROJECT NAME & ADDRESS

PHILLIP NOEGEL

# 345 SW SEMINOLE TER, LAKE CITY, FL 32024

COUNTY:-COLUMBIA COUNTY

#### SYSTEM SIZE

DC SIZE: 11.060 KW DC-(STC) AC SIZE: 8.120 KW AC

# SHEET TITLE RESOURCE DOCUMENT

DRAWN DATE	3/31/2023
DRAWN BY	TSP

SHEET NUMBER

Data Sheet Enphase Networking

# Enphase IQ Combiner 4/4C

X-IQ-AM1-240-4 X-IQ-AM1-240-4C



The Enphase IQ Combiner 4/4C with Enphase IQ Gateway and integrated LTE-M1 cell modem (included only with IQ Combiner 4C) consolidates interconnection equipment into a single enclosure and streamlines IQ microinverters and storage installations by providing a consistent, pre-wired solution for residential applications. It offers up to four 2-pole input circuits and Eaton BR series busbar assembly.

#### Smart

- · Includes IQ Gateway for communication and control
- Includes Enphase Mobile Connect cellular modem (CELLMODEM-M1-06-SP-05), included only with IQ Combiner 4C
- Includes solar shield to match Enphase IQ Battery aesthetics and deflect heat
- Flexible networking supports Wi-Fi, Ethernet, or cellular
- · Optional AC receptacle available for PLC bridge
- Provides production metering and consumption monitoring

#### Simple

- Centered mounting brackets support single stud mounting
- · Supports bottom, back and side conduit entry
- Up to four 2-pole branch circuits for 240 VAC plug-in breakers (not included)
- · 80A total PV or storage branch circuits

#### Reliable

- Durable NRTL-certified NEMA type 3R enclosure
- · Five-year limited warranty
- Two years labor reimbursement program coverage included for both the IQ Combiner SKU's
- · UL listed



#### Enphase IQ Combiner 4/4C

MODEL NUMBER	
IQ Combiner 4 (X-IQ-AM1-240-4)	IQ Combiner 4 with Enphase IQ Gateway printed circuit board for integrated revenue grade PV production metering (ANS C12.20+/- 0.5%) and consumption monitoring (+/- 2.5%). Includes a silver solar shield to match the IQ Battery system an IQ System Controller 2 and to deflect heat.
IQ Combiner 4C (X-IQ-AM1-240-4C)	IQ Combiner 4C with Enphase IQ Gateway printed circuit board for integrated revenue grade PV production metering (ANSI C12.20 +/- 0.5%) and consumption monitoring (+/- 2.5%). Includes Enphase Mobile Connect cellular modem (CELLMODEM-MI-06-SP-05), a plug-andi-play industrial-grade cell modem for systems up to 60 microinverters. (Available in the US, Canada, Mexico, Puerto Rico, and the US Virgin Islands, where there is adequate cellular service in the installation area.) Includes a silver solar shield to match the IQ Battery and IQ System Controller and to deflect heat
ACCESSORIES AND REPLACEMENT PARTS	(not included, order separately)
Ensemble Communications Kit COMMS-CELLMODEM-M1-06 CELLMODEM-M1-06-SP-05 CELLMODEM-M1-06-AT-05	<ul> <li>Includes COMMS-KIT-01 and CELLMODEM-M1-06-SP-05 with 5-year Sprint data plan for Ensemble sites</li> <li>4G based LTE-M1 cellular modem with 5-year Sprint data plan</li> <li>4G based LTE-M1 cellular modem with 5-year AT&amp;T data plan</li> </ul>
Circuit Breakers BRK-10A-2-240V BRK-15A-2-240V BRK-20A-2-240V BRK-15A-2P-240V-B BRK-20A-2P-240V-B	Supports Eaton BR210, BR215, BR220, BR230, BR240, BR250, and BR260 circuit breakers. Circuit breaker, 2 pole, 10A, Eaton BR2 10 Circuit breaker, 2 pole, 15A, Eaton BR215 Circuit breaker, 2 pole, 20A, Eaton BR220 Circuit breaker, 2 pole, 15A, Eaton BR215B with hold down kit support Circuit breaker, 2 pole, 20A, Eaton BR220B with hold down kit support
EPLC-01	Power line carrier (communication bridge pair), quantity - one pair
XA-SOLARSHIELD-ES	Replacement solar shield for IQ Combiner 4/4C
XA-PLUG-120-3	Accessory receptacle for Power Line Carrier in IQ Combiner 4/4C (required for EPLC-01)
XA-ENV-PCBA-3	Replacement IQ Gateway printed circuit board (PCB) for Combiner 4/4C
X-IQ-NA-HD-125A	Hold down kit for Eaton circuit breaker with screws.
ELECTRICAL SPECIFICATIONS	
Rating	Continuous duty
System voltage	120/240 VAC, 60 Hz
Eaton BR series busbar rating	125 A
Max. continuous current rating	65 A
Max. continuous current rating (input from PV/storage)	64 A
Max. fuse/circuit rating (output)	90 A
Branch circuits (solar and/or storage)	Up to four 2-polle Eaton BR series Distributed Generation (DG) breakers only (not included)
Max. total branch circuit breaker rating (input) Production metering CT	80A of distributed generation / 95A with IQ Gateway breaker included 200 A solid core pre-installed and wired to IQ Gateway
Consumption monitoring CT (CT-200-SPLIT)	A pair of 200 A split core current transformers
MECHANICAL DATA	
Dimensions (WxHxD)	37.5 x 49.5 x 16.8 cm (14.75" x 19.5" x 6.63"). Height is 21.06" (53.5 cm) with mounting brackets.
Weight	7.5 kg (16.5 lbs)
Ambient temperature range	-40° C to +46° C (-40° to 115° F)
Cooling	Natural convection, plus heat shield
Enclosure environmental rating	Outdoor, NRTL-certified, NEMA type 3R, polycarbonate construction
Wire sizes	20 A to 50 A breaker inputs: 14 to 4 AWG copper conductors 60 A breaker branch input: 4 to 1/0 AWG copper conductors Main lug combined output: 10 to 2/0 AWG copper conductors Neutral and ground: 14 to 1/0 copper conductors Always follow local code requirements for conductor sizing.
Altitude	To 2000 meters (6,560 feet)
INTERNET CONNECTION OPTIONS	
Integrated Wi-Fi	802.11b/g/n
	CELLMODEM-M1-06-SP-05, CELLMODE M-M1-06-AT-05 (4G based LTE-M1 cellular modem). Note that an Enphase Mobile Connect cellular modem is required for all Ensemble installations.
Cellular	mount commerce contains incoming required for an enderhold Histaliations.
Cellular Ethernet	Optional, 802.3, Cat5E (or Cat 6) UTP Ethernet cable (not included)
Ethernet	

#### To learn more about Enphase offerings, visit enphase.com

© 2021 Enphase Energy, All rights reserved. Enphase, the Enphase logo, IQ Combiner 4/4C, and other names are trademarks of Enphase Energy, Inc. Data subject to change. 10-21-2021



#### CONTRACTOR



22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

PROJECT NAME & ADDRESS

PHILLIP NOEGEL

# 345 SW SEMINOLE TER, LAKE CITY, FL 32024

COUNTY:-COLUMBIA COUNTY


#### SYSTEM SIZE


DC SIZE: 11.060 KW DC-(STC) AC SIZE: 8.120 KW AC

SHEET TITLE
RESOURCE
DOCUMENT

DRAWN DATE 3/31/2023
DRAWN BY TSP

SHEET NUMBER





ALUM FRONT CAP

**APRIL 2016** 

PRODUCT PROTECTED BY ONE

OR MORE US PATENTS

LEGAL NOTICE

SHEET

DRAWING TYPE:

DESCRIPTION:

REVISION DATE:

1411 BROADWAY BLVD NE ALBUQUERQUE, NM 87302 USA

WWW.UNIRAC.COM

CONTRACTOR



22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

PROJECT NAME & ADDRESS

PHILLIP NOEGEL

345 SW SEMINOLE TER, LAKE CITY, FL 32024

COUNTY:-COLUMBIA COUNTY


SYSTEM SIZE


DC SIZE: 11.060 KW DC-(STC) AC SIZE: 8.120 KW AC

SHEET TITLE
RESOURCE
DOCUMENT

DRAWN DATE 3/31/2023
DRAWN BY TSP

SHEET NUMBER





# **#UNIRAC**

WWW.UNIRAC.COM

1411 BROADWAY BLVD NE ALBUQUERQUE, NM 87302 USA PRODUCT LINE: ULA

DRAWING TYPE: PART

DESCRIPTION: ALUMINUM REAR CAP

REVISION DATE: APRIL 2016

DRAWING NOT TO SCALE ALL DIMENSIONS ARE NOMINAL

PRODUCT PROTECTED BY ONE OR MORE US PATENTS

LEGAL NOTICE

SHEET

ULA-A05

SHEET TITLE RESOURCE DOCUMENT

CONTRACTOR

22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

PROJECT NAME & ADDRESS

PHILLIP NOEGEL

345 SW SEMINOLE TER.

LAKE CITY,
FL 32024
COUNTY:-COLUMBIA COUNTY

SYSTEM SIZE


DC SIZE: 11.060 KW DC-(STC) AC SIZE: 8.120 KW AC


Solar

ACIT

DRAWN DATE 3/31/2023
DRAWN BY TSP

SHEET NUMBER





# CONTRACTOR



22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

PROJECT NAME & ADDRESS

PHILLIP NOEGEL

# 345 SW SEMINOLE TER, LAKE CITY, FL 32024

**COUNTY:-COLUMBIA COUNTY** 

#### SYSTEM SIZE

DC SIZE: 11.060 KW DC-(STC) AC SIZE: 8.120 KW AC

# :!\*UNIRAC

1411 BROADWAY BLVD NE ALBOQUERQUE, NM 87302 USA

WWW.UNIRAC.COM

PRODUCT LINE: ULA

DRAWING TYPE: ASSEMBLY

DESCRIPTION: PORTRAIT ORIENTATION

REVISION DATE: APRIL 2016

DRAWING NOT TO SCALE ALL DIMENSIONS ARE NOMINAL

PRODUCT PROTECTED BY ONE OR MORE US PATENTS


LEGAL NOTICE


SHEET

SHEET TITLE
RESOURCE
DOCUMENT

DRAWN DATE 3/31/2023
DRAWN BY TSP

SHEET NUMBER





DRAWING TYPE: PART DETAIL

HD RAIL

9/11/2017

DESCRIPTION:

REVISION DATE:

1411 BROADWAY BLVD. NE

PHONE: 505.242.6411

WWW.UNIRAC.COM

ALBUQUERQUE, NM 87102 USA

NOMINAL

PRODUCT PROTECTED BY

ONE OR MORE US PATENTS

LEGAL NOTICE

SHEET

CONTRACTOR



22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

PROJECT NAME & ADDRESS

PHILLIP NOEGEL

# 345 SW SEMINOLE TER, LAKE CITY, FL 32024

COUNTY:-COLUMBIA COUNTY


## SYSTEM SIZE


DC SIZE: 11.060 KW DC-(STC) AC SIZE: 8.120 KW AC

# SHEET TITLE RESOURCE DOCUMENT

DRAWN DATE	3/31/2023
DRAWN BY	TSP

SHEET NUMBER





CONTRACTOR

AUT Solar

22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

PROJECT NAME & ADDRESS

PHILLIP NOEGEL

345 SW SEMINOLE TER, LAKE CITY, FL 32024

COUNTY:-COLUMBIA COUNTY

SYSTEM SIZE

DC SIZE: 11.060 KW DC-(STC) AC SIZE: 8.120 KW AC

SHEET TITLE
RESOURCE
DOCUMENT

DRAWN DATE 3/31/2023
DRAWN BY TSP

SHEET NUMBER



#### **U-BUILDER PROJECT REPORT**

APPLICATION VERSION: 6.0.0 PROJECT VERSION: 0.0.23

PROJECT TITLE	PROJECT ID	CREATED
ULA	BE7F5876	Nov. 30, 2022, 10:29 a.m.

NAME	Phillip Noegel
ADDRESS	345 SW Seminole Ter, Lake City, FL 32024, USA
CITY, STATE	Lake City, FL
MODULE	Canadian Solar CS3N-395MS

Designed by achavarria@theprocompanies.com

ULA

Canadian Solar

28 - CS3N-395MS

613.53 ft<sup>2</sup>

11.06 KW

NOTE: Installation of the project is intended to happen within the year of project designed in UBuilder. If it's past one year please rerun the design or contact Unirac Engineering Services.

# **BILL OF MATERIALS**

LEGEND: ■ Base System Part ■ Accessory

PART NUMBER	PART TYPE	DESCRIPTION	QUANTITY	SUGGESTED QUANTITY	UNIT PRICE (USD)	TOTAL LIST PRICE (USD)
411246M	Rail	GFT RAIL 246" MILL	14	14	100.42	1405.88
302027C	Mid Clamp	SM BND MIDCLAMP BC SS	42	42	2.97	124.74
302022C	End Clamp	SM ENDCLAMP C, W/HDW, CLR	28	28	2.53	70.84
403216M	Structure	ULA RAIL BRACKET, 2"	28	28	11.54	323.12
403200C	Structure	ULA BRACE, 2"@ 7 FT	7	7	39.37	275.59
403215C	Structure	ULA SLIDER, 2", AL	7	7	11.86	83.02
403211C	Structure	ULA FRONT CAP, 2", AL	7	7	24.90	174.30
403214C	Structure	ULA REAR CAP, 2", AL	7	7	24.90	174.30
User Supplied	Structure	2" SCHEDULE 40 PIPE (quantity given in ft)	258	258	0.00	0.00
008002S	Grounding Lug (Weeb)	GROUND WEEBLUG #1	7	7	9.08	63.56

008013S Microinverter MICRO MNT BND TBOLT 1/4X3/4 28 28 1.08 30.24 Mounting SS

### ACCESSORIES PRICE \$93.80 TOTAL PRICE \$2725.59

### \$0.238 PER WATT \$0.008 PER WATT \$0.246 PER WATT

This design is to be evaluated to the product appropriate Unirac Code Compliant Installation Manual which references International Building Code 2009, 2012, 2015, 2018 and ASCE 7-05, ASCE 7-10, ASCE 7-16 and California Building Code 2010, 2016. The installation of products related to this design is subject to requirements in the above mentioned installation manual.

#### CONTRACTOR



22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

PROJECT NAME & ADDRESS

PHILLIP NOEGEL

# 345 SW SEMINOLE TER, LAKE CITY, FL 32024

COUNTY:-COLUMBIA COUNTY

#### SYSTEM SIZE

DC SIZE: 11.060 KW DC-(STC) AC SIZE: 8.120 KW AC

SHEET TITLE
RESOURCE
DOCUMENT

DRAWN DATE 3/31/2023
DRAWN BY TSP

SHEET NUMBER

# **DETAILED PARTS DESCRIPTION**

QTY



#### Rail 411246M GFT RAIL 246" MILL

246" long mill finish aluminum east-west rail for module mounting. Interfaces with top mounting Solarmount Pro Series or Standard module clamps. Works with both 4 rail or shared rail configurations.



#### Mid Clamp 302027C SM BND MIDCLAMP BC SS

Located between adjacent PV modules, mounts 30-36 mm (1.18-1.42 in) thick modules to rail by clamping module frame from above. Includes T bolt and nut. If mounting on short side of module frame, confirm this is acceptable with PV



#### End Clamp 302022C SM ENDCLAMP C, W/HDW, CLR

Mounts 33-36 mm (1.30-1.42 in) thick PV modules to rail by clamping module frame from above. Includes T bolt and nut. If mounting on short side of module frame, confirm this is acceptable with PV module manufacturer.



#### Structure 403216M ULA RAIL BRACKET, 2"

Rail bracket connects SOLARMOUNT and SOLARMOUNT HD rail to 2" horizontal pipe structure.



#### Structure 403200C ULA BRACE, 2"@ 7 FT

 $7'\ Square\ aluminum\ tube\ for\ ULA\ seismic\ bracing.\ Used\ to\ create\ diagonal\ bracing\ between\ upright\ foundations.\ Cut\ to\ length\ and\ drill\ for\ installation.$ 



#### Structure 403215C ULA SLIDER, 2", AL

Slider connects the lower end of diagonal seismic bracing. Mounts on 2" vertical pipe.



#### Structure 403211C ULA FRONT CAP, 2", AL

Aluminum front cap. Connects short (front of array) upright post with 2" horizontal pipe structure.



#### Structure 403214C ULA REAR CAP, 2", AL

Aluminum rear cap. Connects tall (rear of array) upright post with 2 "horizontal pipe structure.



#### Structure UserSupplied 2" SCHEDULE 40 PIPE (quantity given in ft)

 $2^{\prime\prime}$  SCHEDULE 40 GALVANIZED PIPE SERVES AS THE STRUCTURE TO MOUNT RACKING. SOURCE THIS PIPE LOCALLY.

#### Grounding Lug (Weeb) 008002S GROUND WEEBLUG #1

For electrical bonding of PV modules and rails. Accepts one 14AWG to 6AWG or two 12 AWG to 10 AWG copper wires. Tin plated copper body, 1/4" stainless steel fasteners.



#### Microinverter Mounting 008013S MICRO MNT BND TBOLT 1/4X3/4 SS

Microinverter Mounting T -Bolt

CONTRACTOR



22171 MCH RD MANDEVILLE, LA 70471

258

PHONE: 9152011490

PROJECT NAME & ADDRESS

PHILLIP NOEGEL

# 345 SW SEMINOLE TER, LAKE CITY, FL 32024

COUNTY:-COLUMBIA COUNTY

#### SYSTEM SIZE

DC SIZE: 11.060 KW DC-(STC) AC SIZE: 8.120 KW AC

SHEET TITLE
RESOURCE
DOCUMENT

DRAWN DATE 3/31/2023
DRAWN BY TSP

SHEET NUMBER

#### **ENGINEERING REPORT**

#### Plan review

28
1
11.06 KW

#### **Loads Used for Design**

BUILDING CODE	ASCE 7-16
BASIC WIND SPEED	117.00 mph
GROUND SNOW LOAD	0.00 ps
RISK CATEGORY	)
SEISMIC (SS)	0.099
SEISMIC (S1)	0.000
ELEVATION	162.00 ft
WIND EXPOSURE	C
VELOCITY PRESSURE, QZ	25.09 ps

#### Inspection


PRODUCT	ULA
MODULE MANUFACTURER	Canadian Solar
MODEL	28 - CS3N-395MS
MODULE WATTS	395 watts
MODULE LENGTH	76.40"
MODULE WIDTH	41.30"
MODULE THICKNESS	1,38"
MODULE WEIGHT	49.60 lbs
TILT	30 degrees
CLAMP TYPE	Standard
FOUNDATION TYPE	CONCRETE
FRONT EDGE HEIGHT	2.00 ft
RAIL TYPE	GFT
NS DIAGNOL BRACE	YES


# Site Area 1 / Table Size 1 (count:1)


NUMBER OF MODULES:	28
TOTAL KW:	11.06 KW
TABLE SIZE:	4 X 7
RAIL USED:	GFT
ORIENTATION:	LANDSCAPE
SUGGESTED ROW SPACING	112.95"

(Not required for design. Calculated based on latitude, tilt, and no module shading between 10am and 2pm on Dec. 21st. Customer is responsible for final row spacing and energy production.)

## GEOMETRY







#### Member Description

į.	
N-S RAIL LENGTH: AD	168.95"
N-S RAIL SPAN: BC	93.86"
N-S RAIL OVERHANG: AB, CD	37.54"
FRONT EDGE HEIGHT	24.00 "
REAR EDGE HEIGHT	108.47 "
FRONT LEG LENGTH: BF	35.08"
REAR LEG LENGTH: CG	82.01"
N-S BRACE LENGTH: BG	83.45"
N-S BRACE ANGLE	23.04 degrees
N-S LEG SPACING: FG	81.29"
E-W ARRAY LENGTH	536.30"
E-W SPAN/LEG SPACING	78.87"
E-W OVERHANG: JF,FJ	31.55"
NUMBER OF POSTS	14

## CONTRACTOR



22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

PROJECT NAME & ADDRESS

PHILLIP NOEGEL

# 345 SW SEMINOLE TER, LAKE CITY, FL 32024

COUNTY:-COLUMBIA COUNTY

#### SYSTEM SIZE

DC SIZE: 11.060 KW DC-(STC)
AC SIZE: 8.120 KW AC

# SHEET TITLE RESOURCE DOCUMENT

DRAWN DATE	3/31/2023
DRAWN BY	TSP

SHEET NUMBER

#### LOAD VARIABLES

Dead Loads	psf
VERTICAL	2.20
HORIZONTAL	1.27

Wind Loads on table (Front Post)	psf
LC 0, A	-38.49
LC 0, B	-10.69
LC 180, A	44.90
LC 180, B	55.59

Wind Loads on table (Rear Post)	psf
LC 0, A	-38.49
LC 0, B	-53.46
LC 180, A	44.90
LC 180, B	21.38

Seismic Load	9/0
VERTICAL	2.1
HORIZONTAL	10.98

Snow Load	ps
VERTICAL	0.0
HORIZONTAL	0.0

#### NORTH-SOUTH(N-S) RAIL DESIGN


Maximum Loads	GFT
MAXIMUM VERTICAL LOAD	113.18 pli
MINIMUM VERTICAL LOAD	-95.11 plf
MAXIMUM AXIAL LOAD	4.56 plf
MINIMUM AXIAL LOAD	1.90 plf
MAXIMUM MOMENT VERTICAL	553.94 ft-lbs
MAXIMUM SHEAR	411.09 lbs
MAXIMUM AXIAL (NORTH-SOUTH)	499.72 lbs
MAXIMUM DEFLECTION	0.02"

#### FOUNDATION

Design Inputs	pcf
CONCRETE DENSITY	140.00
SOIL DENSITY	110.00

#### Concrete Design

FOOTING DIAMETER	24.00"
FOOTING DEPTH	7.09 ft



#### CONTRACTOR



22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

PROJECT NAME & ADDRESS

PHILLIP NOEGEL

# 345 SW SEMINOLE TER, LAKE CITY, FL 32024

COUNTY:-COLUMBIA COUNTY

## SYSTEM SIZE

DC SIZE: 11.060 KW DC-(STC)
AC SIZE: 8.120 KW AC

SHEET TITLE
RESOURCE
DOCUMENT

DRAWN DATE 3/31/2023
DRAWN BY TSP

SHEET NUMBER