



Britt Surveying and Mapping, LLC
1438 SW Main Blvd • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

09/20/2023

L-29832

Re: Lot 6 Emerald Cove Phase 1

Sylvester Warren

To Whom It May Concern:

The finished floor elevation of the slab located on this parcel was found to be 104.67 feet. The building permit shows the minimum floor elevation to be 103 feet. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,



L. Scott Britt
LS 5753

