CAROL CHADWICK, P.E.

Civil Engineer
1208 S.W. Fairfax Glen
Lake City, FL 32025
307.680.1772
ccpewyo@gmail.com
www.carolchadwickpe.com

March 11, 2021

Jerod Craig Family Home Center codycraig41114@gmail.com

re: ELEVATION LETTER - 2661 S.W. COUNTY ROAD 778, FORT WHITE, FL

As requested, I inspected the building site for the proposed construction at the above referenced site. At the time of the inspection, an existing mobile home was located on the location of the new home. The photo shows the site looking northeast.


Based on the LIDAR on the Columbia County website, the existing road centerline elevation is approximately 57.3 + /-. The existing ground at the building site is 48.5 + /-. The minimum finished floor elevation of the structure will be 51.10. The finished floor of the home will be below the required elevation of one foot above the adjacent road. The topography of the site drains to the east and north from the building site. A swale will be graded on the uphill side of the home to prevent runoff from impacting the structure.



I certify that the minimum finished floor elevation listed above will protect the structure against water damage from a base flood event, as defined in Article 8 of the Land Development Regulations.

Should you have any questions, please don't hesitate to contact me.

Respectfully,



Carol Chadwick, P.E.

