



Britt Surveying and Mapping, LLC
2086 SW Main Blvd Ste 112 • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

12/02/2018

L-25605

Re: Lot 41 Cannon Creek Place

Bradley Franks Construction, LLC

To Whom It May Concern:

The top of the stemwall on lot 41 is found to be at 98.50 feet. The minimum floor elevation for said Lot 41 is 96.50 feet per the plat of record. All elevations are shown per the plat datum.

Sincerely,

A handwritten signature in black ink, appearing to read "L. Scott Britt", is written over a faint, circular, textured background.

L. Scott Britt
LS 5757