



14405 Peggy Road
Alachua, FL 32615
(386) 462-2845

TO: MARK THOMPSON

RE: DRILLING A WELL AT 181 SE LADUE CT
LAKE CITY

WELL CRITERIA:

4" WELL 200'±

4" CASING 180' SCH 40 PVC

1 1/2 HP PUMP MYERS (152-20)

TANK CHANGER 244 (220EQ)

1 1/4" DROP PIPE SCH 80 PVC

PRESSURE SWITCH SQD 40/60 PSI

1 1/4" CHECK VALVE BRASS

PRESSURE RELIEF VALVE

YOURS

SM GRIFFIS

GEOLOGIST

MGWC # 199346

MWQS # 90026