

PERMIT APPLICATION / MANUFACTURED HOME INSTALLATION APPLICATION

For Office Use Only (Revised 9-22-06) Zoning Official OKS 9/21/07 Building Official OK JTH 9-20-07

AP# 0709-54 Date Received 9/19 By JW Permit # 26273

Flood Zone X Development Permit Zoning A-3 Land Use Plan Map Category A-3

Comments

FEMA Map# Elevation Finished Floor River In Floodway

☒ Site Plan with Setbacks Shown ☒ EH Signed Site Plan ☒ EH Release ☒ Well letter ☒ Existing well

☒ Copy of Recorded Deed or Affidavit from land owner ☒ Letter of Authorization from installer

☒ State Road Access ☐ Parent Parcel # ☐ STUP-MH

Property ID # 26-7S-16-04323-040 Subdivision FAIRVIEW ESTATES Lot 40

- New Mobile Home X Used Mobile Home Year 2007
- Applicant Dale Burd, Rocky Ford or Kelly Bishop Phone # 383-497-2311
- Address P. O. Box 39, Fort White, FL, 32038
- Name of Property Owner Karla Doolen Doolen Phone# 708-452-7138
- 911 Address 2451 SW CR 138, FORT WHITE, FL, 32038
- Circle the correct power company - FL Power & Light - Clay Electric
(Circle One) - Suwannee Valley Electric - Progress Energy
- Name of Owner of Mobile Home Karla Doolen Phone # SAME
Address 4039 N. OZANAM. AVE, NORRIDGE, FL, 60706
- Relationship to Property Owner SAME
- Current Number of Dwellings on Property 0
- Lot Size 215 X 294 Total Acreage 1.44
- Do you : Have Existing Drive or Private Drive or need Culvert Permit or Culvert Waiver (Circle one)
(Currently using) (Blue Road Sign) (Putting in a Culvert) (Not existing but do not need a Culvert)
- Is this Mobile Home Replacing an Existing Mobile Home NO (DUE)
- Driving Directions to the Property
47 South, Through Fort White, FL ON CR 138, AFTER 2nd
Long CURVE IT IS 2nd LOT ON LEFT
- Name of Licensed Dealer/Installer Doug McGowan Phone # 386-303-1963
- Installers Address 101 RUSTIC PINE, JASPER, FL, 32052
- License Number FH 0008623 Installation Decal # 291 024

Spoke to Kristene
9/24/07

Prepared by and return to:

Frederic D. Kaufman
Frederic D. Kaufman, P.A.
Post Office Box 1459
High Springs, FL 32655-1459

Grantees tax identification number: _____
Property folio number: R04323-039

Inst:2004016187 Date:07/13/2004 Time:11:15

Doc Stamp-Deed : 0.70

MLK DC, P. DeWitt Cason, Columbia County B:1020 P:2005

Warranty Deed

This Indenture, Made this 9th day of July, 2004 between **Ronald Ray Doolen, an unmarried man, grantor***, and **Karla K. Doolen, an unmarried woman, grantee***, whose post office address is 4039 N. Ozanam Avenue, Norridge, IL 60706.

*"grantor" and "grantee" are used for singular or plural, as context requires

WITNESSETH: That said grantor, for and in consideration of the sum of TEN AND NO/100 DOLLARS (\$10.00) and other valuable considerations to said grantor in hand paid by said grantee, the receipt whereof is hereby acknowledged, has granted, bargained and sold, to the said grantee, and grantee's heirs and assigns forever, the following described land, situate, lying and being in Columbia County, Florida, wit:

Lot #40 of Fairview Estates, a subdivision as per Plat Book 4, Page 85 of the Public Records of Columbia County, Florida.

SUBJECT TO RESTRICTIONS, RESERVATIONS AND LIMITATION OF RECORD, IF ANY, AND TAXES FOR THE YEAR 2004 AND SUBSEQUENT YEARS.

and said grantor does hereby fully warrant the title to said land, and will defend the same against the lawful claims of all persons whomsoever.

IN WITNESS WHEREOF, grantor has hereunto set grantor's hand and seal the day and year first above written.

Witnesses:

Frederic D. Kaufman
Print Name Frederic D. Kaufman

Jane K. Kaufman
Print Name Jane K. Kaufman

Ronald Ray Doolen
Ronald Ray Doolen
14643 NW 150 Lane
Alachua, FL 32615

STATE OF FLORIDA
COUNTY OF ALACHUA

The foregoing instrument was acknowledged before me this 9th day of July, 2004 by Ronald Ray Doolen, who is/are personally known to me or who has/have produced FL Drivers License as identification.

Frederic D. Kaufman
Notary Public
Print Name: Frederic D. Kaufman

(Seal)

My Commission Expires:



Frederic D. Kaufman
MY COMMISSION # DD101448 EXPIRES
June 4, 2006
BONDED SURETY FIDELITY INSURANCE INC.

Columbia County Property Appraiser

DB Last Updated: 8/2/2007

2007 Proposed Values

Tax Record

Property Card

Interactive GIS Map

New Super Homestead Taxable Value Calculator

Print


Parcel: 26-7S-16-04323-040

Search Result: 1 of 5 Next >>

Owner & Property Info

Owner's Name	DOOKEN KARLA K		
Site Address	LOT 40 FAIRVIEW EST		
Mailing Address	4039 N OZANAM AVENUE NORRIDGE, IL 60706		
Use Desc. (code)	VACANT (000000)		
Neighborhood	26716.01	Tax District	3
UD Codes	MKTA02	Market Area	02
Total Land Area	0.000 ACRES		
Description	LOT 40 FAIRVIEW EST S/D ORB 418-443 & 581-542 & 588-677 & 661-134, 805-255, 998-700, WD 999-2763, WD 1020-2005.		

GIS Aerial



Property & Assessment Values

Mkt Land Value	cnt: (2)	\$21,000.00
Ag Land Value	cnt: (0)	\$0.00
Building Value	cnt: (0)	\$0.00
XFOB Value	cnt: (0)	\$0.00
Total Appraised Value		\$21,000.00

Just Value	\$21,000.00
Class Value	\$0.00
Assessed Value	\$21,000.00
Exempt Value	\$0.00
Total Taxable Value	\$21,000.00

Sales History

Sale Date	Book/Page	Inst. Type	Sale VImp	Sale Qual	Sale RCode	Sale Price
7/19/2004	1020/2005	WD	V	U	01	\$100.00
11/10/2003	999/2763	WD	V	U	06	\$100.00
10/24/2003	998/700	WD	V	Q		\$15,500.00

Building Characteristics

Bldg Item	Bldg Desc	Year Blt	Ext. Walls	Heated S.F.	Actual S.F.	Bldg Value
NONE						

Extra Features & Out Buildings

Code	Desc	Year Blt	Value	Units	Dims	Condition (% Good)
NONE						

Land Breakdown

Lnd Code	Desc	Units	Adjustments	Eff Rate	Lnd Value
000000	VAC RES (MKT)	1.000 LT - (.000AC)	1.00/1.00/1.00/1.00	\$19,000.00	\$19,000.00
009945	WELL/SEPT (MKT)	1.000 UT - (.000AC)	1.00/1.00/1.00/1.00	\$2,000.00	\$2,000.00

PLAT BOOK NO. 4

SHEET 1 OF 1 SHEET




LEGEND:

- DENOTES PERMANENT REFERENCE POINTS (P.R.M.)

NOTE: IRON PIPES HAVE BEEN SET ON ALL LOT CORNERS

CURVE			DATA		
LOT NO.	DELTA	RAD.	TAN.	LENGTH	CHORD
20	61° 58' 46"	676.20	408.27	731.48	688.50
41	05° 42' 50"	676.20	37.75	67.41	
42	17° 34' 58"	676.20	104.37	207.50	206.49
43	52° 08' 18"	726.20	349.95	686.10	664.83



DESCRIPTION:

[illegible]

DEDICATION:

WE, THE OWNERS AND MORTGAGEES OF THE LANDS DESCRIBED AND SHOWN ON THIS PLAT HAVE CAUSED SAID LANDS TO BE SUBDIVIDED AND PLAT HEREON AND DO HEREBY DEDICATE TO THE PUBLIC FOREVER THE STREETS AS SHOWN ON THIS PLAT, FAIRVIEW ESTATES.

Donald M. Davis OWNER
William G. Shubert WITNESS
R. P. Ford MORTGAGEE
C. J. Smith WITNESS

WITNESS Ray Turner

WITNESS Landon Shaw

ACKNOWLEDGEMENT:

STATE OF FLORIDA:
COUNTY OF ALACHUA:
I, James, DAY OF June, 1978, BEFORE ME PERSONALLY APPEARED THE OWNER AND MORTGAGEE ABOVE DEDICATION AND THAT THEY ACKNOWLEDGE BEFORE ME THAT THE EXECUTION OF THIS DEDICATION IS THEIR FREE AND VOLUNTARY ACT.

MY COMMISSION EXPIRES Oct. 27 1919 Notary Public STATE OF Virginia

Name, P. L. 5194, 10/27/1919
My. 20/1919, 10/27/1919, D. 31, 1919
Notary Public, 10/27/1919, 10/27/1919, 10/27/1919

COUNTY ATTORNEY'S CERTIFICATE:

HEREBY CERTIFY THAT I HAVE APPROVED THIS PLAN AS TO WORDING OF DEDICATION AND CERTIFICATION FOR COLUMBIA COUNTY, FLORIDA.

SURVEYOR'S CERTIFICATE

DO HEREBY CERTIFY THAT THIS IS A TRUE AND CORRECT REPRESENTATION OF THE LANDS SURVEYED, AND THAT THE SURVEY WAS MADE IN ACCORDANCE WITH THE REQUIREMENTS OF CHAPTER 177, FLORIDA STATUTES.

HERBERT C. PARRISH
REG. LAND SURVEYOR FLA. CERT. NO. 1251
DATE: 11/1/51

COUNTY COMMISSIONER'S APPROVAL

WE DO HEREBY APPROVE AND ACCEPT THIS PLAT AND THE STREETS DEDICATED HEREIN FOR THE PUBLIC USE OF CALIFORNIA COUNTY ELECTION

CHAIRMAN OF THE BOARD

TEST: *Man S. Chis* DATE: 1

CLERK OF THE CIRCUIT COURT'S APPROVAL

THIS PLAT HAS BEEN APPROVED AND FILED FOR RECORD, THIS THE 16 DAY OF June, 1978, IN PLAT BOOK NO. 4 PAGE 1 OF THE PUBLIC RECORDS OF COLUMBIA COUNTY, FLORIDA.

Maryb Chas Bybee
CLERK OF THE CIRCUIT COURT

213'

PART II - SITEPLAN

SEP 75



LIMITED POWER OF ATTORNEY


I, Doug McGauley, license # IH-0000623 do hereby authorize Dale Burd, Kelly Bishop or Rocky Ford to be my representative and act on my behalf in all aspects of applying for a MOBILE HOME MOVE ON PERMIT to be placed in Columbia County Florida.

Signed

(Date)

Sworn and subscribed before me this 9 day of SEPT, 2007.

Notary Public



MOBILE HOME INSTALLER AFFIDAVIT

As per Florida Statutes Section 320.8249 Mobile Home Installers License:

Any person who engages in mobile home installation shall obtain a mobile home installer's license from the Bureau of Mobile Home and Recreational Vehicle Construction of the Department of Highway Safety and Motor Vehicles pursuant to this section. Said License shall be renewed annually, and each licensee shall pay a fee of \$150.

I, Doug McGauley, license number IH - 0000623 do hereby state that the installation of the manufactured home for (applicant) Dale Burd, Rocky Ford or Kelly Bishop (customer name) Doolen in Columbia County will be done under my supervision.

Doug McGauley
Signature

Sworn to and subscribed before me this 9 day of SEPT, 2007.

Notary Public: [Signature]



PERMIT NUMBER

Installer Don McFarley License # 0000623


Address of home being installed 2451 SW CL 188
FORE WHITE RD 21038

Manufacturer Horton Length x width 16x76

NOTE: if home is a single wide fill out one half of the blocking plan
if home is a triple or quad wide sketch in remainder of home

I understand Lateral Arm Systems cannot be used on any home (new or used)
where the sidewall ties exceed 5 ft 4 in. Installer's initials OLM

Typical pier spacing



New Home ☒ Used Home ☐

Home installed to the Manufacturer's Installation Manual ☒

Home is installed in accordance with Rule 15-C

Single wide ☒ Wind Zone II ☒ Wind Zone III ☐

Double wide ☐ Installation Decal # 291024

Triple/Quad ☐ Serial # H210400

PIER SPACING TABLE FOR USED HOMES

Load bearing capacity (sq in)	16' x 16' (256)	18 1/2' x 18 1/2' (342)	20' x 20' (400)	22' x 22' (484)	24' x 24' (576)	26' x 26' (676)
1000 psf	3'	4'	5'	6'	7'	8'
1500 psf	4' 6"	6'	7'	8'	9'	10'
2000 psf	6'	8'	9'	10'	11'	12'
2500 psf	7' 6"	9'	10'	11'	12'	13'
3000 psf	8'	10'	11'	12'	13'	14'
3500 psf	8'	10'	11'	12'	13'	14'

* Interpolated from Rule 15C-1 pier spacing table.

PIER PAD SIZES

I-beam pier pad size 23x31
Perimeter pier pad size 16x16
Other pier pad sizes (required by the mfg.) _____

Draw the approximate locations of marriage wall openings 4 foot or greater. Use this symbol to show the piers.

List all marriage wall openings greater than 4 foot and their pier pad sizes below:

Opening _____ Pier pad size _____

POPULAR PAD SIZES

Pad Size	Sq Ft
16 x 16	256
16 x 18	288
18.5 x 18.5	342
16 x 22.5	361
17 x 22	372
13 1/4 x 26 1/4	348
20 x 20	400
17 3/16 x 25 3/16	44
17 1/2 x 25 1/2	448
24 x 24	576
26 x 26	676

ANCHORS

4 ft ☒ 5 ft ☐

FRAME TIES

within 2' of end of home spaced at 5' 4" oc ☒

TIEDOWN COMPONENTS

OTHER TIES

Longitudinal Stabilizing Device (LSD)
Manufacturer _____
Longitudinal Stabilizing Device w/ Lateral Arms
Manufacturer _____

Sidewall Longitudinal Marriage wall Shearwall
Numb 14

PERMIT NUMBER

POCKET PENETROMETER TEST

The pocket penetrometer tests are rounded down to 1500 psf or check here to declare 1000 lb. soil without testing.

X 1500 X 1500 X 1600

POCKET PENETROMETER TESTING METHOD

1. Test the perimeter of the home at 6 locations.
2. Take the reading at the depth of the footer.
3. Using 500 lb. increments, take the lowest reading and round down to that increment.

X 1500 X 1600 X 1600

TORQUE PROBE TEST

The results of the torque probe test is 280 inch pounds or check here if you are declaring 5' anchors without testing. A test showing 275 inch pounds or less will require 5 foot anchors.

Note: A state approved lateral arm system is being used and 4 ft. anchors are allowed at the sidewall locations. 1 understand 5 ft anchors are required at all centerline tie points where the torque test reading is 275 or less and where the mobile home manufacturer may require anchors with 4000 lb. holding capacity.

ALL TESTS MUST BE PERFORMED BY A LICENSED INSTALLER

Installer Name

Doug McEachly

Date Tested

9-17-07

Electrical

Connect electrical conductors between multi-wide units, but not to the main power source. This includes the bonding wire between multi-wide units. Pg. 4

Plumbing

Connect all sewer drains to an existing sewer tap or septic tank. Pg. 5

Connect all potable water supply piping to an existing water meter, water tap, or other independent water supply systems. Pg. 6

Site Preparation

Debris and organic material removed ☒ Swale ☒ Pad ☐ Other ☐

Fastening multi wide units

Floor: Type Fastener: Length: Spacing: Walls: Type Fastener: Length: Spacing: Roof: Type Fastener: Length: Spacing: For used homes a min. 30 gauge, 8" wide, galvanized metal strip will be centered over the peak of the roof and fastened with galv. roofing nails at 2" on center on both sides of the centerline.

Gasket (weatherstripping requirement)

I understand a properly installed gasket is a requirement of all new and used homes and that condensation, mold, mildew and buckled marriage walls are a result of a poorly installed or no gasket being installed. I understand a strip of tape will not serve as a gasket.

Installer's initials

Type gasket

Pg.

Installed: Between Floors Yes Between Walls Yes Bottom of ridgebeam Yes

Weatherproofing

The bottomboard will be repaired and/or lapped. Yes Pg. 9 Siding on units is installed to manufacturer's specifications. Yes Fireplace chimney installed so as not to allow intrusion of rain water. Yes

Miscellaneous

Skirting to be installed. Yes ☒ No ☐ Dryer vent installed outside of skirting. Yes ☐ N/A ☒ Range downflow vent installed outside of skirting. Yes ☐ N/A ☒ Drain lines supported at 4 foot intervals. Yes ☐ Electrical crossovers protected. Yes ☐ Other: ☐

Installer verifies all information given with this permit worksheet is accurate and true based on the manufacturer's installation instructions and or Rule 16C-1 & 2

Installer Signature

[Signature]

Date

9/20/07

SINGLE SECTION PIER LOADS

HORTON HOMES

PIER LOADS SINGLE 16 WIDE

16' WIDE WITH MAX. 4 INCH OVERHANG
(184" FLOOR WITH MAX. 4 INCH OVERHANG) 20 PSF LIVE LOAD


MAX. PIER SPACING	PIER LOADS IN POUNDS	MIN. FOOTING AREA (SQ. INCHES) ** 256 SQ. INCHES MIN. ** FOR SOIL BEARING CAPACITY SPECIFIED					
		SOIL BEARING CAPACITY	1000 PSF	1500 PSF	2000 PSF	2500 PSF	3000 PSF
4'-0" O.C.	2702		481	309	256 **	256 **	256 **
5'-0" O.C.	3378		589	379	279	256 **	256 **
6'-0" O.C.	4053		697	448	330	262	256 **
7'-0" O.C.	4729		805	518	382	303	256 **
8'-0" O.C.	5404		913	588	433	343	284

- PIERS TO BE INSTALLED NOT MORE THAN 2'-0" FROM EACH END OF FLOOR AND AT A MAXIMUM PIER SPACING AS SPECIFIED IN CHART SHOWN ABOVE
- INDIVIDUAL PIER SPACING MAYBE EXCEEDED BY UP TO 10% SO LONG AS THE AVERAGE SPACING DOES NOT EXCEED TABULATED SPACING VALUES SHOWN ABOVE

SIDEWALL OPENING FOOTING AREAS

MAXIMUM OPENING	PIER LOADS IN POUNDS	MIN. FOOTING AREA (SQ. INCHES) ** 256 SQ. INCHES MIN. ** FOR SOIL BEARING CAPACITY SPECIFIED					
		SOIL BEARING CAPACITY	1000 PSF	1500 PSF	2000 PSF	2500 PSF	3000 PSF
4'-0"	480		256 **	256 **	256 **	256 **	256 **
6'-0"	720		256 **	256 **	256 **	256 **	256 **
8'-0"	960		256 **	256 **	256 **	256 **	256 **
10'-0"	1200		256 **	256 **	256 **	256 **	256 **
12'-0"	1440		279	256 **	256 **	256 **	256 **
14'-0"	1680		317	256 **	256 **	256 **	256 **
16'-0"	1920		356	256 **	256 **	256 **	256 **
18'-0"	2160		394	256 **	256 **	256 **	256 **
20'-0"	2400		433	278	256 **	256 **	256 **
22'-0"	2640		471	303	256 **	256 **	256 **
24'-0"	2880		509	327	256 **	256 **	256 **
26'-0"	3120		547	352	259	256 **	256 **
28'-0"	3360		586	377	278	256 **	256 **
30'-0"	3600		625	401	296	256 **	256 **

- THE SIDEWALL OPENING CHART ABOVE SPECIFIES THE PIER LOAD AND MIN. FOOTING AREA REQUIRED FOR SUPPORTING END STUD COLUMNS (CLEAR SPAN ON ONE SIDE OF COLUMNS ONLY). FOR PIERS SUPPORTING CENTER STUD COLUMNS ADD THE CLEAR SPANS ON EACH SIDE OF CENTER COLUMNS TOGETHER BEFORE USING THE TABLE TO DETERMINE THE REQUIRED PIER LOAD AND FOOTING AREA.
- SHEARWALL PIERS MUST BE DESIGNED TO SUPPORT A PIER LOAD OF 4000 POUNDS EXCEPT FOR SHEAR WALLS WITH PLF RATINGS THAT DO NOT EXCEED 300PLF, THE PIER DESIGN LOAD MAYBE REDUCED TO 3000 POUNDS.



Horton


TYPICAL FOUNDATION PLAN

FOUNDATION DIMENSIONS			
	A	B	C
1-1 WIDE	13'-4"	32'-1/4"	95'-1/2"
1-3 WIDE	15'-4"	44'-1/4"	95'-1/2"

NOTES:

1. THIS FOUNDATION DIAGRAM IS FOR 95' 1-1-BEAM SPACING ONLY.
2. OR BELOW LARGE CONCENTRATED LOADS (I.E. WATER BEDS).
3. ADDITIONAL PIERS ARE REQUIRED AT ENDS OF ALL SHEARWALLS IN ACCORDANCE WITH THE SETUP MANUAL. SHEARWALLS ARE MARKED ON HOUSE WITH GREEN TIE DOWN BRACKETS. REFER TO SETUP MANUAL FOR ADDITIONAL INFORMATION.
4. MARRIAGE WALL PIERS (MULTI UNIT HOMES ONLY) ARE REQUIRED AT MARRIAGE WALL OPENINGS GREATER THAN 48" IN WIDTH. MARRIAGE WALL PIER LOCATIONS SHOWN ON PLAN ARE OFFSET 12" MAX. (CENTERLINE OF STRAP) TO ALLOW FOR VERTICAL ANCHORS (STRAPS).
5. MAXIMUM PIER SPACING IS 8'-0". ACTUAL REQUIRED PIER SPACING WILL VARY ACCORDING TO FOOTING SIZE AND SOIL CAPACITY. REFER TO SETUP MANUAL FOR ADDITIONAL INFORMATION.
6. PIER SPACING MAY VARY TO ALLOW FOR LONGITUDINAL TIEDOWNS.
7. REFER TO MANUAL FOR ADDITIONAL SETUP INFORMATION.

NOTE: SEE OTHER DRAWINGS FOR ADDITIONAL SPECIFICATIONS



PLAN KEY

- INDICATES TYPICAL FRAME PIER (UNDERNEATH I-BEAMS) - REFER TO SETUP MANUAL FOR INFORMATION.
- INDICATES TYPICAL MARRIAGE WALL, SHEARWALL, AND SIDEWALL PIER--REFER TO SETUP MANUAL FOR INFORMATION.
- INDICATES TYPICAL LONGITUDINAL TIEDOWN LOCATION (UNDERNEATH I-BEAMS) - REFER TO SETUP MANUAL FOR INFORMATION WHEN REQUIRED.


HORTON HOMES, INC.
DYNASTY HOMES, INC.

TYPICAL FOUNDATION PLAN

SCALE: N.T.S.


PIER APPLICATIONS

(1) 4X4 OR (2)-2X4'S ON EDGE
(NAILED TOGETHER) SPANNING
MINIMUM 2 FLOOR JOISTS




SIDEWALL APPLICATION
BLOCKS PARALLEL AND RECESSED
BACK FROM EDGE OF FLOOR


EXTERIOR
SIDE WALL



SIDEWALL APPLICATION
BLOCKS PARALLEL WITH
EDGE OF FLOOR




MARRIAGE WALL APPLICATION



FOOTING CAPACITY USE
4000 LBS OR 3000 LBS
FOR SHEARWALL 300 PLF
OR LESS.

WHEN OUTRIGGER IS
LOCATED AT SHEARWALL
LOCATION, INSTALL
SUPPORT PIER WITHIN
6 INCHES OF OUTRIGGER
LOCATION.

SHEARWALL PIER



DOUBLIN

STATE OF FLORIDA
DEPARTMENT OF HEALTH

APPLICATION FOR ONSITE SEWAGE DISPOSAL SYSTEM CONSTRUCTION PERMIT

07-0746

-----PART II - SITEPLAN-----

5 Feb 77

↑ SLOPE

N
I
R
T
H

WFL2
740

WP22
1441

WL

1104 SQ FT

DRIVE

$$\frac{u + 3}{875}$$

3 LINES

DITCH

CR 138

Notes: _____

Site Plan submitted by: Paula D. [Signature]

MASTER CONTRACTOR

Plan Approved ✓ Not Approved _____

Date 9/24/07

By Mr. D. L. Smith Columbia County Health Department

DH 4015, 10/96 (Replaces HRS-H Form 4016 which may be used)
(Stock Number: 5744-002-4015-6)

COLUMBIA COUNTY OFFICE

M/H OCCUPANCY

COLUMBIA COUNTY, FLORIDA

Department of Building and Zoning Inspection

This Certificate of Occupancy is issued to the below named permit holder for the building and premises at the below named location, and certifies that the work has been completed in accordance with the Columbia County Building Code.

Parcel Number 26-7S-16-04323-040

Building permit No. 000026273

Permit Holder DOUG MCGAULEY

Owner of Building KARLA DOOKEN

Location: 2451 SW CR 138, FT. WHITE, FL



Date: 10/05/2007

Tony Dicks

Building Inspector

POST IN A CONSPICUOUS PLACE
(Business Places Only)